



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G125

Office of the Asst. Executive Engineer (Ele.), C, O&M Section -TUMKUR RURAL SUB DIVISION1

Change Request Note For: 4665551

Application No	62222108250005
Application Submission Date	12-08-2025
Applicant Name	M/S VINN TECHNOLOGIES
Applicant Address	PLOT NO 214A ROAD NO 23 1ST PHASE VN PURA INDUSTRIAL AREA0
Application For	LOAD CHANGE
Additional Load	45KVA
Existing Load KW/HP/KVA	0.00 /0.00/150.00
New Load KW/HP/KVA	0 /0.00/195.00
Change Request Fee	Rs: 250/-
Total Amount	Rs: 250 /-

Circle : TUMKUR Division : TUMKUR Subdivision : TUMKUR RURAL SUB DIVISION1 Section : TUMKUR RURAL SUB DIVISION1

NOTE 1\*\*: Please Make the payment for the above and submit the receipt Details After Payment.

NOTE: This Demand Note generated as per the intimation provided at the time of application. At the time of inspection if additional SLC or Additional Load is required a supplemental demand note will be issued. Your installation will be serviced after all the payments are received.

BENGALORE ELECTRICITY SUPPLY  
COMPANY LTD.  
TUMKUR RURAL SUB DIVISION1

NO: 2222101006152  
NO: 2222101  
DATE: 12/08/2025 11:34:30 AM  
NO: 619067  
NO: 62222108250005  
NO: 4665551  
NO: M/S VINN TECHNOLOGIES  
: PLOT NO 214A ROAD NO 23  
: VN PURA INDUSTRIAL AREA0  
: N/A  
NO: X7vdi  
NO: Rs.250  
NO: NON-REVENUE  
NO: ADDITIONAL LOAD FEES  
(one hundred Fifty Only)

I  
~  
E  
A  
S  
Y  
P  
A  
Y

I  
E  
A  
S  
Y  
P  
A  
Y

THANKS FOR USING CASHCOUNTER





# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(WHOLLY OWNED GOVT. OF KARNATAKA UNDERTAKING)

OFFICE OF THE EXECUTIVE ENGINEER(E), C, O&M DIVISION, KOTHITHOPU ROAD, TUMKUR-572 102

Ph: 2955552, email: eetumkurdn@gmail.com,

No: EE(EI)/AEE(O)/AE-1/2024-25/ 23313-15

Date: 06 FEB 2025

WO No : C-32466/29.01.2025

SELF EXECUTION WORK MATERIALS NOT TO DRAWN

## WORK EXECUTION CERTIFICATE

Sub: For Arranging Additional HT Power supply to an extent of 45KVA in addition to the existing 150KVA Totalling 195KVA to the HT installation bearing R R No: RHT-96 in favour of M/s.VINN TECHNOLOGIES, Plot No:214A, Road No:23, 1st Phase Vasanthanarasapura, Tumkur in Kora Section, RSD-1, Tumkur. (Under Self Execution Basis).

- Ref: 1) T.O.Power Sanction letter No: EE(EI)/AEE(O)/AE-1/2024-25/19391-93/20.12.2024.  
2) Payment Certificate Letter No: AEE(E)/AE(T)/RSD-1/2024-25/5297/24.01.2025.  
3) BESCOM/CGM(Proj)/DGM-3/BC-14/CYS-117/13.01.2023.  
4) BESCOM/GM(M&C)/CYS-138/2022-23/05.01.2023.  
5) CEA (Measures relating to Safety & Electrical Supply) Regulations-2010.  
6) KERC/COS/D/13/14-15, Bangalore, 25th August, 2014.

\*\*\*\*\*

"This estimate is sanctioned in this office vide letter cited under ref(1) : For Arranging Additional HT Power supply to an extent of 45KVA in addition to the existing 150KVA Totalling 195KVA to the HT installation bearing R R No: RHT-96 in favour of M/s. VINN TECHNOLOGIES, Plot No:214A, Road No:23, 1st Phase Vasanthanarasapura, Tumkur in Kora Section, RSD-1, Tumkur. (Under Self Execution Basis).

- 1) AISD Charges ₹=1,43,700/- is collected vide Rt.No: 20250000573 dated 23.01.2025.
- 2) 05% Supervision Charges on Est.Cost ₹=2,107/- is collected vide Rt.No: 20250000574 dated 23.01.2025.
- 3) S.C Charges - ₹= 250/- is collected vide Rt No: 20250000575 dated 23.01.2025.

1. The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout/M.S Building.

66KV	220KV	400KV
18 mtrs (9 mtrs on either side from the center of the line)	35 mtrs (17.5 mtrs on either side from the center of the line)	51 mtrs (25.5 mtrs on either side from the center of the line)

The conditions agreed and undertaken in the undertaking submitted shall be adhered and complied.

2. As per Circular No. BESCOM/BC-33/ F-2338/ CYS-11/05.05.09 vide Sl. No. 15(a); the materials procured by the contractors for execution of total turnkey/ Partial turnkey and self-execution, works shall be invariably be subjected to inspection by competent authority for its quality and specification as approved by BESCOM before commencement of works. The material placed by you is of 1-year guarantee and you have to maintain the same for 1 year.
3. All the electrical equipment such as LBS, transformers, metering cubicle and Meter board shall be provided in Ground floor only.
4. Consequent to the amendment by the regulation by the Hon'ble KERC vide reference, the work shall be executed, completed and shall avail service within 90 days of this work order, else the application for power supply will be deemed as CANCELLED. On cancellation of the application, registration/re-registration cum Supervisory charges shall stands forfeited.
5. As per the KERC. COS under Clause-8.03 the applicant shall furnish the list showing the name plate details of machinery such as make, capacity and layout plan of the premises with in which he intends to make use of the power after installation of the machinery.
6. As per the KERC. COS under Clause-8.10 the capacity of any individual machinery/equipment installed/connected shall not be more than the contract demand.

P.T.O.