



Bangalore Electricity Supply Company Ltd.

No. AEEE / HTR / DYHT 342

Office of the
Asst. Executive Engineer (Ele),
H.T. Rating Sub-Division
BRAZ, BESCOM

To,
The Asst. Executive Engineer (Ele)
Devara halli, O&M Sub-Division
BESCOM Devara halli

Reduction of load
Existing - 400 KVA
Reduction - 150 KVA

Date 10-02-2026

Remaining Total - 250 KVA

Sir,

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 10-02-2026. You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

Previously rated on 26-05-2024

R.R. No. DYHT 342 CD 250 KVA. Meter Constant 1250 Activity Industry
Name & Address of the Consumer M/S LAUAK CIM Aerospace Pvt Ltd.
No: 105 + 106 H.T. Defence & Aerospace Park SE2
in Boodigera O&M unit of Devara halli Sub division.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

As per your request letter reference no: AEE/DHE/
A.E. 11 / 2025-26 / 4806 dt: 10-02-2026 Reduction of load

3. ADVICE ON REVENUE MATTER : Sanctioned from 400 KVA to 250 KVA. Hence
the existing 20/12 C.T. replaced by 12.5/1A and Calibera
the meter before & after replacement of C.T. error is
within permissible limits.

4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint meter data down loaded &
analyzed recording found correct.

FIR for K-2000 - 1627.969
FIR for K-1250 - 1627.969

Yours faithfully,
V. H. Hosakote
Asst. Executive Engineer (Ele)
H.T. Rating Sub-Dvn, BRAZ

Copy for kind information to :

- The Executive Engineer Ele., MT Division, BRAZ, Bangalore
- Executive Engineer Ele., O&M Hosakote Division, BESCOM, Hosakote

In case of discrepancies :

- Chief Engineer Ele., BRAZ, B'lore.
- Superintendent of Police, Vigilance
- Accounts Officer, Internal Audit.