



Bangalore Electricity Supply Company Ltd.

HT Rating Report **11864**

Office of the
Executive Engineer (Ele).,
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

No. EE MT / AEE(O) / BRAZ / AEE HTR /

To,
The Asst. Executive Engineer (Ele).,
Magadi O&M Sub-Division
BESCOM,

Date..... *18.11.25*

Sir,

Subject : Rating Report of HT / ~~EHT~~ Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on *18.11.25*
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

Previously rated on *23.03.22*

R.R. No. *PNA5M20-09* CD..... *170* KVA. Meter Constant. *1000 to 1500* Activity..... *water supply (H71)*
Name & Address of the Consumer..... *Chief officer*
TMC, Monchonabele

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

The installation meter is calibrated after cubicle replacement work, the error record is found to be within permissible limits.

3. ADVICE ON REVENUE MATTER :

Disced connection given by barring C.T. & P.T. due to existing cubicle faulty. From Jun-2022. Now replaced with releaved good metering cubicle. Constant changed from 1000 to 1500. As per clause 27-03 of KERC condition of supply

4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

show claim for overage billing for disced connection period.
Summary of analysis if rated against complaint.....

Yours faithfully,

[Signature]
(ಮುಖಪುಸ್ತಕ / ಎ.ಎಸ್.ಎಂ)
Asst. Executive Engineer (Ele.) (ಎ)

HT Rating Sub-Division (ಎಂ.ಟಿ.ಡಿ.) ಉಪ ವಿಭಾಗ
ಮುಖಪುಸ್ತಕ, ಮಿ.ಟಿ.ಇ.ಇ. ಕಛೇರಿ, ಬಿ.ಬಿ.ಸಿ. ಕೋನರವರು
BRAZ, BESCOM, Bangalore.

Copy for kind information to :

1. The Executive Engineer Ele., MT Division, BRAZ, Bangalore.
2. Executive Engineer Ele, O&M Division, BESCOM,

In case of discrepancies :

3. Chief Engineer Ele., BRAZ, B'lore.
4. Superintendent of Police, Vigilance
5. Accounts Officer, Internal Audit.