



- b. The power supply will be arranged at 230V .
- c. The Tariff applicable to your installation will be LT1-Urban, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level
- h. Amount through DD should be paid in the name AEE BESCOM NELAMANGALA .
- i. Intimation is valid up to 30 days from the date of issue.

You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.

Sl No	Description	Qty	Rate	GST (%)	Amount
1	LT AC Single Phase 2 Wire, 5-30 Amps Smart Energy Meter, Class 1.0 Accuracy with communication Module without Box	8	4067.8000	18 %	38400.00

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., NELAMANGALA Sub-division, BESCOM for information and further needful.

Yours Faithfully,

*[Signature]*  
Assistant Engineer (Technical),  
NELAMANGALA, BESCOM

*[Signature]* Yours Faithfully,  
Assistant Executive Engineer Ele.,  
NELAMANGALA, BESCOM

Copy to:

- The Executive Engineer Ele. C, O&M NELAMANGALA Division, BESCOM
- The Asst. Executive Engineer Ele., C, O&M NELAMANGALA Sub division, BESCOM

*Para Tida factory  
single phase to 3 phase  
for 3kw installation  
12/12*