



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka Undertaking)

Ph. No: 080-22340226
Mob. No. : 9448093022

Office of
The Assistant Executive Engineer (Ele),
MT Lab, MT Sub Division, BRAZ
BESCOM, Hosakote S/d

No: AE/MTLAB/HKHT/2025-26/LAB- 47

DATE: 17/10/2025

CUSTOMER INFORMATION,

Reason for test : **Fixing of SRTPV Installation.**

ATB-8588, V.ROOPA, ATTIBELE.

BESCOM SEAL NO : BRM1148751.

Meter Details:

HPL, 1 PHASE, BI-DIRECTIONAL, SPEM 02, 1 PHASE 2 WIRE, 6400 IMP/KWH.

RESULT : The Meter Bearing **SL No :54267878**, is tested for Accuracy Errors are to be within permissible limits as per IS13789. The main parameters reading of the meter after testing are as follows.

IMPORT SIDE

KWH	2
-----	---

EXPORT SIDE

KWH	1
-----	---

NOTE : The test confirms only the accuracy of the meter, necessary approvals/field condition are to be verified by the concerned officer.

TESTED BY

ASSISTANT ENG(ELE)
MT LAB HOSAKOTE