



Bangalore Electricity Supply Company Ltd.

HT Rating Report

Page 1 of 3
Format F-09-14

No. EE MT / AEE(O) / BRAZ / AEE HTR / 266-62 dt: 04/1/2025

To,
The Asst. Executive Engineer (Ele),
Devana Halli O&M Sub-Division
BESCOM, Devana Halli

Reduction of load
R.R. No: DYHT 225
Ex: 750 KVA
Reduction - 250 KVA
500 KVA

Office of the
Executive Engineer (Ele),
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

Date: 24/02/2025

Sir,
Subject : Rating Report of HT/EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 24/02/2025.
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

R.R. No. DYHT 225 CD 500 KVA.

Previously rated on 07/05/2024

Name & Address of the Consumer: Sri Maruthi Enterprises
Halli village in Devana Halli sub division
BESCOM Bangalore
Activity: Stone Crusher
Hedderway from
Devana Halli

OBSERVATION & ADVICE ON TECHNICAL MATTER :

As per your letter reference no. AEE / AEE(O) / DML / 2025-2
1142 dt: 04/01/2025 Reduction of load sanctioned from
750 KVA to 500 KVA. Hence the existing

ADVICE ON REVENUE MATTER : 40/11 C.T's replaced by 25/11 C.T's and calibrated to
meter before & after replacement of C.T's error is
within permissible limit.

DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint: Meter data down loaded &
analyzed according found correct.

Yours faithfully,

Asst. Executive Engineer (Ele),
HT Rating Sub Division, HRSR
BRAZ, BESCOM, Bangalore.

Copy for kind information to :

The Executive Engineer Ele., MT Division, BRAZ, Bangalore.
Executive Engineer Ele, O&M HRSR

case of discrepancies :

Division, BESCOM, HRSR

Chief Engineer Ele., BRAZ, B'lore.
Superintendent of Police, Vigilance
Accounts Officer, Internal Audit.