

ಸೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ
ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ
ಮತ್ತು ಪಾಲನೆ ವಿಭಾಗ, ಚಂದಾಪುರ,
ಬೆಂಗಳೂರು-560081
ತಾ. 080-2781003



BANGALORE ELECTRICITY SUPPLY COMPANY
(A Government of Karnataka Undertaking)
O&M Division, CHANDAPURA
BESCOM, Bangalore-560081
E-Mail: eechndpr.work@gmail.com

NO : EE(E)/CDP/AEE(O)/AET-1 /2025-26 / 2886-85

Date :

25 JUN 2025

To,
M/S Accord Laser Machining Pvt Ltd,
Plot No-52A, Next to KIADB Office,
Bommasandra Industrial Area,
Bengaluru-560099.
Ref RR No-CDPHT-327.

Power Sanction Letter for HT
Reduction of Load.

- Sub:- Intimation for Arranging Reduction of contract demand of the existing HT installation bearing RR No. CDPHT-327 from 200 KVA to 130 KVA (reduction 70 KVA) under HT2a tariff in favour of M/S Accord Laser Machining Pvt Ltd, Plot No.52A, Bommasandra I/A, Anekal Taluk, Bengaluru
- Ref:- 1. Your Application No: 61322106250023 Dated 19-06-2025 ; HTRD-16.
2. AEE, Chandapura SD Office Letter Ref No : 1778 Dated : 21-06-2025.

*** *****

With reference to the above subject, as per the recommendation of the Assistant Executive Engineer (Ele), Chandapura Sub-division vide ref-(2), power sanction is hereby recorded for arranging Reduction of contract demand of the existing HT installation bearing RR No. CDPHT-327 from 200 KVA to 130 KVA (reduction 70 KVA) under HT2a tariff in favour of M/S Accord Laser Machining Pvt Ltd, Plot No.52A, Bommasandra I/A, Anekal Taluk, Chandapura Sub-Division under Self Execution, subject to the following conditions and observance of ERC / BESCOM norms in force.

The proposed for arranging power supply is as follow:

Regular source:

Station: 220/66/11 KV Yarandanahalli MUSS which has a peak load of 59 MW with installed capacity of power transformers 3*31.5 MVA.

Feeder: Existing F-11 Victory Glass feeder which has a peak load of 296 Amps with 3x400 Sq.mm XLPE HT UG cable/Coyote/Rabbit.

The following works are proposed under self-execution.

BESCOM portion.

> Replace the existing 11 KV, CTs of ratio 10/1A, 0.2S class by new CTs of ratio 7.5/1A, 0.2s class.

You are requested to pay the following amount by way of Demand Draft drawn in favour of the AEE, Chandapura SD, BESCOM, at the office of Assistant Executive Engineer (Ele), Chandapura Sub-division, within 90 days from the date of this intimation and furnish the payment certificate to this office for taking further action failing which the power sanction will stand cancelled.

Deposit Held : 10,61,720 /-			
Deposits	Amount in Rs	CGST @ 9%	SGST @ 9%
5% SC payable (Estimate Cost of Rs.46,793/-)	2,340/-	211/-	211/-
TOTAL (Two Thousand Seven Hundred and Sixty Two Rupees only)			

TOTAL (Two Thousand Seven Hundred and Sixty Two Rupees only)

- The appropriate tariff shall be applicable as per prevailing **KERC tariff order** for any further clarification, **Chandapura**.
- BESCOM.
- You are liable to pay the tariff minimum charges from the date of commencement of supply (i.e., actual date of availing of power supply or expiry of 30 days' notice issued by the BESCOM whichever is earlier) as indicated in the agreement.
- You have to install approved shunt capacitors of appropriate capacity as to fail to avail power supply.
- You have to maintain the power factor at not less than 0.9
- The power tariff applicable to your installation will be **HT-2A** tariff or as in time to time.
- In future, if the total load requirement exceeds 7500 kVA then the applicant shall establish 66/11 KV substation at their own cost in the above premises for execution and avail power supply on 66 KV EHT bases as per KERC regulations.
- The Power supply shall be arranged duly observing all corporate norms.
- 11 KV** systems shall be as per KPTCL/ BESCOM standard practices.
- The Consumer shall execute the works under self-execution through Karnataka government approved Class-1 Electrical Contractor in co-ordination and guidance of KPTCL/BESCOM officials.
- The major materials like Metering cubicle / 11 KV CT & PT, shall be procured from agencies only from the BESCOM approved vendors and it should be tested at MT Lab.
- The materials procured shall be in accordance with the IE/BESCOM specifications and the materials shall be got inspected by **Jurisdictional Engineer Ele.**, before procurement. The copies of the invoices / bills of the purchased shall be submitted as a proof of purchased from the approved dealers.
- You shall submit the copies of the invoices / bills in respect of materials purchased for proof of having purchased the materials from the approved vendors / dealers.
- Guarantee shall be furnished for a period of not less than "one year" for the used for the works as well as for the quality of work carried out from the date over the lines and equipment's by BESCOM/ KPTCL.
- Proof of having purchased the materials and used for execution of works by a reputed firm shall be verified wherever necessary.
- The BESCOM / KPTCL is not responsible in whatsoever manner regarding disputes that may arise at a later stage.
- After payment of above charges and fulfillment of the conditions, the approval shall be issued from this office.
- The materials released (as shown in credit Estimate as per the 7th Schedule) returned to the concerned BESCOM stores.
- Any delay in making payment, not fulfilling the above conditions within 90 days of power sanction/Application deemed to have been cancelled as per the stipulated in the KERC Amendment vide clause No. 4.03 (ii). **The registration processing fee paid shall stand forfeited.**
- You should clear the out-standing arrears, if any, in respect of the existing installation.
- You should abide by the conditions of supply of electricity 2004 is in subsequent amendments.

Thanking You,

By to:-

Assistant Executive Engineer
Assistant Engineer(T)

In case, applicant fails to meet the above conditions to arrange power supply, the power sanction is deemed to have been cancelled.
You have to pay any variation / difference of charges, if any, payable to BESCOM/KPTCL if any in future as per subsequent amendments of KERC.
You shall abide by the prevailing Regulations and changes from time to time.

For any further clarifications, you may contact the Assistant Executive Engineer, O&M Division, **Chandapura**.

For any 765/400/220/66/11 KV lines passing adjacent/nearby/on the premises, mandatory clearance certificate should be obtained from the competent authority by the operator / concerned EE of BESCOM before servicing of the installation. In case of any violation in this regard concerned officers will be held responsible.

Thanking You,

Yours faithfully,


**Executive Engineer(Ele),
C, O&M Chandapura Division,
BESCOM.**

Copy to:-

1. Assistant Executive Engineer(Elec.), C, O & M Chandapura SD.
2. Assistant Engineer(T), Chandapura Division / MF.

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No: AEE/CDP/AAO/SA/2534

Office of the
Assitant Executive Engineer(Ele),
O&M Sub-Dvn, Chandapura

Dated: 06/07/25

To,
Executive Engineer (Ele)
C, O&M BESCOM
No.204 Park Road
Phase-1 Suryacity
Chandapura

Sir,

Sub: - payment of deposit reg

Ref: - Your kind Ltr :-EEE/CDP/AEE(O)/AE(T)/2025-26/ 2884-85 Dated 25.06.2025


As per your intimation letter under reference To. M/s Accord Laser Machining Pvt Ltd Plot. No 52A Next to KIADB Office , Bommasandra Industrial Area, Anekal Taluk, CHANDAPUR SUB DIVISION Anekal Taluk BANGALURU have paid the following amounts.


A/C Head	Amt in RS	Rt.No	Date
5%SC &Inclusive CGST& SGST	2762=00	1322101011463	04.07.2025
TOTAL	2762=00		

Amount in words : Rs Two Thousand Seven hundered Sixty Two Only .

This is for your kind further needful action.


General Cashier / SA
Chandapura sub division


Asst. Accounts Officer
Chandapura sub division


Asst. Executive Engineer(Ele),
Chandapura sub division

8 JUL 2025 ಸಂಖ್ಯೆ F-2252

ಬೆಂ. ಎ. ಕಂ
ಚಂದಾಪುರ ವಿಭಾಗ ಕಛೇರಿ

ಮ.ಪ.ವಿ.ಕಂ(ಪಾ).....
ಲೆಕ್ಕಾಧಿಕಾರಿ.....
ಮ.ಪ. (ಪಾ).....
ಸ. ಲೆಕ್ಕಾಧಿಕಾರಿ.....
ಮ.ಪ.ವಿ.ಕಂ(ಮ.ಪಾ).....
ಸಂ.ವ. ಲೆಕ್ಕಾಧಿಕಾರಿ.....
ಮ.ಪ. (ಪಾ).....