



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/NELAMANGALA /AE(T)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, NELAMANGALA Sub Division
BESCOM, NELAMANGALA

YASHODHAMMA S
NO:158 THOTADAGUDDADAHALLI

Madam

Sub : Arranging power supply to an extent of **2.00 KW** in favor of YASHODHAMMA S NO:158 THOTADAGUDDADAHALLI in NELAMANGALA OMU, NELAMANGALA

Ref: 1) Your application registration **1112102260286** dated **09-FEB-2026**

2) AEE/NELAMANGALA /AE(T) a/ **10-FEB-2026**

With reference to your application dated **09-FEB-2026**. Requesting for arranging power supply to an extent of **2.00 KW** power installations in favor of YASHODHAMMA S NO:158 THOTADAGUDDADAHALLI in NELAMANGALA OMU, NELAMANGALA Sub division in hereby sanctioned subject to the following Conditions.

1. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C. O&M NELAMANGALA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount (Rs.)
1112102260286	11121022602860001	LT1-Urban-DOMESTIC LIGHTING & HEATING - LT2A1	2.00 KW	48.1017-48.1017 - ISD	1630
1112102260286	11121022602860002	LT1-Urban-DOMESTIC LIGHTING & HEATING - LT2A1	2.00 KW	48.1017-48.1017 - ISD	1630
1112102260286	11121022602860003	LT1-Urban-DOMESTIC LIGHTING & HEATING - LT2A1	1.00 KW	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)	150
1112102260286	11121022602860003	LT1-Urban-DOMESTIC LIGHTING & HEATING - LT2A1	1.00 KW	55.1077-55.1077 - INFRASTRUCTURE CHARGES - NO TAX	19500
1112102260286	11121022602860003	LT1-Urban-DOMESTIC LIGHTING & HEATING - LT2A1	1.00 KW	48.1017-48.1017 - ISD	820
Total Amount in Rupees					36730

- The power supply will be arranged at 230V .
- The Tariff applicable to your installation will be LT1-Urban, or the Tariff in force From time to time.
- You have to enter into an agreement with the BESCOM in the prescribed form.
- Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- Amount through DD should be paid in the name AEE BESCOM NELAMANGALA .
- Intimation is valid up to 30 days from the date of issue.

You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.

+SLC = 1300
Rail Ticket to change
JFC
8/12/26