

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ಕಾರ್ಯ ಮತ್ತು ಪಾಲನೆ ವಿಭಾಗ, ಚಂದಾಪುರ,  
ಬೆ.ವಿ.ಕಂ, ಬೆಂಗಳೂರು-560081  
ದೂರವಾಣಿ: 080-2781003



BANGALORE ELECTRICITY SUPPLY COMPANY  
(A Government of Karnataka Undertaking)  
O&M Division, CHANDAPURA  
BESCOM, Bangalore-560081  
E-Mail: [eechndpr.work@gmail.com](mailto:eechndpr.work@gmail.com)

NO: EE (E)/CDP/AEE (O)/AE (T)/2025-26/ 1779-82

Date :

128 MAY 2025

**-: OFFICIAL MEMORANDUM:-**

- Sub: Reduction of contract demand of the existing HT installation bearing RR No. AKLHT-851 from 200 KVA to 100 KVA (reduction 100 KVA) under HT2a tariff in favour of Mr. Baabulal Hooda S/O Kallaram Hooda at Sy No-10/1 & 10/2, Thimmasandra Village, Anekal Taluk – under self-execution.
- Ref: 1. Online Application Ref No: 8409063 Dated: 26-11-2024.  
2. AEE/Anekal SD / AE (T)/2024-25 / 1239 Dated: 26-11-2024.  
3. This Office Intimation Letter Ref No: EEE/CDP/AEE (O)/AE (T)/2024-25 / 13503-04 Dated: 19-12-2024.  
4. Payment Certificate Letter Ref No:- AEE/AKL/AAO/SA/1300 Dated :20-12-2024.  
5. Circular No. BESCOM/GM(QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-186 Dated 12.02.2024.

\*\*\*\*\*

With reference to the above, as per the recommendations of the Assistant Executive Engineer Ele., Anekal Sub division vide ref-2, approval is hereby accorded for reduction of contract demand of the existing HT installation bearing RR No. AKLHT-847 from 200 KVA to 100 KVA (reduction 100 KVA) under HT2a tariff in favour of Mr. Baabulal Hooda S/O Kallaram Hooda at Sy No-10/1 & 10/2, Thimmasandra Village, Anekal Taluk, Anekal Sub-Division, as per the clause No. 34.02 KERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions:


1. The Consumer has supplied the CTs and in presence of AEE, MT division, BRAZ & the MT Staff the existing 11 KV, CTs of ratio 10 / 1A, 0.2S class of accuracy are replaced by new CTs of ratio 7.5 /1A, 0.2s class of accuracy on 29-01-2025. The cost of the Sanctioned estimate is Rs. 45,126 /-(Total rupees Forty Five Thousand & One Hundred & Twenty Six only)
2. Metering standards is as per BESCOM circular cited under ref -5.
3. The Consumer has paid the following amounts in favour of AEE, BESCOM, Anekal sub division

SI No	A/C Head	Amount in Rs	RT No	Date
1	supervision charges @ 5% on estimate cost of Rs. 45,126 /- (Excl'd DEI & ESCOM employees cost)	2,006-00	20240008849	20-12-2024
Total Amount Paid		2,006-00		

4. The reduction of contract demand is final and it will not be revoked at later date.
5. The reduction of contract demand shall be with effect from the meter reading date following the expiry of, "two months" period from the date of registration of the application for reduction of contract demand / sanctioned load along with fresh agreement for reduced contract demand/ sanctioned load duly making payment of registration cum processing fee as prescribed under clause 30.01 of KERC.
6. The energy entitlement shall be re-fixed on Pro-rata basis (applicable during Power cut period).
7. Signature of the consumer shall be tallied with the signature in the original docket before effecting the reduction of load.
8. The Consumer has to pay arrears and audit short claims, if any, detected at a later date.
9. The Consumer has to give an undertaking that he will abide by the above Conditions / decision of the appellate authority in respect of pending appeal/ court cases, if any.

10. The installation shall be rated by M.T Staff before & after implementation of reduction of load.
11. The Consumer shall abide by the rules/regulations, if any, left out and regulations issued at later dates.
12. The capacity of any individual machinery / equipment installed / connected shall not be more than the approved reduced CD.
13. If SRTPV Load is sanctioned to this Consumer, then the existing PPA has to be withdrawn with immediate effect and Supplementary PPA to be executed as per prevailing KERC / BESCOM Norms.
14. The security deposit required shall be recalculated for the reduced contract demand on Prorate basis on average monthly bill of the preceding calendar year as per clause 34.04 and **balance of deposit shall be refunded to the consumer duly observing the KERC/ BESCOM norms.**

All Other formalities shall be observed as per the prevailing KERC regulations.

  
(Dhannanjaya C),  
Executive Engineer(Ele),  
C, O&M Chandapura Division,  
BESCOM.

**Copy to:**

1. The Executive Engineer Ele, MT, BRAZ, BESCOM, Bangalore for information
2. The Accounts Officer, BESCOM, Chandapura Division for information
3. The Assistant Executive Engineer Ele, BESCOM, C, O&M **Anekal** Sub Division, for information **along with file.**
4. Mr. Baabulal Hooda S/O Kallaram Hooda at Sy No-10/1 & 10/2, Thimmasandra Village, Anekal Taluk.
5. AE(T) / M.F / OC.



Reduction of Load  
Existing - 200KVA  
Reduction - 100 KVA

CD = 100 KVA  
MC = 750

(ಕಂಪನಿಯ ಉಪಯೋಗಕ್ಕಾಗಿ)

HT-2(a)

ಆರ್.ಆರ್.ಸಂ.ಬರೆಯಲಾಗಿದೆಯೇ?

yes

ಮಾಪಕದಲ್ಲಿ ಹಾಕಿಯನ್ನು ಇಡಲಾಗಿದೆಯೇ?

yes

ಪುಸ್ತಕ ಸಂಖ್ಯೆ

ಇನ್‌ಸ್ಟಲೇಷನ್ ಸಂಖ್ಯೆ

ಸಂಪರ್ಕ ದಿನಾಂಕ

ಸಂಪರ್ಕ

ಹೊಸ

ಟ್ರಾಪಿಂಗ್

ದೂರವಾಗಿ ಕಾಸಿಂಗ್

ಯಾವ ಸಂಖ್ಯೆಯ ಕಂಬದಿಂದ

ಈ ಆರ್. ಆರ್. ಸಂಖ್ಯೆ ನಂತರದ್ದು

ಮಾಪಕ ಓದುವ ದಿನಾಂಕ

ಸೇವಾ ಮಾರ್ಗ

ಕಂಟಕ್ಟರ್ ಸಿಯು/ಎ

ಕೇಬಲ್ ಡಬ್ಬಿಂಗ್/ವಿಐಆರ್/ಸಿಟಿಎನ್

ಕೊಳವೆ

ಅರ್ಥಿಂಗ್

ವಿರಿಯಲ್ ಪೂಸ್

ಕಟ್‌ಔಟ್

ಸಂಪರ್ಕ ಸೇವೆ ದೂರ

ಪರೀಕ್ಷೆ

ಫೇಸುಗಳ ಮಧ್ಯೆ

ಫೇಸ್‌ನಿಂದ ನೆಲಕ್ಕೆ

ನೂಟ್ರಲಿನಿಂದ ನೆಲಕ್ಕೆ

ದೃಢೀಕರಿಸುವುದೇನೆಂದರೆ, ನಾನು ಸ್ಥಾವರವನ್ನು ಪರೀಕ್ಷಿಸಿದ್ದೇನೆ.

LET

1 Amp

0000370-685

S/NO: 23003294

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

yes

KALABYRAVESHWARA ELECTRICALS

Govt. Licence Class-1 Contractor

(ಗುತ್ತಿಗೆದಾರ/ತಾಂತ್ರಿಕ ಸಲಹೆಗಾರರು ಸಹಿ)

No. 743/447/99 Sub. Bangalore - 560 105.

Ph. 8892209959

ಕಛೇರಿ ಉಪಯೋಗಕ್ಕೆ ಮಾತ್ರ

ಖಾತೆ ಪುಸ್ತಕ ಪುಟ ಸಂಖ್ಯೆ

ಖಾತೆ ಸಂಖ್ಯೆ

ಇನ್‌ಸ್ಟಲೇಷನ್

ಸಂಪರ್ಕ ಸಂಖ್ಯೆ

ಪರೀಕ್ಷಿಸಿದೆ

ಸಹಾಯಕ ಕಾರ್ಯ ನಿ. ಇಂಜಿನಿಯರು

ಹಿರಿಯ ಸಹಾಯಕ/ಸಹಾಯಕ ಲೆಕ್ಕಾಧಿಕಾರಿ





# Bangalore Electricity Supply Company Ltd.

Page 1 of 3  
Format F-09-14

HT Rating Report **12254**

No. EE MT / AEE(O) / BRAZ / AEE HTR / **AKLHT 851**

Office of the  
Executive Engineer (Ele.),  
MT Division, BRAZ, BESCOM  
3rd Floor, Crescent Tower  
Bangalore - 560 001.

To,  
The Asst. Executive Engineer (Ele.),  
**Anekal** O&M Sub-Division  
BESCOM, **Anekal**

Reduction of load  
Existing - 200 kVA  
Reduction 100 kVA  
Remaining - 100 kVA

Date **29/01/2025**

Sir,

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on **29/01/2025**  
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

## 1. DETAILS OF H.T. INSTALLATION :

R.R. No. **AKLHT 851** CD **200-100=100KVA**

Meter Constant **750** Activity

Name & Address of the Consumer **Sri. Kabilal Hooda s/o Kallanur Hooda**  
**at 4/10/10/1 & 10/2 Thimmakudra village in Indawade**  
**area of Anekal Sub division BESCOM.**

## 2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

**As per your letter reference No: EE(O)/AEE(O)/AET(O)**  
**2024-25/4802 dt: 15/01/2025 Reduction of load is**

## 3. ADVICE ON REVENUE MATTER :

**Sanctioned from 200 kVA to 100 kVA Hence**  
**the existing 7.5/1A is replaced by 7.5/1A Ratio**  
**Test T-12 & Blowing test conducted all the**  
**errors existing in permissible limit charged found ok**

## 4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint **After calibrated error is**  
**with in permissible limit.**

Yours faithfully,

**[Signature]**  
Asst. Executive Engineer (Ele.),

HT Rating Sub Division, **Chanda Pura**  
BRAZ, BESCOM, Bangalore.

## Copy for kind information to :

1. The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

2. Executive Engineer Ele, O&M **Chanda Pura** Division, BESCOM, **Chanda Pura**

## In case of discrepancies :

3. Chief Engineer Ele., BRAZ, B'lore.

4. Superintendent of Police, Vigilance

5. Accounts Officer, Internal Audit.



## ANNEXURE

Page 2 of 3  
Format F-09-14

## 1. DETAILS OF SEALS :

12254

R.R. No. ALLHT 85

Sl. No.	Seals Provided to	Sl. No. of Seals Found		Sl. No. of Seals Left	
		Lead	Plastic	Lead	Plastic
1.	M.C. of Meter	BMI 28823	225625		
2.	TC of Meter	BRD2A98195			
3.	M.D. Reset Knob	BRD2A98196		BRD2B09475	
4.	Optical Port				
5.	T.T.B.	BRD2A98197		BRD2B09476	
6.	Meter Chamber Main Door	BRD2A98198		BRD2B09477	
7.	Meter Reading Window				
8.	C.T. / P.T. Chamber	BRD2A98199		BRD2B09478	
9.	Cable Entry Chamber	BRD2A98200		BRD2B09479	
10.					
11.					

## 2. DETAILS OF THE EQUIPMENTS :

- a) Cubicle Type : Cable Entry / 6 bushing / 3 bushing / LBS. Make OLIEVER Sl. No. HC/73
- b) Cubicle Conditions & Location Good & out door yard
- c) Supply side G.O.S. : In Service / Direct / Removed
- d) Lightning Arrestor - Provided / Not Provided

## 3. DETAILS OF CTs / PTs :

	Existing	After Replacement	Existing	After Replacement
1. Make	PARAS	PARAS	PARAS	
2. Type	INDOOR	INDOOR	INDOOR	
3. Class	0.2	0.2	0.2	
4. Insulation Level	15/38/95	15/38/95	15/38/95	
5. Burden	2.5 VA	2.5 VA	25 VA	
6. Ratio Available	10/1A	7.5/1A	1100/110V	
7. Ratio Connected	10/1A	7.5/1A	5/5	
8. Sl. No. 1.	M/CT 018483	M/CT 020821	M/PT 16390	
2.	M/CT 018481	M/CT 020822	M/PT 16391	
3.	M/CT 018482	M/CT 020823	M/PT 16389	

## 4. DETAILS OF METERS :

## ETV Meter

	Existing	After Replacement
a. Make	LT	
b. Type	WR300 BRUKARS (23003294)	
c. Class	0.2	
d. Voltage	3x 63.5V	
e. Ampere	1 AMP	
f. Pulse / Unit	50.000	
g. Dial Constant	1	
h. Sl. No.	23003294	