



GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)



Scan the above QR Code
for verifying the authenticity of the Approval

Date : 07/02/2026

Ack No : EI000110926510

GSC No : EN0010000395844

O/o Electrical Inspector,
Bangalore South,
No 53/2, 1st floor, Behind Nijaguna Kshetra, Bull
temple road, Bangalore-566004
Phone No :08026577477

To: RANDAR PACKAGING PVT LTD ✓

no 492AB kyalasanahalli near sriram pura, jigani hobli
kyaasanahalli, BENGALURU(District), ANEKAL(Taluk)
Karnataka, India-560105

ir,

Sub : Approval of electrical installation pertaining to of 1x400KVA 11KV/433V Oil type HT Transformer centre installed
RANDAR PACKAGING PVT LTD no 492AB, municipality, hennagara GP, jigani bommasandra link road,
kyalasanahalli, Bangalore South 1(District), BANGALORE SOUTH 1(Taluk) - 560105

Drawing Ref No : EI000110915392

Ref :

01. BESCO Intimation Letter: EEE/CDP/AEE(O)/AEI /8906-07 Dated:21.11.2025

With reference to the above, approval is hereby granted for energizing the electrical installation at [**RANDAR PACKAGING PVT LTD with no 492AB, municipality, hennagara GP, jigani bommasandra link road, kyalasanahalli, Bangalore South 1, BANGALORE SOUTH 1 - 560105**] under Regulation No. [45] of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 as per details enclosed.

This approval is strictly subject to your full compliance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 (as amended to date) in every respect.

Note :

Approved

Conditions :

1. As per Regulation No: 48(5) and 48(6) required records shall be maintained.
2. As per Regulation No: 48(7) the installation shall be maintained and operated in a condition free from danger.
3. As per Regulation No: 3 designated person(s) shall operate and carryout the work on electrical lines and apparatus.

Inspection fee of Rs. 17,100/- (IN WORDS) **Seventeen Thousand One Hundred only** paid vide K2 Challan Ref. No: **EL0126004300018175** dated **31/01/2026**

Details of Equipments :

I. Metering Cubical:

CTs Make: Kalpa, Ratio:12.5/1A CI.0.2S, 2.5VA

SI.Nos:5658/25,5657/25,5661/25

PTs Make: Kalpa, 25VA, 11kV/R3/110/R3V, CI 0.2

SI.Nos:7926/25,79087/25,79206/25

Meter Make: L&T, SI.No.25010897

Panel Make: Dev switchgear, SI No:DSG/1390/25-26

Electrical Installation Approval

1 of 3

Ack No : EI000110926510

Date : 07/02/2026





GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)



Scan the above QR Code
for verifying the authenticity of the Approval

2.HT Cable :

1Rx3Cx95 Sqmm 11KV XLPE UG cable.

3.HT Switchgear:

12KV, 800Amps, 26.3KA/3SEC VCB

Make: ABB, SI No: 1VYN020925001140

4. Transformer :

Make:Chuan Shun Electric Company India Pvt Ltd, 1x400KVA,

11KV/433V, 20.99/533.3Amps, Type:ONAN,

Sl. No:HDB004-01

5.LT Switchgear :

MCCB:630 Amps Make:Schneider at LT Kiosk.

MCCB:630 Amps Make:Schneider at LT Panel.

6.LT Cable :


2Rx3.5Cx240Sq mm UG Cable.

7. Sanctioned Load: 250KVA

Subject to following Conditions:

01. Any type of litigations by private/public or Any other Authorities, responsibility lies with the applicant only.
02. Comply the norms laid by any other licensing/Approving authorities.
03. As per Ltr No: CEIG/ACEI/EI-1,2/14754-892/24-25, Dt:28.01.2025, Electricity service provider shall service the building after obtaining the completion/occupation certificate.
04. The responsibility of the authenticity of the documents submitted by the applicant lies with applicant only.
05. This Approval may be withdrawn at any time in case of applicant fails to comply the norms of CEA(MSES)2023 and in case of any objections from any other Authority/Complaints.

Yours faithfully,



Digitally Signed by : YANKANNA

Electrical Inspector

Bangalore South

Signed Date

: 07/02/2026

Note: This is a Digitally Signed Certificate and Does not require manual signature.

Please, Verify authenticity of this certificate by visiting www.ksei.gov.in and entering certificate number in Third party verification.

Copy To : ENKAY ASSOCIATES

K.I.A.D.B COMPLEX , BOMMASANDRA , BOMMASANDRA INDUSTRIAL AREA , BOMMASANDRA , BANGALORE , Bangalore
South 1 , 560058

License No: ICL14563BNU Valid Upto: 30/04/2026

Electrical Installation Approval

2 of 3

Ack No : EI000110926510

Date : 07/02/2026

