



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿರ್ಮಿತ.,

( ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ )

## Bangalore Electricity Supply Company Limited

No.EE(E)\AEE(O)\AE(T)-2/24-25/ 10336-38

Office of the Executive Eng, (Ele).,  
C O & M Division, BESCOM, Tiptur

Date: 10.12.24

### Official Memorandum for Work Execution

**Sub:** For Arranging power supply to an extent of load enhancement of existing RRno.: TP-2453 requesting load 10HP an IP Set installation in favor of K S Panchaksharaiah S/o Shadaksharaiah, Karikare, in O&M-1 Section, Tiptur Sub Division. Under Self Execution Basis.

**Ref:** 1) BESCOM Corporate Office Order No: BC-47/GM(P)/(O)/2762/CYS- 21/07.06.2010.  
2) T.O Power sanctioned letter No: EE(E)/AEE(O)/AET/2024-25/10782-84/04.12.2024  
3) Payment Made Date:05.12.2024

\*\*\*\*\*

"This estimate is sanctioned vide letter cited under ref-(2) for Arranging power supply an extent of load enhancement of existing RRno.: TP-2453 requesting load 10HP an IP Set installation in favor of K S Panchaksharaiah S/o Shadaksharaiah, Karikare, in O&M-1 Section, Tiptur Sub Division. Under Self Execution Basis may the applicant has paid the following deposits at the office of the AEE(E), Tiptur Sub Division.

Account Head	Amount	Receipt No.	Amount Paid Date
ISD	17000/-	1224	05.12.2024
Supervisory Charges	150/-	1223	
Meter Security Charges	2808/-	1221	
TP Box	4300/-	1222	
5% Supervisory Charges on EC	11573/-	1220	

The materials purchased by the consumer shall be inspected by Q.S & S wing, BESCOM, as per circular No: BESCOM/GM(QS&S)/DGM-3/BC-11/F-1425/2013-14/CYS-125/19.02.2014. and Testing of all Self Execution Transformers irrespective of capacities at Transformer Testing Centers of BESCOM jurisdiction as per circular DGM(OP)DGM(OP-1)AGM(OP-3)/AE-1/BC-05/2020-21/CYS-164/29.03.2021. Before execution this certificate shall be given to the concerned A.E.E(E) of the Sub- Division.

Take Necessary safety precautions while executing the work by Class-1 electrical contractor. If any Electrical / Mechanical accidents occurred without any safety precautions by the Electrical Contractor the BESCOM is not responsible. You should submit the relevant documents and details of Class-1 Electrical contractor to the concerned Sub division Officer & Section Officer before commencement of the work.

(P.T.O)



**This work should be completed within a period of 90 Days.** The installation serviced duly observing BESCOM formalities & prevailing KERC regulation applicant has to give guarantee for the materials and work for a period of one year from the date of completion of the work. The materials shown in the estimate are vide order No **F-45649 dated 06.12.2024.**

Asst. Engineer(Ele).  
BESCOM,Tiptur.

Asst. Executive Engineer (Ele)  
BESCOM,Tiptur.

Accounts Officer (F&A)  
BESCOM,Tiptur.

Executive Engineer,(Ele.,)  
C,O&M,Division,BESCOM,Tiptur.

Copy:

- 1.Asst. Executive Engineer(Ele) BESCOM, Sub-Division Office, Tiptur
- 2.Asst. Executive Engineer(Ele) BESCOM, Division Office, Tiptur.
- 3.Asst. Engineer(Ele) BESCOM, Division Office, Tiptur.
4. Senior Assistant C Register O&M Division, BESCOM Tiptur.
5. O/C.