

Office of the
Assistant Executive Engineer Ele.,
C,O&M, VEERASANDRA Sub Division
BESCOM , VEERASANDRA

To
ABHISHEK KUMAR
SYNO.97/1,97/3,98/1,98/2,

Sir/Madam

Sub : Arranging power supply to an extent of **48.00 KW** in favor of ABHISHEK KUMAR SY NO.97/1,97/3,98/1,98/2, in VEERASANDRA OMU, VEERASANDRA

Ref: 1) Your application registration **1325103250390** dated **28-MAR-2025**

2) AEE/ATBL /AE(T) a/ **28-MAR-2025**

With reference to your application dated **28-MAR-2025** . Requesting for arranging power supply to an extent of **48.00 KW** power installations in favor of ABHISHEK KUMAR SY NO.97/1,97/3,98/1,98/2, in VEERASANDRA OMU,VEERASANDRA Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M VEERASANDRA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1325103250390	13251032503900001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	48.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1325103250390	13251032503900001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	48.00 KW	61.9047-(WITH TAX) 5% Supervisory Charge(61.904)	24126
1325103250390	13251032503900001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	48.00 KW	48.1017-48.1017 - ISD	83710
Total Amount					108836

- b. The power supply will be arranged at 400V .
- c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE RSD-01 BESCOM VEERASANDRA .
- i. Intimation is valid up to 90 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., VEERASANDRA Sub division, BESCOM for information and further needful.

Your's Faithfully,

Assistant Executive Engineer Ele.,
VEERASANDRA , BESCOM





ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಸಂಪೂರ್ಣಕಾರಣಿಗಳಿಗಾಗಿ ಸಾರ್ವಜನಿಕ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೆ: ಅಇಂ(ವಿ)/ರಾಪ್/ಅಇಂ(ಕೆ)/ಸಬಾ/2024-25/

ಲಗತ್ತು:

102 - 05

Email: sermgc.work@gmail.com

Phone No. 080-28488780 / 723

BESCOM GST NO: 29AACCB1412G125

ರವರ ಕಛೇರಿ,

ಅಧೀಶ್ವರ ಜಾಲಿನಿಯರ್(ಡಿ),

ವಾಣಿಜ್ಯ, ಕಾರ್ಯಾಲಯ ಕಾಲನ ರಾಮನಗರ ಪುರ,

ಬೆಂಗಳೂರು, ಬೆಂಗಳೂರು, ಕೆಆರ್.ನಿ.

ಬೆಂಗಳೂರು-560004.

To

Sri. Abhishek Kumar

C/o Paras Nath Singh,

Sy. No. 97/1, 97/3, 98/1, 98/2,

Muttannalur Village,

Anekal Taluk.

04 APR 2025

MS POWER SANCTION

ಮಾನ್ಯರ,

ವಿಷಯ: ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ 48 ಕೆ.ವ್ಯಾ (ವಾಣಿಜ್ಯ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: 1. ಕಾನಿಡಂ(ವಿ)/ಬೆಂಪಾ/ಸಕಾನಿಇಂ(ಕೆ)/ಸಇಂ(ಪ್ರಾಂ)/2024-25/164-65 ದಿ: 03.04.2025 ಬೆಂಪಾಪುರ ವಿಭಾಗ.

Application IDs :1325103250390

ನಿಮ್ಮ ಮನವಿಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ 48 ಕೆ.ವ್ಯಾ (ವಾಣಿಜ್ಯ) ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5 / 3.1.3A ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಪರಾಕುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿವಸಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ.

1. ತಾವು ಕಟ್ಟಿರುವ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 206.06 ಚ.ಮೀ, Ground Floor ಇರುತ್ತದೆ. ನೀವು ಕೋರಿರುವ ಪ್ರಮಾಣ 48 ಕೆ.ವ್ಯಾ (ವಾಣಿಜ್ಯ)
2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ ಎಫ್-03 Feeder ಫೀಡರ್, Chokkasandra ಉಪಸ್ಥಾಪನೆಯಿಂದ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
3. ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.-3 ಜಕಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲಿರುವುದು.
4. ಈ ಕೆಳಕಂಡ ಠೇವಣಿ/ದುಲ್ಲಗಳನ್ನು ಸ.ಕಾ.ನಿ.ಇಂ(ವಿ), ವೀರಸಂದ್ರ ಉಪ-ವಿಭಾಗ ರವರ ಹೆಸರಿನಲ್ಲಿ DD ಯನ್ನು ಶೇ.90 ದಿವಸಗಳೊಳಗೆ ವೀರಸಂದ್ರ ಉಪ-ವಿಭಾಗ ಕಛೇರಿಯಲ್ಲಿ ಪಾವತಿಸುವುದು.
5. ತಮಗೆ ಸರಬರಾಜು ನೀಡಲುತಗಲುವ ಸ್ವಯಂಕಾಮಗಾರಿ ಅಂದಾಜು ಪಟ್ಟಿಯ ವೆಚ್ಚ ರೂ.4,87,513/- ಆಗಿರುತ್ತದೆ.

Page 1 of 5

Appl ID:- 1325103250390

Name:- Sri. Abhishek Kumar C/o Paras Nath Singh



SL No	Particulars	Ammount In RS	CGST in RS.	SGST in RS.	Total Ammount RS
1	2MMD				
	a) 48 KW*01 No.s Tariff LT3 (86,208*01=86,208/-)	86,208/-	0.0/-	0.0/-	86,208/-
2	5% Supervision Charges on (Total Estimate Cost Rs. 4,87,513/-)	24,126/-	2,171/-	2,171/-	28,468/-
3	Transformer Testing fees	1,000/-	0.0/-	0.0/-	1,000/-
Total Amount (Rupees One Lakh Fifteen Thousand Six hundred and Seventy Six only)					1,15,676/-

6. As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- 1 /BC-11 / 2024 -25 /Cys-141, dt:05.12.2024.Dry type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors only.
7. If Dry type LBS/500KVA/CSS/transformer has been installed under self execution, an under taking shall be furnished that the same shall be maintained for life time by the applicant.
8. As per BESCOMorder No: BESCOM/CGM(OP)/DGM (OP--1)/FY 2021-2022/CYS-19 Dt:17.05.2021. The sub divisional officers ensure the transformer quality and rating at the authorized test bench/ Divisional stores duly collecting transformer test certificate issued by the concerned MT division before servicing of installation.
9. As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- 1 /BC-11 / 2024 -25 /Cys-15, dt:19.04.2024. All dry type transformers procured under Self-execution shall be got tested at the nearest test bench centerand duly collecting transformer test certificate issued by the concerned MT division.
- 10.As per BESCOM Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates:-15.02.2025& CYS-102 dated 25-03-2025, The power supply shall be arranged to the above said installations through "Smart Energy Meterinline with its capacity and quantum of load requirement in BESCOM jurisdiction".

Appl ID:- 1325103250390

Name:- Sri. Abhishek Kumar C/o Paras Nath Singh