



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/

To,  
The Asst. Executive Engineer (Ele),  
O&M Sub-Division,  
BESCOM

Office of the  
Executive Engineer (Ele),  
MT Division, BRAZ, BESCOM,  
3<sup>rd</sup> Floor, Crescent towers,  
Bangalore-560001.

Sir,

Date: 8/1/26

### Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details has been rated for periodical rating/complaint on 8/1/26. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

#### 1. DETAILS OF H.T. INSTALLATION:

R.R. NO. RPH-12 CD 380 KVA CTR. 20/1 Previously rated on 5/6/25  
Activity Industry Tariff HT (1A) A Meter Constant 2000  
Name & Address of the Consumer Bengaluru Agro Meter NO 584  
Hawbera, Bengaluru

#### 2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

The HT ETV meter is calibrated & it is found that the error is within the limiting accuracy class and it is found that reduction of load on 19/7/24: 499 KVA to 380 KVA. Hence meter constant not affected.

#### 3. ADVICE ON REVENUE MATTER:

in Bill C.B. 2500 to 2000. Hence meter constant not affected. Hence the bill as per the BESCOM norm.

#### 4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis if rated against complaint: No. SLNO - 702996

### ANNEXURE

#### 1. DETAILS OF SEALS:

R.R. No. RPH-12

| SL. No. | Seals Provided to       | Sl. No. of Seals Found Plastic |             | Sl. No. of Seals Left Plastic |             |
|---------|-------------------------|--------------------------------|-------------|-------------------------------|-------------|
|         |                         | Main Meter                     | Check Meter | Main Meter                    | Check Meter |
| 1       | M.C. of Meter           | BNG 72095/2B890604             |             | } returned                    |             |
| 2       | TC Of Meter             | BRA2L22395                     |             |                               |             |
| 3       | M.D. Reset Knob         | BRA2D01286                     |             |                               |             |
| 4       | Optical Port            |                                |             |                               |             |
| 5       | T.T.B                   | BRA2B45437                     | BRA2B47581  |                               |             |
| 6       | Meter Chamber Main Door | 45438                          | 47582       |                               |             |
| 7       | Meter Reading Window    |                                |             |                               |             |
| 8       | C.T./P.T. Chamber       | BRA2D01289                     |             | 47583                         |             |
| 9       | Cable Entry Chamber     | BRA2A31013                     |             | } returned                    |             |
| 10      | Hologram                |                                |             |                               |             |

#### 2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make: Royalhwy Sl. No. 6165
- b) Cubicle Conditions & Location: Salimnagar

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) : 11KV/110V X 20/1 X 1 = 2000

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11 \times 20 \times 1}{1 \times 1} = 2000$$

#### 4. DETAILS OF Ct's/ Pt's: