



BANGALORE ELECTRICITY SUPPLY COMPANY LTD

(Wholly owned Government of Karnataka Undertaking)

Mb: 9448279006

L/L: 0816-2278599

E-mail: setumkur@bescom.co.in

setmkrcircle.work@gmail.com

Office of the

Superintending Engineer(EI),
C,O&M-Circle, Tumakuru-Dist.,
Horapete, Tumkur-01.

No:SE(EI)/EE(O)/AEE(O)/T2/2025-26/

Dated:

4617-19

- 2 SEP 2025

To,

The Assistant Executive Engineer,
Minor Irrigation and Groud Water Development,
Tiptur Sub Division,
Location: Chikkaturvekere,
Turuvekere Taluk.

Account ID:2233107250008.

Location of Unit:-Chikkaturvekere, Turuvekere Taluk, Tumkur District in O&M-2
Section of Turuvekere Sub division, Tiptur Division.

Nature of Activity:-Ethaneeravari (Water Filling to 29 Lakes near Chikkaturvekere Lake).

Sir,

Sub:-Intimation for arranging HT power supply to an extent to 1000 KVA under HT-3(a)(i) tariff in favour of The Assistant Executive Engineer, Minor Irrigation and Groud Water Development Sub division, Tiptur Location at Chikka Turuvekere, Turuvekere Taluk Tumkur District in O&M-2 Section of Turuvekere Sub division Tiptur Division under Self Execution basis.

Ref:-1) Executive Engineer(Ele.), BESCOM, Tiptur Dvn Ltr No:2025-26/6411/
Date:21.08.2025.

2) BESCOM/GM(M&C)/CYS-138/2022-23/Dtd.05.01.2023.

3) BESCOM/CGM(Projects)/DGM-3/BC-14/2022-23/CYS-117/Dt.13.01.2023.

4) BESCOM/BC-24&45/GM(M&C)/DGM(M&C)/AGM-2/2025-26/CYS-32/26.08.2025.

5) KERC Tariff-2025 Order Dtd.01.04.2025.

With reference to the above as per your request for Arranging HT Power Supply to an extent to 1000 KVA under HT-3(a)(i) Tariff to your unit located at the above adress is Sanctioned under Self Execution basis subjected to observing the following terms & Conditions and other KERC/BESCOM formalities.

1. You shall run 11KV line using Covered Conductor to a distance of 6.42 KMs tapping from existing F-1 Mallaghatta feeder upto DP point & lay 3*95 Sqmm XLPE UG Cable (Round Armoured) to a distance of 2*20 Mtrs (Double Run) upto HT Metring Cubicle under Self