



**GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)**

Lr. No

Date : 20/02/2024

Ack No : EI000110640464

Gsc No :

O/o. Deputy Chief Electrical Inspector,
Bangalore Additional West,
No.221, A.H.A Jennith Building,
12th Block, 2nd stage,
Nagarbhavi Main Road, Bangalore - 560 072.
Phone No :080-2321-942

To

SUSHIL KUMAR S KHOKATE
C/O SHIVABAL RAMACHANDRA
plot no 59 & A&B.-plot no 59&A, plot no 59&A&B. INDUSTRIAL ARE
MANCHANAYAKANAHALLI, RAMANAGARA(District), RAMANAGARA(Taluk)
Karnataka, India - 562109

Sir,

Sub : Approval of Drawing pertaining to the Electrical Installation- 1x630kVA, 11kV/433V HT Transformer Substation at **SUSHIL KUMAR S KHOKATE** plot no 59 & A&B., plot no 59&A&B., MANCHANAYAKANAHALLI, plot no 59&A&B. INDUSTRIAL ARE, MANCHANAYAKANAHALLI, RAMANAGARA(District), RAMANAGARA(Taluk) - 562109

Ref : Requisition vide online application ack No. EI000110640464 dated 17/02/2024

Note :

Approved with the following conditions:-

1) Any addition/ alterations shall be got approved separately.

Please find here in the drawings duly approved after effecting necessary corrections and with observations noted in **RED INK**. You may take up the work through a Licenced Electrical Contractor as per the approved drawings and after completing the work, submit the connected documents with completion report to the **undersigned** along with the following particulars to arrange for inspection.

This Approval is valid only for a period of **TWENTY FOUR MONTHS** only from the date of approval and extension may be obtained separately for a further period of Twelve Months only as per sub rule (5) Rule 7 of The Karnataka Electrical Inspectorate (Power, Functions and levy of fees) Rules, 2018.

PARTICULARS OF HT/DG:

1. Manufacturers Test Reports of Generator / Transformer / HT / LT breakers etc.,
2. Completion report of Licensed Electrical Contractor for having completed the works as per the approved drawings along with the following details.
 - a) Description of the motor/equipments, indicating serial numbers.
 - b) Rating in HP/KW/KVA
 - c) Feeder details
 - d) Voltage Rating, insulation test results of the equipments.
 - e) Earth Test Results.
 - f) The completion report should be signed by the Licenced Electrical Contractor and the Electrical supervisor along with their valid licence / Permit number and validity date.
3. Oil Test Results of transformer/oil circuit breaker.
4. Insulation test results of transformer/ generator OCB's cable and other connected equipments.
5. Calibration certificates in original of protective devices, CTs, PTs, Energy meters etc., as calibrated by the relay testing and meter testing division of KPTCL and other approved agencies.
6. Earth test results of all the earth electrodes disconnecting all the earth leads from them.



**GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)**

7. A List of authorized persons qualified to operate at the sub-station/ at the works (list shall be signed by both the employees and employer with permit number and validity date)

Challan/Receipt for having paid **Rs. 8,800 /- (IN WORDS) Eight Thousand Eight Hundred only** towards inspection charges under the following Budget Head Non-Plan 0043-00-102-0-01 other taxes and duties on Electricity through E-payment only.

Drawing Scrutiny Fees of Rs. **1,000/- (IN WORDS) One Thousand only** paid vide K2 Challan Ref No **EL0224004300011806** dated **17/02/2024** is hereby acknowledged.

Note: This is a Digitally Signed Certificate and Does not require manual signature.

Please, Verify authenticity of this certificate by visiting www.ksei.gov.in and entering certificate number in Third party verification.



Digitally Signed by : CHINNAPPAIAH MALLEPURA SRINIVASA
Deputy Chief Electrical Inspector
Bangalore Additional West

Signed Date : 20/02/2024

