



No.AEEEE/HTR/

MILKITT- 323

To,

The Asst. Executive Engineer (Ele),  
Malur O&M Sub -Division.  
 BESCOM.

Temp reduction of 100d  
 Ex- 600  
 - 575  
25kva

Office of the  
 Asst. Executive Engineer (Ele),  
 CDP H.T. Rating Sub -Division.  
 BRAZ BESCOM.

Sir,

Date 19.7.24**Subject: Rating Report of HT/EHT Installation.**

The H.T. Installation having the following details has been rated for periodical rating/complaint on..... You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

**1. DETAILS OF H.T. INSTALLATION:**

R.R.NO. MILKITT-323 CD 600-575 KVA CTR 30/1 Previously rated on 14.6.2023  
 Activity..... Tariff 25kva A Meter Constant 3000  
 Name & Address of the Consumer.....

**2. OBSERVATION & ADVICE ON TECHNICAL MATTER:**

Meter has been calibrated and rated accuracy reading correctly. Errors are within the permissible limit.

**3. ADVICE ON REVENUE MATTER:**

DEC/DEC(1)/MILKITT-28/372/2024-25 dt 28.6.24  
 as per the above return Temp reduction load  
 corridor and Exits are remain same.

**4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.**

Summary of analysis if rated against complaint

Temp validity up to  
Six months only

**ANNEXURE****1. DETAILS OF SEALS:**

R.R. No.....

| SL.N<br>O. | Seals Provided to       | Sl. No. of Seals Found Plastic |             | Sl. No. of Seals Left Plastic |             |
|------------|-------------------------|--------------------------------|-------------|-------------------------------|-------------|
|            |                         | Main Meter                     | Check Meter | Main Meter                    | Check Meter |
| 1          | M.C. of Meter           | BMC 53069 / D 744352           |             |                               |             |
| 2          | TC Of Meter             | BRAZA 96990                    |             |                               |             |
| 3          | M.D. Reset Knob         | BR 88269                       |             |                               |             |
| 4          | Optical Port            | —                              |             |                               |             |
| 5          | T.T.B                   | BRAZA 96991                    |             | BRAZD 30903                   |             |
| 6          | Meter Chamber Main Door | BRAZA 96992                    |             | BRAZD 30904                   |             |
| 7          | Meter Reading Window    | —                              |             |                               |             |
| 8          | C.T./P.T. Chamber       | BRAZ 54820                     |             |                               |             |
| 9          | Cable Entry Chamber     | —                              |             |                               |             |
| 10         | Hologram                | —                              |             |                               |             |

**2. DETAILS OF THE EQUIPMENTS:**

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make Good Sl. No.....  
 b) Cubicle Conditions & Location.....

**3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :**

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = 3000$$



|                     |           |        |        |
|---------------------|-----------|--------|--------|
| 2. Type             | .....     | .....  | .....  |
| 3. Class            | .....     | .....  | .....  |
| 4. Insulation level | .....     | .....  | .....  |
| 5. Burden           | .....     | .....  | .....  |
| 6. Ratio Connected  | .....     | .....  | .....  |
| 7. Sl.No.           | 1. R..... | R..... | R..... |
|                     | 2. Y..... | Y..... | Y..... |
|                     | 3. B..... | B..... | B..... |

*Existing*

**5. DETAILS OF METERS:**

**ETV Meter**

|                  |       |
|------------------|-------|
| a. Make          | ..... |
| b. Type          | ..... |
| c. Class         | ..... |
| d. Voltage       | ..... |
| e. Ampere        | ..... |
| f. Pulse / Unit  | ..... |
| g. Dial Constant | ..... |
| h. Sl. No.       | ..... |

*Existing*  
*NR300RB 11KV*  
*0.25*  
*3x63.5V*  
*1A*  
*50000*  
*1*  
*17124957*

**After Replacement**

**6. A. CALIBRATION DETAILS:**

|                       |       |
|-----------------------|-------|
| a. Voltage V1, V2, V3 | ..... |
| b. Current I1, I2, I3 | ..... |
| c. P.F. / KW          | ..... |
| d. Sequence           | ..... |

**CALIBRATOR**

**METER**

*63.7 63.9 63.6*  
*0.044 0.055 0.035*  
*0.333 / 0.0035*

**B. % of Error**

|                               |       |
|-------------------------------|-------|
| a. Reading of Test Meter      | ..... |
| b. Reading of Reference Meter | ..... |
| c. Percent Error              | ..... |

**KVAH/**

**KVARH**

**7. METER READINGS :**

**A. Cumulative Parameters**

|                              |       |
|------------------------------|-------|
| a. Time Date, Month, Year    | ..... |
| b. Demand with elapsed time  | ..... |
| c. Self diagnostic condition | ..... |
| d. Present KVA. PF           | ..... |
| e. Cumulative KWH            | ..... |

*Existing*  
*14.42 19.7.24*  
*9780.79*

**After Replacement**

**B. BILLING PARAMETERS :**

a. Billing KWH

TOD 1.....  
 2.....  
 3.....  
 4.....

TOD 1.....  
 2.....  
 3.....  
 4.....

*9780.22*

TOD 1.....  
 2.....  
 3.....  
 4.....

TOD 1.....  
 2.....  
 3.....  
 4.....

*0.0083*

b. Billing KVA

TOD 1.....  
 2.....  
 3.....  
 4.....

TOD 1.....  
 2.....  
 3.....  
 4.....

*0.349*

c. Billing PF (Universal TOD)

TOD 1.....  
 2.....  
 3.....  
 4.....

TOD 1.....  
 2.....  
 3.....  
 4.....

d. MD Reset Count

e. MD Reset Manual/ Automatic On

*85*  
*Auto*

*WIRE*

*Penny*