



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/ **DHTP/139**
To, The Asst. Executive Engineer (Ele), **Add'n of Load**
D.R. Pura(U) O&M Sub-Division. **CD: 1750+1000**
BESCOM, **Melomangala** **2750 KVA**

Office of the
Executive Engineer (Ele),
MT Division, BRAZ, BESCOM,
3rd Floor, Crescent towers,
Bangalore-560001.

Sir,

CTR: 150/1A
MC: 15000

Date **04/07/2025**

Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details has been rated for periodical rating/complaint on..... You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

R.R. NO. **DHTP/139** CD. **2750** KVA CTR. **150/1A** Previously rated on **04/07/2024**
Activity **Textile Industry** Tariff **HT 2A** A Meter Constant.....
Name & Address of the Consumer **M/S Doddaballapura Integrated Textile Park Ltd**
Balichettyhalli, D.R. Pura(U)

2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

The installation of the meter is calibrated before and after the replacement of CTR and found OK. And the meter records within the limit.

3. ADVICE ON REVENUE MATTER:

EX CD: **1750 KVA** **New CD: 2750 KVA**
EX CTR: **100/1A** **New CTR: 150/1A** **Meter No: 1159W703092**
EX MC: **10000** **New MC: 15000**

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis if rated against complaint.....

ANNEXURE

1. DETAILS OF SEALS:

SL. No.	Seals Provided to	R.R. No. DHTP/139			
		Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter	BM102982		BM102983	
2	TC Of Meter	BRA2A28364		BRA2A28367	
3	M.D. Reset Knob	BRA2A28365	BRA2A28368	BRA2B73859	BRA2B73861
4	Optical Port	BRA2B93711	BRA2B28369	BRA2B73860	BRA2B73862
5	T.T.B	BRA2B93712		BRA2B73863	
6	Meter Chamber Main Door	BRA2A28371	BRA2B73864		
7	Meter Reading Window	BRA2A28372			
8	C.T./P.T. Chamber	MT088217	MT088218		
9	Cable Entry Chamber				
10	Hologram				

2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 bushing / LBS. Make..... Sl. No.....
b) Cubicle Conditions & Location..... **Good.**

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11KV/\sqrt{3}/110/\sqrt{3}}{1 \times 1} \times \frac{150/1}{1} \times 1 = 15000$$

Fifteen thousand only.

4. DETAILS OF Ct's/ Pt's:

