

SL No	Particulars	Amount in RS	9% CGST in RS.	9% SGST in RS.	Total Amount in RS
1	<b>2MMD</b>				
	a) 60KW * 01No Tariff LT-6(c) (55,200/-)	55,200/-	0	0	55,200/-
2	DCW Charges	9,71,254/-	0	0	9,71,254/-
3	10% ESCOM Establishment Cost on Total cost of the DCW estimate	97,125/-	8,741/-	8,741/-	1,14,608/-
4	Transformer Testing Fees	1,000/-	0	0	1,000/-
5	LT Meter Cubicle Testing Fees	4,080/-	0	0	4,080/-
<b>Total Amount (Eleven Lakhs Forty six Thousand one Hundred forty two Rupees Only).</b>					<b>11,46,142/-</b>

- As per BESCOM order No: CGM(OP)/DGM(OP-1)/AGM(OP-3)/AE-1/BC-05/2020-21/Cys-164 Dated: 29.03.2021. The Sub divisional officers ensure the transformer quality and rating at the authorized test bench/Divisional stores before servicing of installation and Amendment No. BESCOM/CGM(OP)/DGM(OP-1)AGM-3(OP-1)/AE-1(OP-1)/FY 2021-2022 /CYS-19 Dated: 17.05.2021 the applicant has to test the transformer at BESCOM Centre by paying Rs.1000/- along with GST as mentioned in circular at the concerned division office, where the transformer are tested.
- Pre commissioning report from cable (W&M) Division, BESCOM shall be obtained for the newly laid cables under self-execution works before connecting to the network.
- ಸಿಂಗಲ್ ಫೇಸ್ 0 ಸಂಖ್ಯೆ 5-30 ಅಂಪ್ಸ್ ಮತ್ತು ಮೂರು ಫೇಸ್ 0 ಸಂಖ್ಯೆ 5-30 ಅಂಪ್ಸ್ ಮಾಪಕಗಳನ್ನು ತಾವು ನಿಯಮಾನುಸಾರ ತಮ್ಮ ವೆಬ್‌ಸೈಟ್‌ನಲ್ಲಿ ಅಳವಡಿಸಿಕೊಳ್ಳತಕ್ಕದ್ದು.
- Provide 01 ETV Meter with Suitable CTs.
- ಮುಖ್ಯ ಪ್ಯಾನೆಲ್ ಮತ್ತು ವಿತರಣಾ ಪ್ಯಾನೆಲ್‌ಗಳ ನಕ್ಷೆ ಮತ್ತು ವಿನ್ಯಾಸಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ನಿಗಮದ ವಿಭಾಗದಿಂದ ಅನುಮೋದನೆ ಪಡೆಯತಕ್ಕದ್ದು ಮತ್ತು ಮಾಸ್ಟರ್ ಮಾಪಕವನ್ನು ಅಳವಡಿಸುವುದು.
- As per BESCOM order No: BESCOM/CGM(OP)/DGM (OP-1)/FY 2021-2022/CYS-19 Dt:17.05.2021. The sub divisional officers ensure the transformer quality and rating at the authorized test bench/ Divisional stores duly collecting transformer test certificate issued by the concerned MT division before servicing of Installation.
- As per BESCOM Circular vide ref: BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates: - 15.02.2025 & CYS-102 dated 25-03-2025, The power supply shall be arranged to the above said installations through "Smart Energy Meter in line with its capacity and quantum of load requirement in BESCOM jurisdiction".
- ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ 5 ಸ್ಟಾರ್ ಹೊಂದಿರುವ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಪರಿವರ್ತಕವನ್ನು DCW ಯೋಜನೆಯಡಿಯಲ್ಲಿ ಅನುಮೋದಿಸಿದ ಅಂದಾಜುಪಟ್ಟಿಯ ಪ್ರಕಾರ ಅಳವಡಿಸುವುದು.
- ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಏರ್ಪಡಿಸುವ ಮುನ್ನ ನಿಯಮಾನುಸಾರ ಕಟ್ಟಡದ ಸುರಕ್ಷತೆಯ ಬಗ್ಗೆ ಬಿ.ಬಿ.ಎಂ.ವಿ ನೋಡಲ್ ಅಧಿಕಾರಿಯಿಂದ/ಸಂಬಂಧಪಟ್ಟ ಅಧಿಕಾರಿಯಿಂದ ಅನುಮತಿಯನ್ನು ಪಡೆಯುವುದು.

Applicant Name: Indian Oil Corporation Limited, (SRIVEN SERVICE STATION)  
Application ID: 1323209250033



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)  
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/SARJAPURA OMU /AET)

Office of the  
Assistant Executive Engineer Ele.,  
C,O&M, SARJAPURA OMU Sub Division  
BESCOM, SARJAPURA OMU

**IOCL(SRIVEN SERVICE STATION)**  
**SY.NO 195/3 DOMMASANDRA 562125**

Sir/Madam

**Sub :** Arranging power supply to an extent of **60.00 KW** in favor of IOCL(SRIVEN SERVICE STATION) SY.NO 195/3 DOMMASANDRA 562125 in SARJAPURA OMU OMU, SARJAPURA OMU

**Ref:** 1) Your application registration **1323209250033** dated **09-SEP-2025**

2) AEE/SARJAPURA OMU /AE(T) a/ **17-OCT-2025**

With reference to your application dated **09-SEP-2025**. Requesting for arranging power supply to an extent of **60.00 KW** power installations in favor of IOCL(SRIVEN SERVICE STATION) SY.NO 195/3 DOMMASANDRA 562125 in SARJAPURA OMU OMU, SARJAPURA OMU Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M SARJAPURA OMU sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1323209250033	13232092500330001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1323209250033	13232092500330001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	61.9067-LT METERING CUBICAL TESTING CHARGES	4080
1323209250033	13232092500330001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	62.9097-62.9097 - ESCOM Establishment Charges @ 10% on DCW(TAX)+CGST(46.9977)9%+SGST(46.9987)9%=(97125 + (97125*0.09) + (97125*0.09))	114607
1323209250033	13232092500330001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	47.3137-47.3137 - DCW(HT/LT) - NO TAX	971254
1323209250033	13232092500330001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	48.1037-48.1037 - ASD	1760
1323209250033	13232092500330001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	48.1017-48.1017 - ISD	53440
Total Amount in Rupees					1146141

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT6(C), or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

