

NO: EE(E)/CDP/AEE(O)/AE(T)/2025-26/ 1621-24

Date :

22 MAY 2025

**-: OFFICIAL MEMORANDUM :-**

- Sub: Enhancement of contract demand of the existing HT installation from 150 KVA to 320 KVA (Addition 170 KVA) bearing RR No. AKLHT-769 under HT-2(a) tariff in favour of M/S Adhesive Specialities, No.261/2, Vaddarapalya Road, Haragadde, Jigani KIADB O&M of Jigani Sub Division, Anekal Taluk - under self-execution.
- Ref: 1. Online Application Ref No: 8419503 Dated: 17.01.2025.  
2. AEE/JGN/AE(T)/2024-25/7551/29.01.2025  
3. This Office Intimation Letter Ref No: EEE/CDP/AEE(O)/AE(T)/2024-25/16125-26 Dated: 10.02.2025.  
4. Payment Certificate Letter Ref No: - AEE/JGN/AAO/SA/2024-25/7853 /25-02-2025.  
5. Circular No. BESCOM/GM (QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-186 Dated 12.02.2024.

With reference to the above, as per the recommendation of Jigani Sub-Division office vide ref letter No(2), approval was accorded by Executive Engineer (E), BESCOM, O&M Chandapura Division vide Ref(3) for Enhancement of contract demand from 150 KVA to 320 KVA (Addition 170 KVA) bearing RR No. AKLHT-769 under HT-2(a) tariff in favour of M/S Adhesive Specialities, No. 261/2, Vaddarapalya Road, Haragadde, Jigani KIADB O&M of Jigani Sub Division, as per the clause No. 34.01 KERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions:

1. The cost of the Sanctioned estimate is Rs. 45,922 /-(Total rupees Forty Five Thousand Nine Hundred Twenty Two only)
2. Metering standards is as per BESCOM circular cited under ref -5.
3. The Consumer has paid the following amounts in favour of AEE, BESCOM, Jigani sub division

Sl No	A/C Head	Amount in Rs	RT No	Date
1	ASD			
2	supervision charges @ 5 % on estimate cost	3,61,130-00	1324101001923	
Total Amount Paid		2296-00	1324101001924	20.02.2025
		3,63,426-00		

4. The Additional contract demand is final and it will not be revoked at later date.
5. The Additional contract demand shall be with effect from the Date of CT Replacement (MRT Date) for Enhancement of contract demand / sanctioned load along with fresh agreement for Additional contract demand & to obey Section 32.04 & its amendments from time to time.
6. The energy entitlement shall be re-fixed on Pro-rata basis (applicable during Power cut period).
7. Signature of the consumer shall be tallied with the signature in the original docket before effecting the Additional Contract Demand as per Norms.
8. The Consumer has to pay arrears and audit short claims, if any, detected at a later date.
9. The Consumer has to give an undertaking that he will abide by the above Conditions / decision of the appellate authority in respect of pending appeal/ court cases, if any.
10. The installation shall be rated by M.T Staff before & after implementation of Additional load.

11. The Consumer shall abide by the rules/regulations, if any, left out and regulations issued at later dates.
  12. The capacity of any Individual machinery / equipment installed / connected shall not be more than the approved CD.
  13. If SRTPV Load is sanctioned to this Consumer, then the existing PPA has to be withdrawn with immediate effect and Supplementary PPA to be executed as per prevailing KERC / BESCOM Norms.
- All Other formalities shall be observed as per the prevailing KERC regulations.

**(Dhananjaya C),  
Executive Engineer(Ele),  
C, O&M Chandapura Division,  
BESCOM.**

**Copy to:**

1. The Executive Engineer Ele, MT, BRAZ, BESCOM, Bangalore for information
2. The Accounts Officer, BESCOM, Chandapura Division for information
3. The Assistant Executive Engineer Ele, BESCOM, C, O&M Jigani Sub Division, for information **along with file.**
4. M/S Adhesive Specialities, No.261/2, Vaddarapalya Road, Haragadde, Jigani KIADB Office of Jigani Sub Division.
5. AE(T) / M.F / OC.

Ref Credit Wo No & Date	461/WDV/16.206.7/ R-65248 Dated : 03-03-2025
Ref ACK No & Date	

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**

No. AEE/JGN/AAO/SA/2024-25/ 7853

Email: aee.jigani@gmail.com

Mobile: 9448991274

Attachment:

To,

The Executive Engineer (Ele),  
BESCOM - Chandapura Division,  
Chandapura, Bangalore-560099

Office of the,

Assistant Executive Engineer (Ele)

BESOM, Jigani Sub-division, Jigani,

Date: 25/02/2025

Sir,

Sub: - Payment of deposit reg.....


Ref: -I- EEE/CDP/AEE(O)/AE(T)/2024-25/ 16125-26 Dt-10.02.2025


As per intimation letter under reference of M/s Adhesive Specialities, Sy No.261/2, Behind Indo Nissan Factory, Vaddarapalya Road, Haragadde Village, Jigani, Anekal Taluk, have paid the following amount towards arranging additional Power Supply to an extent of 170 KVA to AKLHT-769.


A/C Head	Application I D	Amt in RS	Rt.No	Date
ISD	8419503	361130	1324101001923	20.02.2025
5 % Supervision Charges	8419503	2296	1324101001924	20.02.2025
	<b>TOTAL</b>	<b>363426</b>		

Amount in words:- Rs.Three Lakhs Sixty Three Thousand Four Hundred and Twenty Six Only.

This is for your kind further needful action.

  
General Cashier  
Jigani sub division

  
Asst. Accounts Officer  
Jigani sub division

Yours Faithfully  
  
Asst. Executive Engineer (Ele),  
Jigani Sub division

E 3

Stamp: 3 MAR 2025 9761  
Handwritten: 63/3





# Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking) 8 - 250  
110

No: EEE/CDP/AEE (O)/AE(T)/2024-25/

16125-26

Office of  
Executive Engineer (Ele)  
C, O&M Division, BESCOM  
No. 204, Park Road., Phase-1,  
Suryacity, Chandapura.

10 FEB 2025

To

M/s Adhesive Specialities,  
Sy. No. 261/2, Behind Indo Nissan factory,  
Vaddarapalya Road,  
Haragadde Village,  
Anekal Taluk.

Sir/Madam,

Sub: Arranging power supply to an extent of Addl Load of 170 KVA to the existing contract demand 150 KVA totaling 320 KVA of RRNO : AKLHT-769 M/s Adhesive Specialities at Sy. No. 261/2, Behind Indo Nissan factory, Vaddarapalya Road, Haragadde Village, Anekal Taluk.

Ref: 1) Your Application Reg. No. 8419503 / 17.01.2025

2) Letter No: AEE/JGN/AE(T)/2024-25/7551 / 29.01.2025

BESCOM is pleased to sanction for power supply to an extent of Addl Load of 170 KVA to the existing contract demand 150 KVA totaling 320 KVA of RRNO : AKLHT-769 M/s Adhesive Specialities at Sy. No. 261/2, Behind Indo Nissan factory, Vaddarapalya Road, Haragadde Village, Anekal Taluk.

Subject to below conditions:

• Power supply will be arranged from F-46 Anadha Sweets Road of 66/11 KV Jigani MUSS

2. You are requested to pay the following charges by DD/Cash (above 10000/- only DD will be accepted) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM Jigani Sub-Division within 90 Days from the date of this intimation and furnish the payment certificate for taking further action in this matter

Deposit Held Rs. 2,98,070/-	
Deposit Required for 320 KVA under HT-2(a) tariff is Rs. 6,59,200/-	Tariff – HT-2a
Deposit to be paid : 3,61,130/-	
Payment Towards	Amount(Rs.)
ISD	361130.00
5% Supervisory Charge(61.904)	2296.00
Total	363426.00

3. To Submit payment certificate along with Self execution agreement on Rs. 500/- stamp paper regarding obtaining of necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.

4. The metering equipment to be installed should be conspicuously visible and at the main inference to the premises preferably with an independent entrance.

6. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation

It is proposed to replace the existing 7.5/1 Amps 3CT by 20/1 Amps 3CT.

7. a) You should execute an agreement in the prescribed form and shall be submitted to the Executive Engineer Ele. of concerned division along with payment certificate.

b) Produce necessary Licensee/permit /NOC objection Certificate, etc. issued by the competent authorities as required under statute.

c) Submit the completion-cum-test report from Class-I Licensed Electrical Contractor along with lists in duplicate showing details of machinery, make, capacity and the layout plan of your premises within which you intend to use the power. The capacity of any individual machinery equipment installed /connected shall not be more than the contract demand.

- d) You should produce the approval of competent authority of Electrical Inspectorate to charge the equipment installed by you.
8. After payment of requisite supervisor charges and deposits and fulfillment of stipulated conditions administrative approval / certificate will be issued from this office.
9. You should comply with the following requirements within a period of 90 days from the date of this letter failing which sanction will stand cancelled.
- a) Execute an agreement in prescribed form on Rs.500/- stamp paper.
- b) Furnish the contractor's completion-cum test report along with a list in duplicate showing details of machinery, make, capacity and the layout plan of your premises within which you intend to use the power. The capacity of any individual machinery / equipment installed / connected shall not be more than the contract demand.
10. You are liable to pay the tariff minimum charges from the date of commencement of supply i.e., actual date of availing of the power supply or expiry of 90 days of notice issued by BESCOM whichever is earlier as indicated in the agreement even if you fail to avail power supply.
11. The tariff applicable to your installation will be as per the prevailing power tariff.
12. 11 KV System shall be as per BESCOM standard practices, the material used shall confirm ISI/BESCOM/KPC specification and got inspected before commencing of work by the undersigned.
13. All the major materials like transformer, ACSR conductor, metering cubicle, HT UG cable, LT UG cable, 11 KV Insulator and 11 KV single/double break GOS shall be procured only from the BESCOM approved vendors. You have to use only 11 KVA polymeric type of insulator as per the directions of corporate office vide Ltr. No. BESCOM/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/Cys-113 dated 29.08.13.
14. You shall submit the copies of invoice/bills respect of materials purchased by you for proof of having purchased materials from approved vendors/dealers.
15. Guarantee shall be furnished for a period of not less than one year for the materials used in the works as well as for the works carried out from the date taking over the lines and equipments by BESCOM.
16. You have to install approved shunt capacitors of appropriate capacity, so as to maintain the power factor at not less than 0.90.
17. If you are not desirous of availing the power supply, the amount paid by you towards initial security deposits, and security will be refunded on application, after deducting of 10% of the total amount.
18. The approval for your installation by electrical inspectorate (Test and Commissioning Certificate) should be produced for servicing of your installation.
19. You have to produce necessary license/permit/NOC from KSPCB before placing Work Order.
20. You have to produce necessary NOC from respective PGCIL/KPTCL if any EHT lines pass in premises before availing power supply to the layout/building.
21. For all EHT/HT/LT lines passing through the layout/building safety clearance to be maintained. (Statutory) are shifting existing lines to be done at your cost.
22. BESCOM is not responsible in whatsoever manner regarding any of legal dispute that may arise at later stage.
23. The entire distribution system along with connected equipment's will be taken over by KPTCL/BESCOM after completion of work.
- You are requested to contact Assistant Executive Engineer(Ele), Jigani Sub-Division, BESCOM or this office for any clarification.

Yours Sincerely,

(Dhananjaya C)

Executive Engineer (Ele)  
C, O&M Division, BESCOM  
Chandapura

Copy to.

1. The Asst. Executive Engineer (Ele), C, O&M Sub-Division, Jigani for information.
2. AE(T)/MF