



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

Office of the Asst. Executive Engineer (Ele.), C, O&M Section -VEERASANDRA
Change Request Note For- 1969200

Application No	61325105250028
Application Submission Date	29-05-2025
Applicant Name	K MOHAMMED SAMCEER
Applicant Address	YARANDANAHALLYF12NO.228.B,3RD PHASEBOMMASANDRA INDUSTRIAL AREACHANDAPURA0
Application For	LOAD CHANGE
Additional Load	50KVA
Existing Load KW/HP/KVA	0.00 /0.00/200.00
New Load KW/HP/KVA	0 /0.00/250.00
Change Request Fee	Rs: 250/-
Total Amount	Rs: 250 /-

Circle : RAMANAGAR Division : CHANDAPURA Subdivision : VEERASANDRA Section : VEERASANDRA

NOTE 1**: Please Make the payment for the above and submit the receipt Details After Payment.

2**: This Demand Note generated as per the intimation provided at the time of application. At the time of inspection if additional SLC or Additional Load is required a supplemental demand note will be issued. Your installation will be serviced after all the payments are received.



BANGALORE ELECTRICITY SUPPLY
COMPANY LTD.
VEERASANDRA

ರೇಷನ್ ಸಂಖ್ಯೆ : 1325101011204

ಕಾಂಟೇನರ್ ಸಂಖ್ಯೆ : 1325101

ಪಾವತಿ ಮಾರ್ಗ : Cash

ಪಾವತಿ ದಿನಾಂಕ : 29/05/2025 12:50:29 PM

ಪಾವತಿ ಮೊತ್ತ : 619067

ರಾ. ರಾ. ಸಂಖ್ಯೆ : 61325105250028

ಬಳಕೆದಾರರ ಸಂಖ್ಯೆ : 1969200

ಬಳಕೆದಾರರ ಹೆಸರು : K MOHAMMED SAMCEER

ವಿಳಾಸ : YARANDANAHALLY 12 NO. 228.

3RD PHASE BOMMASANDRA INDUSTRIAL AREA CH
APURAO

ಹಂತ : N/A

ಬೆಲ್ಟ್ ಕಾಂಟ : DL391

ಪಾವತಿ ಮೊತ್ತ : Rs. 250

ಅಧಿಕಾರದ ವಿಧ : NON-REVENUE

ಅಧಿಕಾರದ ವಿಧ : ADDITIONAL LOADS

(Two hundred Fifty Only)

THANKS FOR USING CASH COUNTER



Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/CDP/AEE (O)/AE(T)/2025-26/

2349-50

Office of
Executive Engineer (Ele)
C, O&M Division, BESCOM
No. 204, Park Road., Phase-1,
Suryacity, Chandapura.

To

Sri. K Mohammed Samceer,
No. 228B, 3rd Phase,
Bommasandra Industrial Area,
Anekal taluk.

Sir/Madam,

5 JUN 2025

Sub: Arranging power supply to an extent of Addl. 50 KVA to the existing Contract demand of 200 KVA totaling 250 KVA of HT installation of RR No. CDPHT-472 of Sri. K Mohammed Samceer, at No. 228B, 3rd Phase, Bommasandra Industrial Area, Anekal taluk.

Ref: 1) Your Application Reg. No. 61325105250028 / 29.05.2025

2) Letter No: AEE/VSRAE(T)/2025-26/315 dated 30.05.2025.

BESCOM is pleased to sanction for Arranging power supply to an extent of Addl. 50 KVA to the existing Contract demand of 200 KVA totaling 250 KVA of HT installation of RR No. CDPHT-472 of Sri. K Mohammed Samceer, at No. 228B, 3rd Phase, Bommasandra Industrial Area, Anekal taluk.

Subject to below conditions:

- Power supply will be arranged from F-12 Deepak Forge Feeder of 220/66/11 KV Yarandahalli MUSS

2. You are requested to pay the following charges by DD/Cash (above 10000/- only DD will be accepted) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM Veerasandra Sub-Division within 90 Days from the date of this intimation and furnish the payment certificate for taking further action in this matter

Deposit Held Rs. 10,36,650/-	
Deposit Required for 250KVA under HT-2a is Rs. 5,02,500/-	Tariff - HT-2a
Deposit to be paid Rs. NIL/-	
Payment Towards	Amount(Rs.)
5% Supervisory Charge(61.904) (On Total estimate cost Rs. 46,793/- Excluding electrical Inspectorate Charges)	2340.00
Total	2340.00

3. To Submit payment certificate along with Self execution agreement on Rs. 500/- stamp paper regarding obtaining of necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.

4. The metering equipment to be installed should be conspicuously visible and at the main inference to the premises preferably with an independent entrance.

6. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation

It is proposed to replace the existing 10/1 Amps 3 CT by 12.5/1 Amps 3CT.

7. a) You should execute an agreement in the prescribed form and shall be submitted to the Executive Engineer Ele. of concerned division along with payment certificate.

b) Produce necessary Licensee/permit /NOC objection Certificate, etc. issued by the competent authorities as required under statute.

c) Submit the completion-cum-test report from Class-I Licensed Electrical Contractor along with lists in duplicate showing details of machinery, make, capacity and the layout plan of your premises within which you intend to use the power. The capacity of any individual machinery equipment installed /connected shall not be more than the contract demand.



- d) You should produce the approval of competent authority of Electrical inspectorate to charge the equipment installed by you.
8. After payment of requisite supervisor charges and deposits and fulfillment of stipulated conditions administrative approval / certificate will be issued from this office.
9. You should comply with the following requirements within a period of 90 days from the date of this letter failing which, the sanction will stand cancelled.
 - a) Execute an agreement in prescribed form on Rs.500/- stamp paper.
 - b) Furnish the contractor's completion-cum test report along with a list in duplicate showing details of machinery, make, capacity and the layout plan of your premises within which your intend to use the power. The capacity of any individual machinery / equipment installed / connected shall not be more than the contract demand.
10. You are liable to pay the tariff minimum charges from the date of commencement of supply i.e., actual date of avallment of the power supply or expiry of 90 days of notice issued by BESCO which ever is earlier as indicated in the agreement even if you fail to avail power supply.
11. The tariff applicable to your installation will be as per the prevailing power tariff i.e HT-2A
12. 11 KV System shall be as per BESCO standard practices, the material used shall confirm ISI/BESCO/KPTCL specification and got inspected before commencing of work by the under signed.
13. All the major materials like transformer, ACSR conductor, metering cubicle, HT UG cable, LT UG cable, 11 KV pin Insulator and 11 KV single/double break GOS shall be procured only from the BESCO approved vendors. You have to use only 11 KVA polymeric type of insulator as per the directions of corporate office vide ltr. No. BESCO/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/Cys-113 dated 29.08.13.
14. You shall submit the copies of invoice/bills respect of materials purchased by you for proof of having purchased materials from approved vendors/dealers.
15. Guarantee shall be furnished for a period of not less than one year for the materials used in the works as well as quality of works carried out from the date taking over the lines and equipments by BESCO.
16. You have to install approved shunt capacitors of appropriate capacity, so as to maintain the power factor at not less than 0.90.
17. If you are not desirous of availing the power supply, the amount paid by you towards initial security deposits, Meter security will be refunded on application, after deducting of 05% of the total amount.
18. The approval for your installation by electrical inspectorate (Test and Commissioning Certificate) should be produced for servicing of your installation.
19. You have to produce necessary license/permit/NOC from KSPCB before placing Work Order.
20. You have to produce necessary NOC from respective PGCIL/KPTCL if any EHT lines pass in premises before availing power supply to the layout /building.
21. For all EHT/HT/LT lines passing through the layout/building safety clearance to be maintained. (Statutory) are shifting of existing lines to be done at your cost.
22. BESCO is not responsible in whatsoever manner regarding any of legal dispute that may arise at later stage.
23. The entire distribution system along with connected equipment's will be taken over by KPTCL/BESCO after completion of work.
24. Intimation issued as per manual estimate.

You are requested to contact Assistant Executive Engineer (Ele), Veerasandra Sub-Division, BESCO or this office for any clarification.

Yours Sincerely,

Executive Engineer (Ele)
C, O&M Division, BESCO
Chandapura

Copy to.

1. The Asst. Executive Engineer (Ele), C, O&M Sub-Division, Veerasandra for information.
2. AE(T)/MF



No: AEE/VSR/AAO/SA/ 409

Dated: 17/6/2025

Sir,

Ref: - 1 your kind Ltr:- EEE/CDP/AEE (O)/AE (T)/2025 - 26/2349 - 50 Dated
05.06.2025.

A/C Head	Amt in RS	Rt.No	Date
SC 5%	2,340 = 00	1325101011647	13.06.2025
TOTAL	2,340 = 00		

This is for your kind further needful action.

Asst.Executive Engineer (Ele),
Veerasandra sub division

Asst. Accounts Officer
Veerasandra sub division



NO: EE (E)/CDP/AEE (O)/AE (T)/2025-26/ 3949-52

Date :

22 JUL 2025

-: OFFICIAL MEMORANDUM :-

- Sub: Enhancement of contract demand of the existing HT installation from 200 KVA to 250 KVA (Addition 50 KVA) bearing RR No. CDPHT-472 under HT-2(a) tariff in favour of Sri.Mohammed Samceer at No.228B, 3rd Phase BIA Anekal Taluk in Ananthanagara O&M unit Veerasandra Sub-Divison – under self-execution.
- Ref: 1. Online Application Ref No: 61325105250028 Dated: 29-05-2025.
2. AEE/Veerasandra SD / AE (T)/2024-25 / 315 Dated: 30-05-2025.
3. This Office Intimation Letter Ref No: EE (E)/CDP/AEE (O)/AE (T)/2025-26/3949-50 Dated: 05-06-2025.
4. Payment Certificate Letter Ref No:- AEE/VSR/AAO/SA/25 Dated : 5-04-2025.
5. Circular No: -BESCOM/GM (QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-186 Dated 12.02.2024.

With reference to the above, as per the recommendations of the Assistant Executive Engineer Ele., Veerasandra Sub Division vide ref-2, approval is hereby accorded for Enhancement of contract demand of the existing HT installation from 200 KVA to 250 KVA (Addition 50 KVA) bearing RR No. CDPHT-472 under HT-2(a) tariff in favour of Sri.Mohammed Samceer at No.228B, 3rd Phase BIA Anekal Taluk in Ananthanagara O&M unit Veerasandra Sub-Divison, , as per the clause No. 34.01 KERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions:

- The Consumer has to supply the CTs and in presence of AEE, MT division, BRAZ & the MT Staff the existing 11 KV, CTs of ratio 10/ 1A, 0.2S class of accuracy to be replaced by new CTs of ratio 12.5 /1A, 0.2s class of accuracy . The cost of the Sanctioned estimate is Rs. 46,793 /- (Total rupees Forty Six Thousand & Seven Hundred Ninety Three only)
- Metering standards is as per BESCOM circular cited under ref-5.
- The Consumer has paid the following amounts in favour of AEE, BESCOM, Veerasandra sub division

SI No	A/C Head	Amount in Rs	RT No	Date
1	supervision charges @ 5 % on estimate cost	2,340-00	1325101011647	13-06-2025
Total Amount Paid		2340-00		

- The consumer is liable to pay the tariff minimum charges from the date of commencement of supply (i.e. actual date of availing of power supply or expiry of 30 days' notice period issued by the BESCOM whichever is earlier) as indicated in the agreement even if consumer fail to avail power supply.
- The Additional contract demand is final and it will not be revoked at later date.
- The Additional contract demand shall be with effect from the Date of CT Replacement (MRT Date) for Enhancement of contract demand / sanctioned load along with fresh agreement for Additional contract demand & to obey Section 32.04 & its amendments from time to time.
- The energy entitlement shall be re-fixed on Pro-rata basis (applicable during Power cut period).
- Signature of the consumer shall be tallied with the signature in the original docket before effecting the Additional Contract Demand as per Norms.

9. The Consumer has to pay arrears and audit short claims, if any, detected at a later date.
 10. The Consumer has to give an undertaking that he will abide by the above Conditions / decision of the appellate authority in respect of pending appeal/ court cases, if any.
 11. The installation shall be rated by M.T Staff before & after implementation of Additional load.
 12. The Consumer shall abide by the rules/regulations, if any, left out and regulations issued at later dates.
 13. The capacity of any individual machinery / equipment installed / connected shall not be more than the approved CD.
 14. If SRTPV Load is sanctioned to this Consumer, then the existing PPA has to be withdrawn with immediate effect and Supplementary PPA to be executed as per prevailing KERC / BESCOM Norms.
- All Other formalities shall be observed as per the prevailing KERC regulations.

[Signature] 22/7
**Executive Engineer(Ele),
 C, O&M Chandapura Division,
 BESCOM.**
[Signature] 22/7/25

Copy to:

1. The Executive Engineer Ele, MT, BRAZ, BESCOM, Bangalore for information
2. The Accounts Officer, BESCOM, Chandapura Division for information
3. The Assistant Executive Engineer Ele, BESCOM, C, O&M Veerasandra Sub Division, for information **along with file.**
4. Sr. Mohammed Samceer at No.228B, 3rd Phase BIA.
5. AE(T) / M.F / OC.

Ref Credit Wo No & Date	461/WDV/16.206.7/ S-61314 Dated : 20-06-2025
Ref ACK No & Date	329/22.07.2025