



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly Owned Government of Karnataka Undertaking)

NO : EEE/HKTD/AEE(O)/AE-1/2025-26/3143

Date : 21/7/25

Encl:

O/o Executive Engineer (Elec),  
C, O&M Hoskote Division,  
Hosakote-562114.

Email ID: eehosakote@bescom.co.in  
eeylhmk.work@gmail.com

☎: 080-27931033 / 9448279024

**OFFICIAL MEMORANDUM**

**Sub:-** Additional of Contract demand from 120 kVA to 149 kVA of (Additional load of 29 KVA) existing HT installation bearing RR No.AVHT-109 in favour of **M/s Halotech System Pvt Ltd at Sy No.123/2, Kannauru Village, Bidarahalli Hobli, Banaglore East Taluk** in Doddagubbi O&M of Avalahalli Subdivision.

**Ref:-** Ltr. No.AEE/AVL/AET/2025-26/1392, dt:24.06.2025.

In accordance with the Conditions of Supply of Electricity of Distribution licenses in the State of Karnataka approval is hereby accorded for additional of Contract demand from **120 kVA to 149 kVA** of (Additional load of 29 KVA) existing HT installation bearing RR No.AVHT-109 in favour of **M/s Halotech System Pvt Ltd at Sy No.123/2, Kannauru Village, Bidarahalli Hobli, Banaglore East Taluk** in Doddagubbi O&M of Avalahalli Subdivision subject to the following conditions.

1. The additional of load is final and it will not be revoked at a later date.
2. The additional of load shall be given effect from the meter reading date following the expiry of two months period from the date of registration of the application.
3. The energy entitlement shall be re-fixed on Pro-rate basis (applicable during Power cut period).
4. The Consumer has to enter into fresh agreement for additional Contract Demand.
5. Signature of the consumer has to be tallied with the signature in the original docket before effecting the additional of load.
6. The Consumer has to pay arrears and audit short claims if any detected at a later date.
7. Fresh indemnity Bond has to be taken from the consumer.
8. The consumer have to give an undertaking to the effect that he will abide by the above condition / decision of the appellate authority in respect of pending appeal/ court cases if any.
9. The installation shall be rated by M.T. Staff before & after effecting of additional of load.
10. The Consumer is subject to abide by the rules/regulations, if any left out and regulations issued at later dates.
11. The connected load of any single machine should not exceed the additional CD.
12. You have to pay EXIT charges if approved by the Regulatory Commission.
13. The security deposit required shall be recalculated for the additional contract demand on prorata basis on average monthly bill of the preceding calendar year as per clause 34.04 and balance of deposit shall be refunded to the consumer.
14. The existing CT's of ratio in the metering cubical will be 7.5/1A Amps.
15. **Note:** Existing load 120KVA+ Additional Load 29 KVA total load 149 KVA the 2 mmd will be Rs.2,87,570/-. But the consumer has security deposit of Rs.3,12,000/-. Since the existing deposit is higher than present total load deposit, 2 mmd amount need not to be paid.

**Note:** Applicant should produce the Occupation Certificate issued by the local authorities before servicing the installation and applicant should abide by all the regulations/conditions of corporate office circular ಮುಖ್ಯವ್ಯಕ್ತಿ(ಕಾ)/ಉಪವ್ಯಕ್ತಿ/ಜಿ.ಸಿ-5/ಕ-341/25-26/ Cys -02 Dt: 04.04.2025.

All Other formalities shall be observed as per the prevailing KERC regulations.

  
Executive Engineer, El. (C, O&M),  
BESCOM, Hosakote Division.