

P-40
73



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: EEE/CDP/AEE(O)/AE(T)-2/2025-26/

Office of the

Executive Engineer (EI)

C,O&M Chandapura Division
BESCOM, No-204, Park Road, 1st
Phase, Suryacity, Chandapura,
Bengaluru-570081

Encl: 1 File

8837-38

E-mail: eechndpr.work@gmail.com

Date :

19 NOV 2025

To,

**M/s NEO BUILD VENTURES LLP
Rep by Sri A Shyam Prasad
At Sy No 4/9,4/10,5,59/1,59/2,60/4
Chikkanahalli Village
R R No ATBHTTP43**

**Power Sanction Letter for HT
Temp Additional Load.**

Sir,

Sub:- Intimation for Arranging Additional contract demand for existing HT Temporary installation bearing R R No ATBHTTP-43 from 200 KVA to 480 KVA (Addition 280KVA) under HT5 tariff in favour of **M/s NEO BUILD VENTURES LLP, Rep by Sri A Shyam Prasad At Sy No 4/9, 4/10,5, 59/1,59/2, 60/4, Chikkanahalli Village, Sarjapura (Hobli), Anekal (T)**

Ref:- 1.Your Application No: 61323210250016 Dated 18.10.2025.
2.AEE, Attibele SD Office Letter Ref No : 5130 Dated : 04.11.2025.

*** **

With reference to the above subject, as per the recommendation of the Assistant Executive Engineer (Ele), Attibele Sub-division vide ref-(?), power sanction is hereby accorded for arranging Addition of contract demand of the existing HT Temporary installation bearing R R No ATBHTTP-43 from 200 KVA to 480 KVA (Addition 280KVA) under HT5 tariff in favour of M/s NEO BUILD VENTURES LLP, Rep by Sri A Shyam Prasad At Sy No 4/9, 4/10,5, 59/1,59/2, 60/4, Chikkanahalli Village, Sarjapura (Hobli), Anekal (T) Bengaluru, Attibele Sub-Division under Self Execution, subject to the following conditions and observance of KERC / BESCOM norms in force.

The proposed for arranging power supply is as follow:

Regular source:

Station: 66/11 KV Dommasandra MUSS which has a peak load of 26 MW with installed capacity of power transformers 2*31.5 MVA

Feeder: Existing F-15 T C Halli feeder which has a peak load of 470KVA with 3x400 Sq.mm XLPE HT UG cable/Coyote/Rabbit.

The following works are proposed under self-execution. BESCO portion.

- > Replace the existing 11 KV, CTs of ratio 10/1A, 0.2S class by new CTs of ratio 25/1A, 0.2s class.
- 1. You are requested to pay the following amount by way of Demand Draft drawn in favour of the AEE, Attibele SD, BESCO, at the office of **Assistant Engineer (Ele), Sarjapura Section** within 90 days from the date of this intimation and furnish the payment certificate to this office for taking further action failing which the power sanction will stand cancelled.

Deposit Held : 10,69,086 /-

Deposits	Amount in Rs	CGST @ 9%	SGST @ 9%	Total Amount in Rs
Deposit to be Paid for additional load of 280 KVA	23,49,100/-			23,49,100/-
5% SC payable (Estimate Cost of Rs.44,976/-)	2,249/-	202/-	202/-	2,653/-
Demand Charges is required for 547 HP is Rs 2,18,800/- already exsistng is Rs 68000/-	2,12,200/-			2,12,200/-
TOTAL (RUPEES TWENTY FIVE LAKHS SIXTY THREE THOUSAND NINE HUNDREAD AND FIFTY THREE ONLY)				25,63,953 /-

- 2. The appropriate tariff shall be applicable as per prevailing KERC tariff order 2025 for BESCO.
- 3. You are liable to pay the tariff minimum charges from the date of commencement of supply (i.e., actual date of availing of power supply or expiry of 30 days' notice period issued by the BESCO whichever is earlier) as indicated in the agreement even if you fail to avail power supply.
- 4. You have to install approved shunt capacitors of appropriate capacity as to maintain the power factor at not less than 0.9
- 5. The power tariff applicable to your installation will be HT-2A tariff or as in force from time to time.
- 6. In future, if the total load requirement exceeds 7500 kVA then the applicant/developer shall establish 66/11 KV substation at their own cost in the above...

Consumer... Karnataka State... co-ordination... The major materials... it should be tested... 11. The materials... IE/BESCO...