



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly owned by Government of Karnataka)

No.EEE/AEE(O)/AE(T-2)/Klr/2025-26/  
Mobile No.9448279019  
Phone No.08152 222607  
Email id: eeklrdivn.work@gmail.com  
Encl:

10544-45

280  
ಕಾರ್ಯದರ್ಶಿ

Office of the  
Executive Engineer(Ele)  
C, O & M Division,  
BESCOM, Kolar

Date: 6 FEB 2026

To,  
Sri.Mallikarjunaiah.A.G S/o Gopalappa.G.  
Plot No. P11.12  
Tamaka Industrial Area  
Kolar Taluk -563101.  
Sir,

"Power Sanction"

Sub: Power sanction for Arranging 250 KVA HT Power Supply for Industrial purpose in favor of Sri.Mallikarjunaiah.A.G S/o Gopalappa.G located at Plot No: P11.12 Bethmangala Road in Tamaka Industrial area of Kolar Urban Sub-division **UNDER Self Execution** - reg.

Ref: 01. Offline Application Registration: HT-25 Date: 30.12.2025.  
02. Online application ID No.1223112250049, Sub Application ID: 12231122500490001 Dated: 29.12.2025.  
03. Estimate No. SP-391 Dated: 07.02.2026.  
Submission of file from AEE Kolar USD vides No.AEE/ AET/ BESCOM/ USD/2025-26/2873, Dated: 12.02.2026.

BESCOM is pleased to communicate the Power sanction for Arranging 250 KVA HT Power Supply for Commercial purpose in favor of Sri.Mallikarjunaiah.A.G S/o Gopalappa.G located at Plot No: P11.12 Bethmangala Road in Tamaka Industrial area, O&M-3 Section of Kolar Rural Sub-division **UNDER Self Execution**.

The Power Sanction is subject to the following conditions:

1. **Regular source:**

**Line:** Existing 11kV TF-14 Industrial Feeder having peak load of 80 Amps feeding from 66/11kV Tamaka Sub-Station.

**Sub-station:** 66/11 KV Tamaka having peak load 24 MWs with installed capacity of 1\*12.5 and 1\*20 MVA


**Alternate source:** NA

2. You shall construct 11 KV line and HT metering Cubicle as per the BESCOM norms **under Self-Execution**.
3. The materials procured shall be in-accordance with the IE/BESCOM/KPTCL specifications and the materials shall be got inspected by QS & S / Jurisdictional Executive Engineer Ele, C, O & M Division BESCOM. The copies of the invoices / bills of the materials purchased shall be submitted as proof of purchase from the BESCOM approved vendors / dealers.
4. You have to pay the following amounts through DD Payable at SBI Kolar branch, drawn in favour of **AEE, BESCOM, Kolar Urban Sub-Division** within 90 days from the date of this intimation and Electrical inspectorate charges to DEI, Govt. of Karnataka.
- a. **Rs. 33,773/-** towards Supervision charges at 5 % of estimate cost of Rs. 6,75,465/-.
- b. **Rs. 5,02,500/-** towards ISD under HT-2(a) tariff for 250 KVA load.
- c. **Rs.10,000/-** towards Material Inspection Charges.
5. You have to execute the works as per approved estimate under self-execution through class-1 Licensed Electrical Contractor, under the supervision of BESCOM.
6. The major materials like Transformer, ACSR conductor, Metering cubicle, HT UG cable etc., shall be procured from the BESCOM approved vendors and other materials may be procured from authorized dealers / approved vendors. You have to use only Polymer

insulators as per the corporate circular no. BESCOM/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/CYS-113 dtd 29-8-13.

7. Major materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminium/copper conductor, Optical fiber, Insulators, GOS & CSS shall be assured guaranteed for 5 years for the defects in materials and workmanship from the date of commissioning.
8. Minimum guarantee of five years from the date of commissioning for the materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminium/copper conductor, Optical fiber, Insulators, GOS & CSS. For the rest of equipment's/materials shall be guaranteed for the 12 months from the date of commissioning. The consumer liability shall be limited to the replacement of the any defective parts in the equipment's of his own manufacture or those of his vendors.
9. Guarantee shall be furnished for a period not less than one year for the materials used for the works. Guarantee for period not less than one year for the quality of work carried out from the date of taking over the lines and equipment's by BESCOM.
10. Approval of the Electrical Inspectorate shall be obtained for the electrical equipment and lines before Commissioning as per the KERC norms.
11. You have to submit the Occupancy certificate / such other certificate from the competent authority before availing the service
12. BESCOM is not responsible in whatsoever manner regarding any legal disputes that may arise at a later stage.
13. Any modification in the existing system shall be at the cost of developer with prior approval of the competent authority. Suitable safety clearance shall be maintained for the Electrical lines in accordance with the IE rules.
14. NOC from concerned authority (PGCIL/KPTCL) shall be obtained whenever EHV lines pass in the premises.
15. You should clear the outstanding arrears of the installations inside the premises, if any.
16. You should abide to the conditions of supply as per prevailing electricity act in force with subsequent amendments.
17. You have to submit the Pollution Control Board Consent before servicing the installation.
18. As per the KERC clause 4.02(g)(iv) & amendment No. KERC/CoS/D/07/10. Dtd.01.07.2010 you have to install Solar water heaters & same shall be certified & to be produced before servicing the installation.
19. You have to certify for not taking the child labour in your installation.
20. The payment certificate duly signed by the Assistant Executive Engineer, Kolar Urban Sub-Division shall be sent to this office for issuing Administrative approval. Any delay in making payment, not fulfilling the above conditions within 90 days, the power sanction is deemed to be cancelled as per the conditions stipulated in the KERC.
21. You have to pay any variation / difference charges payable to BESCOM, if any in future.
22. You are requested to contact the Assistant Executive Engineer, El., C, O & M Urban Sub-division, Kolar for any clarifications.

Yours faithfully,

  
Executive Engineer, El.,  
C, O & M Division,  
BESCOM, Kolar

**Copy to:-**

1. The Asst. Executive Engineer (El), C, O & M Urban Sub-Division, BESCOM, Kolar.
2. AEE(O)/AE-2/OC/MF.