

Bangalore Electricity

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/ HKTD/AEE (O)/AE(T)/2025-26/35(5

Office of Executive Engineer C, Q&M BESCOM

To

M/s Larsen & Toubro Ltd, Sy No.39, 40/1, Gollahalli Village, Jala Hobli, Bangalore North Talluk.

Sir/Madam.

Sub: Arranging power supply to reduction of contract demand from 400 KVA to 35 KVA (Reduction load of 365 KVA) to existing installation bearing RR No. VNHTP-53 in favour of M/s Larsen & Toubro Ltd at Sy No.39, 40/1, Gollahalli Village, Jala Hobli, Bangalore North Talluk in Sadahalli O&M of Vidyanagara Sub Division, under self execution.

Ref: 1)Your Application Reg. No. 61126107250002 dated:02/07/2025.

2) Letter No:AEE/V.Nagara/AET/2025-26/896 dt.02.07.2025.

BESCOM is pleased to sanction for power supply to reduction of contract demand from 400 KVA to 35 KVA (Reduction load of 365 KVA) to existing installation bearing RR No. VNHTP-53 in favour of M/s Larsen & Toubro Ltd at Sy No.39, 40/1, Gollahalli Village, Jala Hobli, Bangalore North Talluk in Sadahalli O&M of Vidyanagara Sub Division, under self execution.

Subject to below conditions:

1. Power supply will be arranged from F-12 Hardware Park feeder from 66/11 KV Budigere MUSS.

2. You are requested to pay the following charges by DD/Cash (above 10000/- only DD will be accepted) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM, VIDYANAGARA Sub-Division within 90 Days from the date of this intimation and furnish the payment certificate for taking further action in this matter

Payment Towards		Amount(Rs.)
5% Supervisory Charge		2,170
CGST 9% on 5% Supervisory Charge		195
SGST 9% on 5% Supervisory Charge		195
Total		2,560

^{*} It is proposed to release from 20/1 A CT's to 2.5/1A CT's.

3. To Submit payment certificate along with Self execution agreement on Rs. 200/- stamp paper regarding obtaining of necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.

4. The metering equipment to be installed should be conspicuously visible and at the main inference to the

premises preferably with an independent entrance.

6. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation

It is proposed to provide CT's with HT ETV Meter 1A class 0.2s accuracy with TOD feature 3CT's 3PTs metering cubicle.

7. a) You should execute an agreement in the prescribed form and shall be submitted to the Executive Engineer Ele. of concerned division along with payment certificate.

b) Produce necessary Licensee/permit /NOC objection Certificate, etc. issued by the competent authorities as required under statute.