

* Type of Premises Industry H.T. (1)
 Total No. of Points/ Motors 20000 VA
 Total connected load partial service
 Load connected on phase A out of 20000 VA

R. R. No. Painted or m
 Slip inserted in Meter CTR = 100/1A
 Book No. 10000
 Installation No. 5019497
 Date of servicing AS PM SEE/BR/EE(1)
 Service Tapping 9/1/24

Distribution Transformer:

Location IFFCO Self Service
 Voltage ratio 11.5V/433V
 Capacity Cg power industry
 Connected Load 20000 VA

Telephone Crossing m
 From pole No. m
 Next R. R. No. 1st
 Reading date

Meter:

Type and make LST
 Capacity 2400.6 A. 12
 Initial reading check meter
2400.6206

Service Line:

Conductor Cu/IA 3X 400 & m
 Cable WP/MIR/CTC vg flo
 Pipe New fedr

General:

Cowh = 0.352
 Meter sealed intact yes
 Meter terminal cover seal yes
 Cutout sealed yes
 Does Installation comply with wiring Rules? no
 Are any defects noticed? no
 Rotation of meter yes
 Checked O. K. ok
 Meter Card fixed ok

Earthing:

Aerial Fuse Rmiv 24m's OD
 Cutout & 2000.32
 Aerial Fuse 50m for m
 Cutout Channarapaty &
 Service Distance New fedr to
 Test ad n Hmity
 Phase to Earth Source from
 Neutral to Earth Hararav & Ag

Certified that the installation was tested and rated by me

PC Test Report 16/1/24 m 006
Enclod.

Consumers Signature

Contractor's/ Technical Asst. Signature

* State whether residence, Shop, Office, Hotel, Restaurant, Cinema Theatre, Hospital, Religious Educational, Factory (describe) Agricultural Pumping. Other pumping (describe) Cottage Industry (describe)

FOR OFFICE USE ONLY

Sanction No.....

Ledger Folio

Account No.....

W.O. No.....

Installation

Service No.....

CHECKED

Asst. Engineer

Asst. Executive Engineer

Sr. Asst./Asst. Accounts Officer



BANGALORE ELECTRICITY SUPPLY COMPANY LTD.,

Office of the Executive Engineer Elect.,
MT Division, BRAZ,
Bengaluru - 1. Ph: 22340226

No. EEMT / BRAZ / AEE / HTR-45-46 dt 16/04/2025

To,
The Asst. Executive Engineer Elec.,
Dhevanahalli O&M Sub-division
BECOM, Bengaluru

Acc Id - 5019497
CT - 2000 KVA
CTR - 100/1A
MC - 10000

Dated 16-04-2025

006

Subject : Pre Commission Test of HT/EHT Installation.

Ref. : Your Letter No. SEE/OPS/EE(O)/AEE(O)/F2/2025-26/282
dt: 11/04/2025

The Pre-commission test was conducted on the H.T. Metering Cubical on 16-04-2025 of the HT installation with the following details.

- Name & Address of the consumer: M/S Indian Farmers Fertiliser Co-operative Ltd (IFFCO) at Plot No: 75 Aerodrome 1/0 Phase-2 in Dhevanahalli Subdivision
- Contract Demand 2000 KVA 3.CT Ratio 100/1A
- Multiplication Constant 10000 [TEN THOUSAND ONLY]
- Sanctioned Tariff HT 2 (a)
- Equipment Details :

	CT	PT	Meter Details	H.T. Metering Cubical Details
Make	<u>KALPA</u>	<u>KALPAA</u>	Make <u>LT</u>	Make <u>CHARTER</u>
Class	<u>0.2S 16A/KA</u>	<u>0.2</u>	Sl. No. <u>24006412</u>	Sl. No. <u>CT/PT/16A/KA/2425</u>
Type	<u>INDOOR</u>	<u>INDOOR</u>	Year <u>2024</u>	
Burden	<u>25VA</u>	<u>25VA</u>	Type <u>NR300B34C4D3</u>	Moedm Details
Insulation Level	<u>15/38/95</u>	<u>15/38/95</u>	Volts <u>3X63.5V</u>	Make <u>N-50/5</u>
Ration connected	<u>100/1A</u>	<u>100/1 110V</u>	Amps. <u>1 AMP</u>	Model No.
Sl.No.	R <u>579657</u>	<u>319423</u>	Pulse/Unit <u>50 000</u>	Serial No. <u>N34W 705275</u>
	Y <u>579658</u>	<u>319428</u>	Class <u>0.2A</u>	
	B <u>579659</u>	<u>319431</u>	Dial Constant <u>1</u>	

check meter SL No: 24006206

7. Ration test : Tested Good / Bad Tested Good / Bad

8. Whether display parameters of ETV meter are as per BECSOM requirement : YES/NO

Basins Fixed :

No.	Particulars	Main Meter	Sub-Meter
1.	Main cover of Meter	BMI 92854 / SCE 54853	BMI 92853 / PCE 80624
2.	Terminal cover of Meter	BRA 2B 10400	BRA 2B 10803
3.	MD. Reset Knob	BRA 2B 10801	BRA 2B 10804
4.	Optical Port		
5.	T.T.B.	BRA 2B 10802	BRA 2B 10805
6.	Metering Cubical Door	BRA 2B 10806	
7.	Window		
8.	CT / PT Chamber	BRA 2B 10807	
9.	Cable Entry Chamber	BRA 2B 10808	
10.	Hologram	MT 106225	MT 106224

10. Transformer Details

- Make CCP Power & Industrial
- Voltage Class 1100 / 433V
- Transformer Capacity 7000 kVA
- Current (HT/LT in amps) 104.97 / 2666.7A
- Vector Group %Z DY 11 6.74%
- Sl. No. DT 7641 1A

11. Observations For Pre Commission test we have conducted I.R, Polarity & Ratio tests. All the errors are within permissible limits. Wiring is in order. Power supply may be arranged by observing other all BESCOM normal.

Praxanna
Consumer / Representative
Signature with Seal

Yours faithfully,

V. L. Ling
Asst. Executive Engineer Elec.
HT Rating Sub-Division Hofalkote
BRAZ, BESCOM, Bengaluru

Copy Submitted for kind Information to :

- Executive Engineer Elec., MT Division, BRAZ, BESCOM, Bengaluru
- Executive Engineer Elec., O & M Hofalkote Division, BESCOM, Bengaluru

Initial Reading of ETV Meter :	006	C.H
Cum. kWh (Import)	0.352	0.311
To D. C1-0.144		0.002
C2-0.124		0.118
C3-0.082		0.006
C4-0.000		0.123
Cum. kVAh (Lag)	0.164	0.172
Cum. kVAh (Lead)	0.024	0.021
Cum. kVAh	0.454	0.419
Date/Time	16/04/2025 10:55	10:56
Bill kwh (Import)	0.352	0.311
(Export)		
Bill kVAh	0.454	0.419
Present MD	0.000	0.000
Billing MD	0.000	0.000
Anomaly	000	000
MD Reset Count	15	15
Cum. Demand	0.294	0.245
Bill P.F.	-	-



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BRC/EE (O)/AEE(O)/F-2/2025-26/288-38

Encl: 01 File.

Email ID: sehra@bescom.co.in
Ph No. 080-28482437 / 94482 79007

To,
Executive Engineer (Ele),
C, O&M Division,
Hosakote.

Sir,

Sub: Approval for arranging partial HT power supply to an extent of 2000 kVA to HT installation, out of sanctioned load of 4000 kVA in favour of M/s Indian Farmers Fertilizer Co-operative Ltd (IFFCO) at plot No. 75, Hi-tech Defence and Aerospace park phase 2, KIADB Industrial area, Naganayakanahalli village in Devanahalli sub-division-Reg.

- Ref:**
1. Y.O Ltr No. EEE/HKTD/AEE(O)/AE-1/2025-26/152-153 Dated: 05.04.2025.
 2. T.O Ltr No. SEE/BRC/EE(O)/AEE(O)/F-2 & F-22/2025-26/119-20 Dated: 05.04.2025.
 3. CGM(OP) Ltr No. BC-18/CGM(OP)/DGM-OP2/M-OP//F-533/2025-26/498 Dated: 09.04.2025.
 4. CEBRAZ Ltr No. CEBRAZ/SEO/AEE-2/2025-26/127-128 Dated: 09.04.2025.

With reference to the above subject, as per the Corporate office approval vide ref (3) & Chief Engineer Electy, BRAZ, approval vide ref-(4), an approval is hereby accorded for arranging partial HT power supply to an extent of 2000 KVA to HT installation, out of sanctioned load of 4000 kVA in favour of M/s Indian Farmers Fertilizer Co-operative Ltd (IFFCO) at plot No. 75, Hi-tech Defence and Aerospace park phase 2, KIADB Industrial area, Naganayakanahalli village in Devanahalli sub-division, subject to the condition that, to obtain a revised requisitioned load from the applicant in order to execute the power supply agreement as per the revised approved load.

Hence, it is instructed to take further action duly observing prevailing BESCOM norms.

Yours faithfully,


(Basavanna.C)
Superintending Engineer (Ele),
BRC, BESCOM, Bangalore.

AEE(DH)
for next final action
[Signature]

Office of the
Superintending Engineer (Ele),
(C, O&M), B'lore Rural Circle,
BESCOM, KSSCL, Beeja
Bhavan, 5th floor, Bellary Road,
Hebbal, Bangalore -560024.

Date: 09 APR 2025

11/4/25
345

Approved
[Signature]