



- 3 Quality of materials used in the field should be ISI marked and bound standards (Application shall enclose the documents for having purchased.)
- 4 The work shall be carried out by the applicant at their own cost through class-1 L.E.C as per.
 - a. The estimate prepared by the company under the supervision of the company.
- 5 **Guarantee shall be furnished by the applicant for the period of 5 year for Transformers and cables and one year for all other materials.**
 - a. Materials used in the work from the date of availing power supply the transformer used shall be of a reputed company make approved by the corporate. **For Self Execution works only BEE-4 Star Rated Transformer have to be provided by the applicant.**
- 6 The materials purchased should be from the approved firms, by the company.
 - a. **he Materials and the work should be got inspected by the field officers and the inspection report shall be submitted as per circular No: BC-9/F-653/2012-2013 dated 15.05.2012.**
- 7 Electrical Inspectorate approval for the works shall be obtained from the competent authority at your own cost.
- 8 Joint inventory of materials used shall be taken in the prescribed format after completion of work.
- 9 It is also requested to pay all the other charges that would be incurred during temporary supply and while obtaining permanent service to this installation.
- 10 You are requested to contact the undersigned in case of any other information that may be required by you.
- 11 **Pay D2 and other fees at Huliurdurga sub-divisional office.**
- 12 You are requested to give undertaking to replace 0.5 class meter by 0.2 class meter and other metering accessories whenever it is available in the market at your cost.
- 13 **This Power Sanction stands automatically cancelled, if the documents provided by yourself found to be fake at later stage or on expiry of validity of any statutory Approval. If pollution control board is not submitted before service the power sanction is deemed to be cancelled and consumer himself is held responsible.**
- 14 The Transformer shall be placed at safe place. The place near the TC should be cleared to maintain safety.
- 15 Any dispute arises at the place of line work has to be solved by the applicant and complete the work. Any site problem in future has to be solved by the consumer.
- 16 This Power Supply intimation is given for the IP installation 500mtr away from lift irrigation & water Channal

You are requested to contact the undersigned in case of any other information that may be required by you we remain at your services.

Yours faithfully


Executive Engineer (Ele.)
C, O&M division, BESCOM
 Kunigal.

Copy:-

1) AE(T)/ O/C

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED.**

Office of the Executive Engineer (Ele), O&M Division, BESCOM Kunigal-572 130

☎: 08132-220018 ✉ : eekunigal@bescom.co.in

No: EE(Ele)/AEE(O)/AE(T)/KGL/2025-26/

280

Date: -

15 MAY 2025

REVISED INTIMATION

To,
Sir/Smt Ugraiah
S/O Late Karatigowda
Halagere Village,
Huliyurdurga Hobli,
Kunigal Taluk,
Sy.No/Katha No:- 179/68.

Sir,

Sub:- Intimation for AP/S to 10HP IP set under LT4a Tariff by providing 25kVA Transformer in favour of Sri/Smt Ugraiah S/O Late Karatigowda @ Halagere Village, Sy No/Katha No:- 179/68, in Yadavani Section, Huliyurdurga Sub Division, Kunigal Division.(Under Self Execution Scheme).

- Ref: 1)AEE(Ele)/AE(T)/BESCOM/Huliyurdurga/2024-25/25, Dated:-11.04.2025.
2)Estimation No:-HS-01, Date:-01.04.2025.(Estimate Cost:-199653/-)
3) Application ID:-2243104250008, Dated:-07.04.2025.
4) BESCOM/CGM/(Op)/DGM(Op-1)/AGM/2023-24/CYS-193, Dtd:12.10.2023
5) ELECTRICITY TARIFF - 2025 K.E.R.C. ORDER DATED: 27.03.2025
6) BESCOM/CGM/(Op)/DGM(Op-1/AGM-3(Op-1)/FY2021-22/CYS-19, Dtd:17.05.2021
7) GM(QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-124. Dated:18.11.2023
8) BESCOM/BC-49/GM(CT&GST)/DGM/AGM/(CT&GST)/F-3/2024-25/CYS-48, Dated:26.11.2024
9) ಬೆವಿಕಂ/ಮುಪ್ರವ್ಯ(ಯೋ)/ಉಪ್ರವ್ಯ-1/ಸಪ್ರವ್ಯ/2025-26/CYS-06, ದಿನಾಂಕ:-24.04.2025

With Respect to the above subject & Ref(1)&(2), I wish to inform you to pay Intimation for AP/S to 10HP IP set under LT4a Tariff by providing 25kVA Transformer in favour of Sri/Smt Ugraiah S/O Late Karatigowda @ Halagere Village, Sy No/Katha No:-179/68, in Yadavani Section, Huliyurdurga Sub Division, Kunigal Division.(Under Self Execution Scheme).

The Power sanctioned subject to following conditions:

Sl.No	Particulars	Amount	Payable at
1	Initial Security Deposit from consumers (48.101)	₹ 16,600.00	O/o The Assistant Executive Engineer(Ele.), Yadavani O&M Huliyurdurga Sub-Division, BESCOM.
2	Meter Security Cost(47.603)	₹ 2,808.00	
3	TP Box	₹ 4,300.00	
4	SC Charges	₹ 250.00	
5	Transformer Testing charges under the Account Head 62.930	₹ 1,000.00	
TOTAL Amount		₹ 24,958.00	

- Intimation is valid for 90 days from this date.
- The Electrical inspectorate charges are paid by the consumers and approved by the competent authorities.

Conditions for self-execution:-

- All the materials to be used in self execution works especially switchgear cables, cable jointing accessories, transformers, poles, GOS, DOL and 11 kV pin/disc insulators etc. shall be of BESCOM approved makes only and got inspected through QS&S, BESCOM.
- All the papers required to be submitted to Electrical Inspectorate office shall be routed Sub-divisional Engineers only.

P.T.O....