



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)
No. EEMT/AEE(O)/BRAZ/AEE HTR/

To,
The Asst. Executive Engineer (Ele),
Gowindam & M Sub-Division,
BESCOM.

GRHT-50.

CD = 280 KVA

CTR = 15/1 A

MC = 1500

Office of the
Executive Engineer (Ele),
MT Division, BRAZ, BESCOM,
3rd Floor, Crescent towers,
Bangalore-560001.

Sir,

Date: 6/8/25

Subject: Rating Report of HT/EHT Installation.
The H.T. Installation having the following details has been rated for periodical rating/complaint on..... You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

R.R.NO. GRHT-50 CD 280 KVA CTR 15/1 A A Meter Constant 1500
Activity Granite Tariff 12.67
Name & Address of the Consumer C.N. Rocks, Plot 73 KIADB
Kudumalakunte, eBDR.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

Meter calibrated 1.0% of Error found with in the permissible limits.

3. ADVICE ON REVENUE MATTER:

Wrong Applicability of constant. Actual constant 1500
but constant billed in bill 1000. Since from
1/8/25 at the time of FR. PSE. 2.6 kWh. Hence

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO. action to be taken as per KEPC Summary of analysis if rated against complaint.

NORMS. BBCZ (P.T.O)

ANNEXURE

1. DETAILS OF SEALS:

R.R. No. GRHT-50

SL.N O.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter	BME 21934	Retain		
2	TC Of Meter	BRA2D 75937	Retain		
3	M.D. Reset Knob	BRA2D 05365	Retain		
4	Optical Port				
5	T.T.B	BRA2D 75938	BRA2D 80251		
6	Meter Chamber Main Door	BRA2D 75939	BRA2D 80252		
7	Meter Reading Window				
8	C.T./P.T. Chamber	BRA2D 85841	BRA2D 80253		
9	Cable Entry Chamber	BRA 2 66618	Retain		
10	Hologram	MT 098361	Retain		

2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make (Venkat Switch gears.)
b) Cubicle Conditions & Location. eBDR needs to be cleared.

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11kV / \sqrt{3} \times 15/1 \times 1}{1 \times 1} = 1500$$

4. DETAILS OF Ct's/ Pt's: