



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G125

AEE/MALUR/ (AET)

Office of the  
Assistant Executive Engineer Ele.,  
C,O&M, MALUR Sub Division  
BESCOM, MALUR

To  
M/S SWMVARDHANA PROPERTIES  
PROP MOHAN REDDY,

Sir/Madam

**Sub :** Arranging power supply to an extent of 6.00 KW in favor of M/S SWMVARDHANA PROPERTIES PROP MOHAN REDDY, in MALUR OMU, MALUR

**Ref:** 1) Your application registration 1243102260015 dated 05-FEB-2026

2) AEE/MALUR /AE(T) a/ 20-FEB-2026

With reference to your application dated 05-FEB-2026 . Requesting for arranging power supply to an extent of 6.00 KW power installations in favor of M/S SWMVARDHANA PROPERTIES PROP MOHAN REDDY, in MALUR OMU, MALUR Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M MALUR sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1243102260015	12431022600150001	LT7-TEMPORARY - LT7	6.00 KW	47.3017-ACC	50300
1243102260015	12431022600150001	LT7-TEMPORARY - LT7	6.00 KW	61.9067-61.9067 - MATERIAL INSPECTION CHARGE	5000
1243102260015	12431022600150001	LT7-TEMPORARY - LT7	6.00 KW	61.9047-5% Supervisory Charges (61.904)	21731
Total Amount in Rupees					77031

- The power supply will be arranged at 400V .
- The Tariff applicable to your installation will be LT7, or the Tariff in force From time to time.
- You have to enter into an agreement with the BESCOM in the prescribed form.
- Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- Amount through DD should be paid in the name AEE BESCOM MALUR .
- Intimation is valid up to 30 days from the date of issue.

Assistant Engineer (E) Tech  
C, O&M Sub-Division, BESCOM  
Malur - 563130

You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.

Sl No	Description	Qty	Rate	GST (%)	Amount
1	LT AC 3 Phase 4 Wire, 10-60 Amps Smart Energy Meter, Class 1.0 Accuracy with Communication Module without Box	1	7203.3900	18 %	8500.00
2	Polycarbonate Box for Three Phase Whole Current Smart Energy Meter	1	322.0300	18 %	380.00

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., MALUR Sub division, BESCOM for information and further needful.