

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ಕಾರ್ಯ ಮತ್ತು ಪಾಲನೆ ವಿಭಾಗ, ಚಂದಾಪುರ,
ಬಿ.ವಿ.ಕಂ, ಬೆಂಗಳೂರು-560081
ದೂರವಾಣಿ: 9448279027



BANGALORE ELECTRICITY SUPPLY COMPANY
(A Government of Karnataka Undertaking)
O&M Division, CHANDAPURA
BESCOM, Bangalore-560081
E-Mail: eechndpr.work@gmail.com

P-78
167

NO : EE(E)/CDP/AEE(O)/JET-2 /2025-26 / 1119H-95

Date: 16 JAN 2026

To,

Smt. Chitra G,
D/o Gopal Reddy,
Sy. No. 442, No. 69/69,
Jigani Village,
Anekal taluk.
Mob No-9845272428

Power Sanction Letter by
Temporary LT to HT
installation

Sir,

Sub:- Intimation for Arranging HT temporary power supply to an extent **200 KVA to the HT temporary installation** in favour of **Smt. Chitra G D/o Gopal Reddy at Sy. No. 442, No. 69/69, Jigani Village, Jigani Hobli, Jigani**

KIADB O&M, Jigani Sub-Division, Anekal Taluk Bengaluru reg.

Ref:- 1. Your Application No: 1324111250062 / 18.11.2025
2. AEE, Jigani SD Office Letter Ref No : 7179 / 30.12.2025

*** **

With reference to the above subject, as per the recommendation of the Assistant Executive Engineer (Ele), **Jigani** Sub-division vide ref-(2), power sanction is hereby accorded for Arranging HT temporary power supply to an extent **200 KVA to the HT temporary installation** in favour of **Smt. Chitra G D/o Gopal Reddy at Sy. No. 442, No. 69/69, Jigani Village, Jigani Hobli, Jigani KIADB O&M, Jigani Sub-Division, Anekal Taluk under Self Execution**, subject to the following conditions and observance of KERC / BESCOM norms in force.

The proposed for arranging power supply is as follow:

Regular source:

Station: 66/11 KV Jigani MUSS which has a peak load of 38.7 MW with installed capacity of power transformers 3*20 MVA.

Feeder: Existing F-3 Charbuja feeder which has a peak load of 48 Amps with 3x400 Sq.mm XLPE HT UG cable/Coyote/Rabbit.

The following works are proposed under self-execution.

BESCOM portion.

- It is proposed to tap the existing 11 KV line by providing 11 Mtrs Spun Pole with 200 Amps GOS and to extend the line to a distance of 100 Mtrs (2 Runs) by using 3*95 Sq. mm HT UG cable.
- It is proposed to provide HT metering cubicle at applicant premises.

Alternate source:

Not proposed

The total cost of the estimate is Rs. 7,25,512/- (Total Seven lakh Twenty five thousand five hundred and Twelve only)

The pre commission test shall be done for the new HT metering cubicle in presence of the Executive Engineer Ele., MT division, BRAZ after installation.

You have to pay the following amount in the form of DD in favour of **AEE, BESCOM, Jigani sub-division within "90 days** from the date of this power sanction".

- a) **Rs.36,276/- (Total Rupees Thirty Six thousand two hundred and Seventy six only)** towards Supervision charges@ 5% of estimate cost of **Rs.7,25,512/-**
- b) **Rs. 4,080 /-(Total Rupees Four thousand and Eighty only)** towards HT metering cubicle testing charges.
- c) **Rs.91,200/- (Total Ninety one thousand and two hundred only)** towards demand charges under HT-5.
- d) **Rs. 14,28,000/- (Total fourteen Lakhs Twenty eight thousand only)** towards ACC under HT-5.

1. The appropriate tariff shall be applicable as per prevailing KERC tariff order 2025 for BESCOM.
2. Power supply shall be arranged on **HT-5 basis**.
3. In future, if the total load requirement exceeds 7500 kVA then the applicant/developer shall establish 66/11 KV substation at their own cost in the above premises under self-execution and avail power supply on 66 KV EHT basis as per KERC regulations.
4. The Power supply shall be arranged duly observing all corporate norms.
5. **11 KV** system shall be as per KPTCL/ BESCOM standard practices.
6. The applicant shall execute the works under self-execution through Karnataka State government approved Class-1 Electrical Contractor in co-ordination and under the guidance of KPTCL/BESCOM officials.
7. The entire Distribution system with connected equipment's shall be taken over by KPTCL/ BESCOM after completion of the works.
8. All the major materials like Transformer, ACSR conductor, Metering cubicle, HT UG cable, LT UG cable, 11 kV Pin insulators and 11 kV single / double break GOS shall be procured by the agencies only from the BESCOM approved vendors and other materials may be procured from authorized dealers of approved vendors to BESCOM. You have to utilize only Polymer insulators as per corporate circular vide Lr no. BESCOM/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/CYS-113 dt 29-8-13.
9. The materials procured shall be in-accordance with the IE/BESCOM/KPTCL specifications and the materials shall be got inspected by **Jurisdictional Assistant Executive Engineer Ele / Assistant Engineer Ele**, before procurement. The copies of the invoices / bills of the materials purchased shall be submitted as a proof of purchased from the approved vendors / dealers.

10. You shall submit the copies of the invoices / bills in respect of materials purchased by you for proof of having purchased the materials from the approved vendors / dealers.
11. Guarantee shall be furnished for a period of not less than "one year" for the materials used for the works as well as for the quality of work carried out from the date of taking over the lines and equipment's by BESCO/ KPTCL.
12. Proof of having purchased the materials and used for execution of works from the reputed firm shall be verified wherever necessary.
13. You have to obtain the necessary approval from the concerned authorities like Electrical Inspectorate for new HT / LT lines / DTCs , Forest clearance, statutory clearances, National Highway, PWD etc., others, if any, whichever applicable and has to submit it before servicing.
14. The BESCO / KPTCL is not responsible in whatsoever manner regarding any of legal disputes that may arise at a later stage.
15. After payment of above charges and fulfillment of the conditions, the administrative approval shall be issued from this office.
16. The procedure in the circular issued by the corporate office vide No. CGM(O)/DGM(O)-3/AGM-1/ BC-07/F-383/19-20/CYS-64 dated 20-09-2019 shall be followed.
17. Any EHT and HT / LT lines passing through the layout, safety clearance shall be maintained (statutory) or shifting of existing lines shall be done at your own cost only.
18. The materials released (as shown in credit Estimate as per the 7th Schedule) shall be returned to the concerned BESCO stores.
19. Any delay in making payment, not fulfilling the above conditions within 90 days, the power sanction/Application deemed to have been cancelled as per the conditions stipulated in the KERC Amendment vide clause No. 4.03 (ii). **The registration cum processing fee paid shall stand forfeited.**
20. You should clear the out-standing arrears, if any, in respect of the existing installations.
21. You have to provide additional infrastructure required as and when there is increase in load by the individuals in the premises.
22. You shall submit the indemnity bond if the applicant is not the owner of the premises.
23. You should abide by the conditions of supply of electricity 2004 is in force with subsequent amendments.
24. In case, applicant fails to meet the above conditions to arrange power supply, the power sanction is deemed to have been cancelled.
25. You have to pay any variation / difference of charges, if any, payable to BESCO/ KPTCL if any in future as per subsequent amendments of KERC.
26. You shall abide by the prevailing Regulations and changes from time to time.

27. The concerned BESCOM field officers shall follow the instructions issued by the corporate office vide circular for obtaining occupancy certificate vide Lr no. CGM(OP)/DGM-3/BC-05/F-341/25-26/CYS-02 dtd 04-04-2025 before servicing of the installation.

The above amount shall be paid within 90 days from the date of power sanction at Jigani sub-division, failing which this power sanction shall be deemed to have been cancelled.

For any further clarifications, you may contact the Assistant Executive Engineer, O&M Sub-Division, Jigani.

Note: For any 765/400/220/66/11 KV lines passing adjacent/nearby/on the premises, mandatory clearance certificate should be obtained from the competent authority by the developer / concerned EE of BESCOM before servicing of the installation. In case of any deviation in this regard concerned officers will be held responsible.

Yours faithfully,


**Executive Engineer(Ele),
C, O&M Chandapura Division,
BESCOM.**