



Bangalore Electricity Supply Company Ltd.

Page 1 of 3
Format F-09-14

HT Rating Report

No. EE MT/AEE(O)/BRAZ/AEE HTR/

To
The Asst. Executive Engineer (Ele.),
O&M Sub-Division
BESCOM, Dalmahalli Halli

DYMT 400
Add. Annual load 10156
Existing - 200 BVA
Addl - 300 BVA
Total - 500 BVA
CT R - 25/1A MC - 2500

Office of the
Executive Engineer (Ele.),
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

Date 08/10/2025

Subject : Rating Report of HT/ EHT Installation

The HT Installation having the following details has been rated for periodical rating / complaint on 08/10/2025
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

R.R. No. DYMT 400 CD 500 KVA. Previously rated on 19/02/2025
Name & Address of the Consumer M/s Auto cat Engineers - GARALA KRISHNA
Dalmahalli Sub division BESCOM. No: 263 & 264 Polamhalli village

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

As per your letter reference No: AEE / DML / AEE /
25-26/2359 dt: 23/09/2025 Additional load Sanctioned
3. ADVICE ON REVENUE MATTER : from 200 BVA to 500 BVA - Hence the
existing 10/1A CT's replaced by 25/1A CT's &
calibrated the meter before & after replacement
& CT's error are within permissible limit.

DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint Meter data downloaded &
analysed recording found correct.

Yours faithfully,

Asst. Executive Engineer (Ele.),

HT Rating Sub Division, Halkote.
BRAZ, BESCOM, Bangalore.

Copy for kind information to :

The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

Executive Engineer Ele, O&M Halkote

case of discrepancies :

Chief Engineer Ele., BRAZ, B'lore.

Superintendent of Police, Vigilance

Accounts Officer, Internal Audit.