



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/VIDYANAGAR/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, VIDYANAGAR Sub Division
BESCOM , VIDYANAGAR

To
RAGHAVENDRA B S
S/O SAHADEVARAO B K K.NO.39/48, NELLUKUNTE VILLAGE562157

Sir/Madam

Sub : Arranging power supply to an extent of **8.00 KW** in favor of RAGHAVENDRA B S S/O SAHADEVARAO B K K.NO.39/48, NELLUKUNTE VILLAGE562157 in VIDYANAGAR OMU, VIDYANAGAR

Ref : 1) Your application registration **61126109250060** dated **20-SEP-2025**

2) AEE/VIDYANAGAR /AE(T) a/ **20-SEP-2025**

With reference to your application dated **20-SEP-2025** . Requesting for arranging power supply to an extent of **8.00 KW** power installations in favor of RAGHAVENDRA B S S/O SAHADEVARAO B K K.NO.39/48, NELLUKUNTE VILLAGE562157 in VIDYANAGAR OMU,VIDYANAGAR Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M VIDYANAGAR sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61126109250060	5577510	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	8.00 KW	55.1067-55.1067 - SERVICE LINE CHARGES	3900
61126109250060	5577510	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	8.00 KW	48.1017-48.1017 - ISD	9600
61126109250060	5577510	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	8.00 KW	48.1037-48.1037 - ASD	1900
Total Amount in Rupees					15400

- b. The power supply will be arranged at 0V .
- c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM VIDYANAGAR .
- i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED.You are requested to contact the Asst. Ex. Engineer Ele., VIDYANAGAR Sub division, BESCOM for information and further needful.

Your's Faithfully,

Assistant Engineer (Technical),
VIDYANAGAR, BESCOM

Your's Faithfully,

Assistant Executive Engineer Ele.,
VIDYANAGAR, BESCOM

Copy to:

- 1.The Executive Engineer Ele. C, O&M HOSAKOTE Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M VIDYANAGAR Sub division, BESCOM.