



Bangalore Electricity Supply Company Ltd.

No. AEEE / HTR / CHTPH 18533

To,
The Asst. Executive Engineer (Ele)
..... O&M Sub-Division
BESCOM

Office of the
Asst. Executive Engineer (Ele),
..... H.T. Rating Sub-Division,
BRAZ BESCOM

Date: 23/07/2025

Sir,

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 23/07/2025.
You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

Previously rated on 09/02/2020

R.R. No. CHTPH 18533 CD 150 KVA CTR 7.5/1 A Meter Constant 750

Activity: Construction

Name & Address of the Consumer: M/s. Arat A One World Pvt. Ltd. at 82/1, 82/2, 83/3, 84/3, 84/5, 86/2, near Sacha Industrial Area in Hebbagodi Old unit of Chanda Pura Sub division.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

As per your reference letter no: AEE / CDP / AEM / 2025-26 / 2714 dt: 22/07/2025 Reduction of load sanctioned from 300 kva to 150 kva. Hence the existing 15/11 is

3. ADVICE ON REVENUE MATTER : replaced by 7.5/1 & calibrated the meter before & after replacement of CT. All the errors are well in the permissible limit.

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis if rated against complaint: meter was down loaded & analysed according load correct.

Yours faithfully,

Asst. Executive Engineer (Ele)

..... H.T. Rating Sub-Dvn, BRAZ

Copy for kind information to:

1. The Executive Engineer Ele., MT Division, BRAZ, Bengaluru.
2. Executive Engineer Ele., O & M Division, BESCOM,

In case of discrepancies :

3. Chief Engineer Ele., BRAZ, Bengaluru.
4. Superintendent of Police, Vigilance
5. Accounts Officer, Internal Audit.



1. DETAILS OF SEALS :

ANNEXURE

Page 2 of 3
Format F-09-14

R.R. No. CHT PH 18533

Sl. No.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1.	M.C. of Meter	<u>BMT 63761</u>	<u>SCS33275</u>	<u>BR02B</u>	
2.	TC of Meter	<u>BR02B02453</u>			
3.	M.D. Reset Knob	<u>BR02B02454</u>		<u>BR02B 15162</u>	
4.	Optical Port				
5.	T.T.B.	<u>BR02B 02455</u>		<u>BR02B 15163</u>	
6.	Meter Chamber Main Door	<u>BR02B02456</u>		<u>BR02B 15164</u>	
7.	Meter Reading Window				
8.	C.T. / P.T. Chamber	<u>BR02B 02457</u>		<u>BR02B 15165</u>	
9.	Cable Entry Chamber	<u>BR02B 02458</u>		<u>BR02B 15166</u>	
10.	Hologram				
11.	Others				

2. DETAILS OF THE EQUIPMENTS :

- Cubicle Type : Cable Entry / 6 bushing / 3 bushing / LBS. Make Benavati Sl. No. 24059
- Cubicle Conditions & Location Good out door yard
- Supply side G.O.S. : In Service / Direct / Removed.
- Lightning Arrestor - Provide / Not Provided

3. DETAILS OF Cts / Pts :

	Existing	After Replacement	Existing	After Replacement
1. Make	<u>KALPA</u>	<u>KALPA</u>	<u>KALPA</u>	
2. Type	<u>INDUOR</u>	<u>INDUOR</u>	<u>INDUOR</u>	
3. Class	<u>0.25</u>	<u>0.25</u>	<u>0.25</u>	
4. Insulation level	<u>15/38/45</u>	<u>15/38/45</u>	<u>15/38/45</u>	
5. Burden	<u>25VA</u>	<u>25VA</u>	<u>25VA</u>	
6. Ratio Connected	<u>15/1A</u>	<u>15/1A</u>	<u>15/1A</u>	
7. Sl.No. 1. R	<u>307389</u>	R <u>3663</u>	R <u>319439</u>	R
2. Y	<u>307390</u>	Y <u>3664</u>	Y <u>319455</u>	Y
3. B	<u>307391</u>	B <u>3665</u>	B <u>319442</u>	B

4. DETAILS OF METERS :

ETV Meter

	Existing	After Replacement
a. Make	<u>L.T.</u>	
b. Type	<u>Wk 30042 11KAL21</u>	
c. Class	<u>0.25</u>	
d. Voltage	<u>3x 635V</u>	
e. Ampere	<u>1AMP</u>	
f. Pulse / Unit	<u>50000</u>	
g. Dial Constant	<u>1</u>	
h. Sl. No.	<u>24011088</u>	



5. MULTIPLYING CONSTANT FOR BILLING (Kwh. Kvah. Kva) :

Page 3 of 3
Format F-09-14

PT Ratio x CT Ratio x Dial Constant
Meter PT Ratio x Meter CT Ratio

= 750 (Seven Hundred fifty only)

5. A. CALIBRATION DETAILS :

- Voltage V_1, V_2, V_3
- Current I_1, I_2, I_3
- P.F. / K W
- Sequence

CALIBRATOR

METER

631, 636, 636
0.064, 0.062, 0.063
0.330 / 0.0081
Reason &
KVAH /

631, 636, 636
0.064, 0.062, 0.063
0.330 / 0.0081
Reason ?
KVAH

B. CALIBRATION DATE :

- Reading of Test Meter
- Reading of Reference Meter
- Percent Error

0.064 %

7. METER READINGS :

A. Cumulative Parameters

- Time Date, Month, Year
- Demand with elapsed time
- Self diagnostic condition
- Present KVA. PF
- Cumulative KWH

Existing

After Replacement

16.16, 23/05/2025

0.0114, 0.330
43.040

I.R for k- 15004
I.R for k- 750

2.
3.
4.

TOD 1.
2.
3.
4.

B. BILLING PARAMETERS :

- Billing KWH

IR for k- 15004
IR for k- 750

TOD 1. 43.040
2.
3.
4.

TOD 1.
2.
3.
4.

- Billing KVA

0.0468
TOD 1.
2.
3.
4.

TOD 1.
2.
3.
4.

- Billing PF (Universal TOD)

0.752
TOD 1.
2.
3.
4.

TOD 1.
2.
3.
4.

- MD Reset Count

- MD Reset Manual / Automatic On

14
Name Roll

8. CONSUMER EQUIPMENT DETAILS

- Transformer Make
- Capacity
- Vector Group

- Voltage Class
- Current
- SL No.

Consumer's Representative's Signature
with Seal

Asst. Executive Engineer (Ele)

H.T. Rating Sub-Division

