



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/MALUR (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, MALUR Sub Division
BESCOM, MALUR

To
VIJAYA KILARI CONSTRUCTIONS
H HOSAKOTE VILLAGE,

Sir/Madam

Sub : Arranging power supply to an extent of **20.00 KW** in favor of VIJAYA KILARI CONSTRUCTIONS H HOSAKOTE VILLAGE, in MALUR OMU, MALUR

Ref : 1) Your application registration **1243102260279** dated **18-FEB-2026**

2) AEE/MALUR /AE(T) a/ **21-FEB-2026**

With reference to your application dated **18-FEB-2026**. Requesting for arranging power supply to an extent of **20.00 KW** power installations in favor of VIJAYA KILARI CONSTRUCTIONS H HOSAKOTE VILLAGE, in MALUR OMU, MALUR Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M MALUR sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1243102260279	12431022602790001	LT7-TEMPORARY - LT7	20.00 KW	61.9067-61.9067 - MATERIAL INSPECTION CHARGE	5000
1243102260279	12431022602790001	LT7-TEMPORARY - LT7	20.00 KW	61.9047-5% Supervisory Charges (61.904)	17805
1243102260279	12431022602790001	LT7-TEMPORARY - LT7	20.00 KW	47.3017-ACC	167600
Total Amount in Rupees					190405

- b. The power supply will be arranged at 400V .
- c. The Tariff applicable to your installation will be LT7, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM MALUR .
- i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FORFEITED. You are requested to contact the Asst. Ex. Engineer Ele., MALUR Sub division, BESCOM for information and further needful.

Your's Faithfully,


Assistant Engineer (Technical),
MALUR, BESCOM

Your's Faithfully,

Assistant Executive Engineer Ele.,
MALUR, BESCOM



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No.EE(E)/AEE(O)/JE-3/KGF/2024-25/ 11302-03.	 ಸ್ವಾತಂತ್ರ್ಯ ಅಮೃತಮಹೋತ್ಸವ	Office of the Executive Engineer (Elec.), C, O & M Division, Champion Reefs, K.G.F - 563117, Date: 21-2-26
--	---	---

To,
M/S Vijay Kilari Constrtuction
Prop: Kilari Raghunath Babu
H Hoskote Gate Hosur Road,
Malur.

ID :1243102260279

Tariff- LT-7 Temporary , 20KW

Sir,

Sub : Power sanction to to Temporary Power Supply LT-7 installation to a M/S Vijay Kilar Construction Prop: Kilari Raghunath babu in Hoskote Gate Hosur Road Malur Taluk in O&M-1 Section of Malur Sub-division.

Ref : AEE(E), Malur S/D vide Ltr No: AEE(E)/AE(T)/MLR/4547/2025-26, Dtd: 19.02.2026.

With reference to your application, APS to **20KW** Floor Mill work Unit is sanctioned subjected to following conditions.

1. You have to pay the following amount at O&M **Malur** Sub-Division, BESCOM within period of **90** days from the date of this letter. Failing which the sanction stands cancelled.
2. You have to execute the extension of line and other erection work under Self Execution by paying Supervision Charges. Before starting the work the materials are to be inspected by the under signed.
3. You have to give guarantee for the material used as well as the quality of the work executed at least for a period of one year from the date of service.
4. The purchased material is should be as per BESCOM Specification and shall confirm to ISI. The materials procured from approved vendor for this work shall be got inspected by QS&S section before they are used in the field. As per Circular No: BESCOM/GM(QS&S)/DGM-3/BC-11/F-1425/13-13/CYS-125/ Dated: 19.02.2014.
5. Pay **Supervision Charges** of **Rs.17,805/-** (Rs. Seventeen Thousand eight hundred and Five only)
6. Please pay **Material inspection Charges** of **Rs. 5,000/-** (Rs. Five Thousand rupees only)
7. Please pay **ACC** of **Rs.1,75,555/-**(Rs. One Lakh Seventy five thousand Five hundred and fifty five only.
8. The consumer should submit the copies of invoice/bills in respect of materials purchased by the dealers.
9. There should not be marking of BESCOM P.O. No. on the poles in future.

ABSTRACT:-

