



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED


(Wholly owned Government of Karnataka Undertaking)

No:-AEE/AAO/DBP/25-26/ 4223

Office of the,
Asst Executive Engineer(Ele)
Com,O&M Urban Sub division,
BESCOM,Doddaballapura
Email:-bescomdbp@yahoo.com

To,
The Executive Engineer(Ele).,
C, O&M Division,BESCOM,
Nelamangala.

ದರಾಫ್ತು: 02/9/25



Sir,
Sub:-Payment Certificate.
Ref:- Your office Letter No:7344-45 date:30-03-2025.

For arranging additional power supply to an extent of 84HP to the LT-5(0) power Installation bearing RR No DUP-14558(Exi 66HP+Add 84HP=total 150HP)in favour of M/s Origama cellulo Pvt Ltd,Plot No S7,KIADB Industrial area,Apparel park,Kasaba Hobli,Doddaballapura Taluk,Bashettihalli Section of doddaballapura Urban Sub Division.

Under Self Execution

The Consumer paid the following deposits.

- 5% SC on Estimate Cost Rs:104669/-paid vide Rt No:1114101010202 Dt :02.09.2025. ✓
 - I S D Rs:47070/-paid vide Rt No:1114101010201 Dt 02-09-2025 ✓
 - Transformer Testing Fee of Rs:1000/-paid vide Rt No:1114101010203 Dt:02-09-2025 ✓
- (Including GST if applicable)

Govinde Rao K.R.
General Cashier

AAO/SA

Your's faithfully,

Assistant Executive Engineer(Ele)
C,O&M Urban Subdivision,BESCOM
Doddaballapura

107
10/9/25

A.E.E. IO
A.O.
A.A.O.I
A.A.O.II
H.C.

E.E



Bangalore Electricity Supply Company Limited

(Wholly Owned by Govt. of Karnataka Undertaking)

Office of the Executive Engineer (Ele), C.O&M Division, BESCO, Nelamangala
Estimate for Arranging additional power supply to an extent of **84HP** to the **LT-5(a)** Power Installation bearing RRNO **DUP-14558** (Exi 66HP + Add 84HP = Total 150HP) in favour of M/s Origami Cellulo Pvt Ltd, Plot No S7, KIADB Industrial Area, Apparel Park, Kasaba Hobli, Doddaballapura Taluk, Bashettyhalli Section, Doddaballapura Urban Sub Division. **Under self Execution.**

CERTIFICATE

Certificate To No: **EEE/NEL/AEE(O)/AET/2025-26/7825-26** Date: **16/9/25**
This Estimate is Sanctioned for Arranging additional power supply to an extent of **84HP** to the **LT-5(a)** Power Installation bearing RRNO **DUP-14558** (Exi 66HP + Add 84HP = Total 150HP) in favour of M/s Origami Cellulo Pvt Ltd, Plot No S7, KIADB Industrial Area, Apparel Park, Kasaba Hobli, Doddaballapura Taluk, Bashettyhalli Section, Doddaballapura Urban Sub Division. **Under self execution. 05% of Supervision charges of Rs:- 88,703/- (Rs:- Eighty Eight Thousand Seven Hundred & Three Rupees Only) vide Rt.NO.1114101010202/02.09.2025. of the total estimated cost of Rs. 17,74,060/- (Rs. Seventeen Lakh Seventy Four Thousand & Sixty Only).**
No Work order is assigned under any Head of Account of the Corporation to this work. This Certificate itself is treated as Sanction. After Completion of work Joint inventory as prescribed vide Chief controller of Accounts circular NO. AO\Sn. 4\Cys- 10 /92-93 dated 20.4.1992 (page 246 of Compendium Vol-1) will be taken and asset accounted in the books of Company.

- NOTE:**
- All the materials used should be got inspected by Q&S/BESCO instructed by executive Engineer (Ele.) Nelamangala before commencement of work.
 - The Concerned Assistance Executive Engineer(Ele), is instructed to take futher action duly observing the conditions stipulated as per this office approval /KERC Rules/BESCO norms.
 - The Work Should be completed within 90 Days from the date of work order issued from this office. This Certificate will be valid only upto 90 days.
 - Consumer is only responsible for any objections while executing the work and after completion of work in future.

AE(T)

AEE(O)

Executive Engineer (Ele.),
(C.O&M) Division BESCO,
Doddaballapura Taluk.

- (C.O&M) Division
1. M/s Origami Cellulo Pvt Ltd, Plot No S7, KIADB Industrial Area, Apparel Park, Kasaba Hobli, Doddaballapura Taluk.
2. AEE(Ele),Doddaballapura Urban Sub Division.

Power Sanction Issued : EE/ P/S ltr No. 7344-45/30.08.2025.
Amount Paid:- AEE/AEE/DBPU/25-26/4223/02.09.2025.

SL NO	Deposits	Amount (Rs.)	RT NO & Date
1	ISD Charges Rs.	47,070/-	1114101010201/02.09.2025.
2	05 % SC on Est Cost	88,703/-	1114101010202/02.09.2025.
3	9% CGST	7983/-	
4	9% SGST	7983/-	
5	TC Testing Charges Rs	1000/-	1114101010203/02.09.2025.

HEAD OF Credit	: 16-206
ESTIMATE NO	: SOB-176/22.08.2025.
WORK ORDER NO & DATE	: 407/25-26/16-206/N-37169/11-09-2025
SANCTIONED FOR Rs.	: 9834/-
(Rs. Nine Thousand Eight Hundred & Thirty Four Only)	
AEE(O) (C. O&M DIVISION) BESCO NELAMANGALA	
Exe. Engineer(Ele.)	



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/DODDABALAPURA (U)/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, DODDABALAPURA (U) Sub Division
BESCOM , DODDABALAPURA (U)

To
M/S ORIGAMI CELLULO PVT LTD
MANOJ KUMAR PACHISIA, PLOT NO S7, KIADB APPAREL PARK561203

Sir/Madam

Sub : Arranging power supply to an extent of **0.00 KVA 150 HP** in favor of M/S ORIGAMI CELLULO PVT LTD MANOJ KUMAR PACHISIA, PLOT NO S7, KIADB APPAREL PARK561203 in DODDABALAPURA (U) OMU, DODDABALAPURA (U)

Ref: 1) Your application registration **61114108250006** dated **19-AUG-2025**

2) AEE/DODDABALAPURA (U) /AE(T) a/ **21-JAN-2026**

With reference to your application dated **19-AUG-2025** . Requesting for arranging power supply to an extent of **0.00 KVA 150 HP** power installations in favor of M/S ORIGAMI CELLULO PVT LTD MANOJ KUMAR PACHISIA, PLOT NO S7, KIADB APPAREL PARK561203 in DODDABALAPURA (U) OMU, DODDABALAPURA (U) Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M DODDABALAPURA (U) sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61114108250006	5720474	LT5-Urban- INDUSTRIAL POWER - LT5A-ULB	0.00 KVA/150.00HP	48.1037-48.1037 - ASD	47070
61114108250006	5720474	LT5-Urban- INDUSTRIAL POWER - LT5A-ULB	0.00 KVA/150.00HP	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)	150
Total Amount in Rupees					47220

b. The power supply will be arranged at 0V .

c. The Tariff applicable to your installation will be LT5-Urban, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level

h. Amount through DD should be paid in the name AEE BESCOM DODDABALAPURA (U) .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., DODDABALAPURA (U) Sub division, BESCOM for information and further needful.

Your's Faithfully,

Assistant Engineer (Technical),
DODDABALAPURA (U), BESCOM

Your's Faithfully,

Assistant Executive Engineer Ele.,
DODDABALAPURA
(U), BESCOM

Copy to:

