

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

EEMT/AEE(O)/BRAZ/AEE HTR/

Asst. Executive Engineer (Ele),
O&M Sub-Division,
COM. N. N. Nagar, Bangalore.

EXCD: 300 KVA
Added: 300 KVA

Office of the
Executive Engineer (Ele),
MT Division, BRAZ, BESCOM,
3rd Floor, Crescent towers,
Bangalore-560001.

CTR: 30/1A

Total CD: 200 KVA

MC: 3000

Date: 11/02/25

Subject: Rating Report of HT/EHT Installation.

H.T. Installation having the following details has been rated for periodical rating/complaint. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

DETAILS OF H.T. INSTALLATION:

R.NO. DPH7 182 CD. 600 KVA CTR: 30/1A Previously rated on 22/10/24
Activity: Plastic A Meter Constant: 2000
Tariff: 11/2a
Name & Address of the Consumer: M/s. P. S. M. Plastics Pvt. Ltd.
87-88, Anurag Balli, J/A

OBSERVATION & ADVICE ON TECHNICAL MATTER:

The meter of the installation is rated before and after the replacement of CT's and calibrated for meter.

ADVICE ON REVENUE MATTER:

EXCD: 300 KVA MC: 1500 New CD: 300 KVA
CTR: 15/1A MC: 3000
Downloaded data analysis enclosed: YES/NO.
Summary of analysis if rated against complaint.

ANNEXURE

DETAILS OF SEALS:

R.R. No. DPH7 182

L.N O.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter	BMI 39881			
2	TC Of Meter	BLAZB 70718			
3	M.D. Reset Knob	BLAZB 70719	BLAZB 72487		
4	Optical Port	BLAZB 94952	BLAZB 72488		
5	T.T.B	BLAZB 94953	BLAZB 72489		
6	Meter Chamber Main Door				
7	Meter Reading Window	BLAZB 70722	BLAZB 72490		
8	C.T./P.T. Chamber	BLAZB 70723	BLAZB 72491		
9	Cable Entry Chamber	MT 102609			
10	Hologram				

DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 bushing / LBS. Make. Verified Sl. No.
b) Cubicle Conditions & Location. Good

MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11kV/11kV \times 30/1 \times 1}{1 \times 1} = 3000$$

{Three Thousand only}

DETAILS OF Ct's/ Pt's: