





ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**

<b>No:</b> CEBRAZ/SEO/AEE-2/25-26/ ೧೨೨-೨೬ <b>Email ID:</b> <a href="mailto:cebraz.work@gmail.com">cebraz.work@gmail.com</a> <b>E-mail:</b> <a href="mailto:cebraz@bescom.co.in">cebraz@bescom.co.in</a> <b>Ph No.</b> 080-23500117 <b>Encl:</b>	 	<b>Office of the</b> <b>Chief Engineer Ele,</b> <b>Bangalore Rural Area Zone,</b> <b>No.1- 4, IT Park, 5th Floor, KSIIDC</b> <b>Building, Rajajinagar Industrial</b> <b>Estate, Rajajinagar,</b> <b>Bengaluru- 560 044,</b> <b>Date:</b> 17 APR 2025
---	--	---

**M/s INOX Air Products,**  
Rep by Sri Diganta Kumar Sarma,  
Plot No. 115 & 116,  
Devanahalli General Industrial area,  
KIADB Industrial area,  
Devnahalli, Bengaluru

Sir,

**Sub:** Arranging EHT power supply to an extent of **8000 kVA** in favour of **M/s INOX Air Products Pvt Ltd rep by Sri Diganta Kumar Sarma** at plot No. 115 & 116, Devanahalli General Industrial area, KIADB Industrial area, **Devanahalli sub-division**

**Ref:** 1. SEE, BRC Lr No. SEE/BRC/EE(O)/AEE(O)/F-2(b) & F-22/5461-63 dated 24-10-2024  
2. T.O Lr No. CEBRAZ/SEO/AEE-2/24-25/5156-58 dtd 29-10-2024  
3. CGM (op) Lr No. CGM(OP)/DGM-OP2/AGM-1(OP3)/BC-18/F-533 (09)/2024-25/503 dtd 09-04-2025

\*\*\*\*

With reference to the above subject, as per the approval from the corporate office vide ref (3), power sanction is hereby issued for arranging EHT power supply to an extent of **8000 kVA** in favour of **M/s INOX Air Products Pvt Ltd rep by Sri Diganta Kumar Sarma** at plot No. 115 & 116, Devanahalli General Industrial area, KIADB Industrial area, **Devanahalli sub-division** under HT2(a) tariff, subject to the following conditions under self execution:

**KPTCL Portion:**

1. The applicant shall draw 66 kV OH/UG cable from the proposed 220/66/11 kV Adinarayana Hosahalli phase -2 sub-station upto applicant's premises for a distance of about 2.0 kms under self execution.
2. The applicant shall construct 66 kV terminal bay at proposed 220/66/11 kV KIADB station at Adinarayana Hosahalli phase -2 (to be constructed by KIADB) for terminating their 66 kV line



3. The applicant has to carry out necessary modifications and extensions required at proposed 220/66/11 kV KIADB station at Adinarayana Hosahalli phase -2 sub-station for construction of 66 kV terminal bay as per KPTCL specifications.
4. Any ROW issue has to be solved by the applicant himself.
5. The power supply is feasible only after completion and commissioning of proposed 220/66/11 kV KIADB station at Adinarayana Hosahalli phase -2 by KIADB under self execution basis
6. The applicant shall execute connection agreement between concerned SEE/ works, and SEE, Maintenance for the use of Intra State Transmission system as approved by Hon'ble commission vide Lr dtd 16-12-2021 and furnish the same at the time of servicing the installation. The copy of the connection agreement is available on KERC website.
7. As per KERC 2015, under clause 5.8, respective user shall maintain their equipment beyond the outgoing gantry of feeder / line emanating from STU sub-station onwards.
8. Metering shall be as per BESCOM standards and norms.
9. **66 KV** system shall be as per KPTCL/ BESCOM standard practices

Further, in order to meet immediate load requirement, the committee considered and approved the load to an extent of 8000 kVA in favour of M/s INOX Air Products Pvt Ltd, rep by Sri Diganta Kumar Sarma at plot No. 115 & 116, Devanahalli General Industrial area, KIADB Industrial area, Devanahalli sub-division, subject to the following conditions.


- a) The applicant shall avail power supply by tapping the existing 66 kV NRS DB pura -Vijayapura SC line to the proposed gas plant EHT installation till the commissioning of proposed 220/66/11 kV Adinarayana Hosahalli phase -2 sub-station.
  - b) The applicant has to furnish the Indemnity Bond stating that KPTCL is not responsible for any line interruption on the existing 66 kV KPTCL line.
  - c) The applicant has to switch over the 66 kV connectivity after completion / commissioning of proposed 220/66/11 kV Adinarayana Hosahalli phase -2 sub-station.
10. You have to pay the following amount in the form of DD in favour of Asst. Executive Engineer Ele., BESCOM, **Devanahalli sub-division within 90 days** from the date of this power sanction.



- a. **Rs. 1,64,80,000/- (Total Rupees one crore sixty four lakh eighty thousand only)** towards 2 MMD under HT2a tariff
11. The applicant has to execute the works under self-execution through Karnataka State government approved **super grade Licensed Electrical Contractor** in co-ordination under the guidance of KPTCL/BESCOM officials.
  12. The entire Distribution system with connected equipments will be taken over by KPTCL/ BESCOM after completion of the works.
  13. The materials used shall confirm to ISI/BESCOM/KPTCL specifications and the materials procured should be got inspected before commencing of work by concerned Executive Engineer, BESCOM.
  14. You shall submit copies of the invoices / bills in respect of materials purchased by you for proof of having purchased the materials from the approved vendors / dealers.
  15. Guarantee shall be furnished for a period of not less than one year for the materials used for the works as well as for the quality of work carried out from the date of taking over the lines and equipments by BESCOM/ KPTCL.
  16. Proof of having purchased the materials used for execution of works from the reputed firm will be verified wherever necessary.
  17. You have to obtain the approvals of Electrical Inspectorate for new HT / LT lines / DTCs Forest clearance, statutory clearances, National Highway, PWD etc., others if any whichever applicable and has to submit it before servicing .
  18. The BESCOM / KPTCL is not responsible in whatsoever manner regarding any of legal disputes that may arise at a later stage.
  19. After payment of above charges and fulfilling of the conditions, an administrative approval will be issued from this office
  20. You should clear the out-standing arrears if any.
  21. You should abide by the conditions of supply of electricity 2004 in force with subsequent amendment.
  22. In case, applicant fails to meet the above conditions to arrange power supply, the intimation letter is deemed to have been cancelled.
  23. You have to pay any variation / difference of charges, if any, payable to BESCOM/ KPTCL in future as per subsequent amendments of KERC.

**NOTE:** For any 765/400/220/66/11 KV lines passing adjacent/ nearby/on the premises, mandatory clearance certificate should be obtained from the competent authority by the applicant. The same shall be ensured by the concerned EE of BESCOM before servicing of the installation. In case of any deviation in this regard, the concerned officers will be held responsible.

Yours faithfully,

  
**Chief Engineer Electy,**  
BRAZ, BESCOM

Copy to:

1. The Superintending Engineer Ele, C, O & M, BRC circle, BESCOM.
2. The Executive Engineer Ele, C, O & M division, Hosakote BESCOM .
3. The Executive Engineer Ele., MT division, BRAZ, BESCOM, Bengaluru.
3. The Asst. Executive Engineer Ele, C, O & M, Devnahalli sub Division, BESCOM,  
to submit the payment certificate within 3 days after payment.  
AEE-2 / MF/OC.