



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(wholly owned Government of Karnataka Undertaking)

NO-AEE(E)/LTRSD-2/DVG/2025-26/ 469
Encl: 06 No's Rating reports

office of the,
Assistant Executive Engineer (E)
LT Rating Sub-div -2, BESCOM,
Davangere

Date: 13.09.2025

To,

The Assistant Executive Engineer (Ele)
Anagodu Sub Division
Bescom, Davanagere
Sir,

Subject:- Submission of Field reports.

With reference to the above, Please find here with enclosed field reports of following installations pertaining to your sub-division. The details are as follows,

SL No	Name of the S/D Section	Date	Name of the Consumer	RR.No.	Tariff	Sanction Load	Remarks
1	Anagodu/ Anaji	08-10-2025	Sri Krishna	ALP804	LT-5	65HP	Permanent Cancellation: No Power supply. Meter & mains removed as per ltr no: AEE/ AAO/ ANG/ 25-26/ 2335/ 24.09.2025 Meter & mains removed in presence of so anaji & LM staff. FR obtained from meter test bench. IR=0.10 RTC Error to be scarp.
2	Anagodu/ Anaji	08-10-2025	Reddy Crusher	ALP331	LT-5	65HP	Permanent Diss: As per ltr no: AEE(t)/ AAO/ ANG/ 25-26/ 2335/ 24.09.25 Meter not calibrated due to no load FR obtained from meter test bench FR=46903.7 Old meter to be scarp
3	Anagodu/ Anaji	08-10-2025	S.R.Ravi	ALP1608	LT-5	65HP	Permanent Diss: power supply disconnected due to no payment B1Kwh=1396.7, 1396.7, 1396.6, 1393.5, 1389.3, 1384.0 B1MD=0.0, 0.0, 0.0 As per ltr no: AEE/ AAO/ 2025-26/ 2335 Date: 24.09.2025 Meter removed supply removed by so Anaji Section
4	Anagodu/ Anaji	08-10-2025	P.Hallanaik	ALP718	LT-5	65HP	Permanent Diss: NO power supply mains removed meter removed in presence of so Anaji. As per ltr no: AEE(t)/ AAO/ ANG/ 25-26/ 2335 Date: 24-09-2025 FR obtained from meter test bench. RTC Error meter faulty.
5	Anagodu/ Anaji	08-10-2025	Sri Kumar Naik	ALP803	LT-5	65HP	Permanent Cancellation: No Power supply. Meter removed as per ltr no: AEE(t)/ AAO/ ANG/ 25-26/ 2335/ Date: 24.09.2025 In presence of so meter & mains removed FR obtained from meter test bench. Meter MNR to be scarp.
6	Anagodu/ Anaji	08-10-2025	Sri M.G.Shivappa	ALP-828	LT-5	66HP	Permanent Diss: NO power supply. Meter & mains removed in presence of so Anaji. As per ltr no: AEE(t)/ AAO/ ANG/ 25-26/ 2335 Date: 24-09-2025 FR obtained in meter test bench. FR=900.5 K=20

(Handwritten signature)

Your's faithfully

(Handwritten signature)
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ವಿ)
ಮಾಪಕ ತಪಾಸಣಾ ಉಪ ವಿಭಾಗ-2, ಬೆಸಕಂ
ದಾವಣಗೆರೆ