Statement of Energy Consumption of 11KV Feeders of Davangere Division for the month of MAR-2025 in C,O &M Division, BESCOM, Davangere

Sl. No.	Designation	Name of the Line/Bank/Feeder	Voltage Class	CT Ratio	Meter readings		Difference	MC	Assessed Cons.	Consumption.	Total Cons.	Meter Status			Remarks	Diff to Bank & Feeders	Di
					Present	Previous						EM/ETV	Sl. No.	Make			
Name of the Station : 66 KV Basavapatna																	
4	**B1**	**Bank1, 12.5 MVA Apex**	**11KV**	**800/1**	**1330.537**	**1281.956**	**48.581**	**80000**	**0**	**3886480**	**3886480**	**DLMS**	**Q0253114**	**SECURE**	BANK-1 PT FUSE WAS FAILED FROM 15-06-2024 TO 17-06-2024		
	F1	Harlipura NJY	11 KV	200/1	40756.500	39744.600	1011.900	250	0	252975	**3899455**	DLMS	Q0253453	SECURE	New Meter Changed on date:29.08.2024		
	F2	Hosahalli NJY	11 KV	200/1	658.938	646.185	12.753	20000	0	255060		DLMS	Q0253467	SECURE			
	F3	Marabanahalli	11KV	300/1	760.412	718.360	42.052	20000	0	841040		DLMS	Q0253528	SECURE			
	F4	Chiradoni	11 KV	200/1	552.826	532.640	20.186	20000	0	403720		DLMS	Q0253057	SECURE		**-13944**	
	F5	Yellodhalli	11 KV	200/1	645.206	617.727	27.479	20000	0	549580		DLMS	Q0253066	SECURE			
	F6	Punnyastala	11 KV	200/1	643.757	600.343	43.414	20000	0	868280		DLMS	Q0253580	SECURE			
	F7	Sangahalli NJY	11 KV	200/1	9.617	0.000	9.617	20000	240680	433020		ETV	Q0255300	SECURE	Meter Changed on date:17.03.2025, OLD METER IR-705.789, FR-717.823,MC-20000,CONSM-240680		
	F8	Basavapatna Urban	11KV	200/1	598.679	583.890	14.789	20000	0	295780		DLMS	Q0253274	SECURE			
	B2	**Bank2 20 MVA**	**11KV**	**400/1**	**154.239**	**107.612**	**46.627**	**80000**	**0**	**3730160**	**3730160**	**ETV**	**Q0253244**	**L&T**			
	F9	Siddeshwara Nagar	11KV	200/1	4061.900	3766.000	295.900	2000	0	591800	**3727600**	ETV	21001969	SECURE			
	F10	Nilogal	11KV	200/1	6572.800	6113.300	459.500	2000	0	919000		ETV	Q0253207	SECURE		**2560**	
	F11	Basavapatna IP	11KV	200/1	4207.700	3925.600	282.100	2000	0	564200		ETV	Q0253520	SECURE			
	F12	Kanchugaranahalli	11KV	200/1	3536.900	3244.500	292.400	2000	0	584800		ETV	Q0253136	SECURE			
	F13	Daginakatte NJY	11KV	100/1	15596.900	15063.000	533.90	2000	0	1067800		ETV	16194161	L&T			
		Aux.-1 (B1)			**22299.00**	**21330.00**	**969**	**1**		**969**		LANDIS +GYR	**D420416**	LANDIS +GYR			
Name of the Station : 66 KV Devarahalli																	
11	**B1**	**Bank1, 12.5 MVA Apex**	**11KV**	**600/1**	**60.113**	**26.314**	**33.799**	**80000**	**0**	**2703920**	**2703920**	**DLMS**	**Q0253363**	**Secure**	Bank-1 meter changed on 03.02.2025		
	F1	Gangur	11KV	200/1	835.262	821.336	13.926	30000		417780	**2704110**	DLMS	Q0253289	Secure			
	F2	Udgiri NJY	11KV	200/1	53.882	28.232	25.650	20000		513000		ETV	Q0255761	SECURE	New Meter Changed on date:01.01.2025. Old Meter FR-792.060	**-1600**	
	F3	Devarahalli	11KV	200/1	588.659	565.422	23.237	30000		697110		DLMS	Q0253241	Secure			
	F4	Gullahalli	11 KV	200/1	849.857	819.775	30.082	20000		601640		DLMS	Q0253501	Secure			
	F5	Navodaya	11 KV	200/1	60.512	58.970	1.542	10000		15420		DLMS	Q0253202	Secure			
	F12	K.Matti IP	11KV	200/1	1473.69	1244.11	229.580	2000		459160		ETV	Q0704590	SECURE	New Feeder charged on 27.03.2024, Name as F12-K Matti		
			11KV	600/1	1096.499	1049.756	46.743	80000		3739440	3739440	DLMS	Q0253132	Secure			