

Sl. No.	Designation	Name of the Line/Bank/Feeder	Voltage Class	CT Ratio	Meter readings		Difference	MC	Assessed Cons.	Consumption.	Total Cons.	Meter Status			Remarks	Diff to Bank & Feeders
					Present	Previous						EM/ETV	Sl. No.	Make		
40. Name of the Station : 66 KV Kereblichchi commissioned on 03.07.2015 and load taken on 20.07.2015																
16	B1	Bank-1, 8 MVA	11KV	400/1	1290.086	1246.355	43.731	40000		1749240	1749240	DLMS	Q0253249	Secure		
	F1	Kereblichchi	11KV	200/1	1052.127	1027.871	24.256	20000		485120	1746220	DLMS	Q0253257	Secure		1889
	F2	Water Supply KBC	11KV	200/1	414.787	406.917	7.870	20000		157400		DLMS	Q0253200	Secure		
	F3	Hosur IP KBC	11KV	200/1	693.744	664.304	29.440	20000		588800		DLMS	Q0253082	Secure		
	F4	Alur N.JY	11KV	200/1	290.669	284.663	6.006	20000		120120		DLMS	Q0253586	Secure		
	F9	Jakkali IP	11KV	200/1	1205.540	1008.150	197.390	2000		394780		DLMS	Q0704544	SECURE	New Feeder charged on 16.03.2024	
	B2	Bank-2 8 MVA	11KV	400/1	485.439	428.426	57.013	40000		2280520	2280520	DLMS	Q0253526	Secure	NEW METER CONNECTED ON 01.12.23	
	F5	Somalapur IP	11KV	200/1	686.311	659.897	26.414	20000		528280	2251060	DLMS	Q0253053	Secure		29460
	F6	Channapura IP	11KV	200/1	1125.365	1073.598	51.767	20000		1035340		DLMS	Q025391	Secure		
	F7	Somalapur N.JY	11KV	200/1	522.974	514.966	8.008	20000		160160		DLMS	Q0253073	Secure		
	F8	Alur IP KBC	11KV	200/1	20.660	0.000	20.660	20000	114080	527280		ETV	Q0250810	SECURE	Meter Changed on date:08.03.2025, OLD METER IP-575.658, FR-S&L 392,MC-20000,CONSUM-114080	
		Aux-1 (B1)			44682.8	43551.4	1131	1		1131		ETV	P0019916	Lambda & GYR		