



|                     | Existing  | After Replacement | Existing | After Replacement |
|---------------------|-----------|-------------------|----------|-------------------|
| 1. Make             | KALPA     | KALPA             |          |                   |
| 2. Type             | 3-φ WY    | 3-φ WY            |          |                   |
| 3. Class            | 0.2       | 0.25              |          |                   |
| 4. Insulation level | W3215X1-P | W3215X1-P         |          |                   |
| 5. Burden           | 2.5 VA    | 2.5 VA            |          |                   |
| 6. Ratio Connected  | 5/1 A     | 7.5/1 A           |          |                   |
| 7. Sl. No.          |           |                   |          |                   |
|                     | 1 R 22421 | R 3885            | R        | R                 |
|                     | 2 Y 22422 | Y 3886            | Y        | Y                 |
|                     | 3 B 22423 | B 3887            | B        | B                 |

5. DETAILS OF METERS:  
ETV Meter

|                  | Existing           | After Replacement |
|------------------|--------------------|-------------------|
| a. Make          | LEB                |                   |
| b. Type          | WR300.53 11MWR3    |                   |
| c. Class         | 0.25               |                   |
| d. Voltage       | 3x 43.9V           |                   |
| e. Ampere        | 1A                 |                   |
| f. Pulse / Unit  | 50000              |                   |
| g. Dial Constant | 1                  |                   |
| h. Sl. No.       | 83008788 Amt. 8093 |                   |

6. A. CALIBRATION DETAILS:

|                               | CALIBRATOR          | METER               |
|-------------------------------|---------------------|---------------------|
| a. Voltage V1, V2, V3         | 61.28, 61.53, 61.64 | 61.24, 61.58, 61.69 |
| b. Current I1, I2, I3         | 0.291, 0.271, 0.183 | 0.283, 0.270, 0.153 |
| c. P.F. / K.W                 | 0.0316 / 0.985      | 0.0315 / 0.980      |
| d. Sequence                   | 2, 3                | 2, 3                |
| e. % of Error                 |                     |                     |
| a. Reading of Test Meter      | 0.0638%             | 0.0638%             |
| b. Reading of Reference Meter |                     |                     |
| c. Percent Error              |                     |                     |

7. METER READINGS:

|                              | Existing       | After Replacement |
|------------------------------|----------------|-------------------|
| A. Cumulative Parameters     |                |                   |
| a. Time Date, Month, Year    | 14.54 06.11.25 | 15.34 06.11.25    |
| b. Demand with elapsed time  | 000            | 000               |
| c. Self-diagnostic condition | 0.1163 / 0.954 | 0.0269 / 0.950    |
| d. Present KVA PF            | 701.268        | 701.268           |
| e. Cumulative KWH            |                |                   |
| TOD 1                        | /              | /                 |
| 2                            | /              | /                 |
| 3                            | /              | /                 |
| 4                            | /              | /                 |

B. BILLING PARAMETERS:

|                                  |         |         |
|----------------------------------|---------|---------|
| a. Billing KWH                   | 693.635 | 701.268 |
| TOD 1                            | /       | /       |
| 2                                | /       | /       |
| 3                                | /       | /       |
| 4                                | /       | /       |
| b. Billing KVA                   | 0.1979  | 0.1570  |
| TOD 1                            | /       | /       |
| 2                                | /       | /       |
| 3                                | /       | /       |
| 4                                | /       | /       |
| c. Billing PF (Universal TOD)    | 0.952   | 0.945   |
| TOD 1                            | /       | /       |
| 2                                | /       | /       |
| 3                                | /       | /       |
| 4                                | /       | /       |
| d. MD Reset Count                | 34      | 35      |
| e. MD Reset Manual/ Automatic On | Aut on  | Aut on  |

Prateegowda P.N.  
Consumer's Representative's Signature  
With Seal

Asst. Executive Engineer (Ee.)  
HT Rating Sub-Division, HEBKOTE  
MT Division, BRAZ, Bangalore

Note: Retard 5/1A, 0.1570 KVA, 3 months like old CT should be replaced.