



GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)



Scan the above QR Code
for verifying the authenticity of the Approval

Ack No : EI000110919788

Date : 13/01/2026

GSC No : EN0010000392355

O/o. Deputy Chief Electrical Inspector,
Bangalore Additional South,
No. 119, 1st Floor, Munilakshamma Building,
Arekere Main Road, Arekere, BTS layout
B G Road, Bengaluru -560 076.
Phone No :8026484656

To:

SRI SIDDAPURA SRINIVASA RAMAKRISHNAREDDY
So Ramakrishnareddy
KH No.384/49/2,, Kallubalu Village Panchayath
Kallubalu, BENGALURU(District), ANEKAL(Taluk)
Karnataka, India-560105

Sir,

Sub : Approval of electrical installation pertaining to 1x2000kVA(Oil Type), 11kV/433V HT Transformer Substation at SRI SIDDAPURA SRINIVASA RAMAKRISHNAREDDY KH No.384/49/2,, Jigani Harohalli Main Road, Kallubalu Panchayath, Jigani Hobli, Kallubalu Village, BANGALORE ADDL SOUTH(District), BANGALORE ADDL SOUTH (Taluk) - 560105

Drawing Ref No : EI000110919501

Ref :

1. Drawing acknowledgement No: EI000110919501 Dated: 09.01.2026
2. Work Completion Report Letter No: Nil, Dated: 09.01.2026.(EI000110919788)

With reference to the above, approval is hereby granted for energizing the electrical installation at [SRI SIDDAPURA SRINIVASA RAMAKRISHNAREDDY with KH No.384/49/2,, Jigani Harohalli Main Road, Kallubalu Panchayath, Jigani Hobli, Kallubalu Village, BANGALORE ADDL SOUTH, BANGALORE ADDL SOUTH - 560105] under Regulation No. [45] of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 as per details enclosed.

This approval is strictly subject to your full compliance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 (as amended to date) in every respect.

Note :

Conditions :

1. As per Regulation No: 48(5) and 48(6) required records shall be maintained.
2. As per Regulation No: 48(7) the installation shall be maintained and operated in a condition free from danger.
3. As per Regulation No: 3 designated person(s) shall operate and carryout the work on electrical lines and apparatus.

Inspection fee of **Rs. 31,600/- (IN WORDS) Thirty One Thousand Six Hundred only** paid vide K2 Challan Ref. No: **EL0126004300004492** dated **09/01/2026**

Details of Equipments :

Details of the Equipments:

1. HT Cable: a) 2Rx 3Cx 95Sqmm 11KV XLPE HT UG Cable. (From Tapping point to GOS)
b) 1Rx 3Cx 95Sqmm 11KV XLPE HT UG Cable. (From GOS to HTMC to VCB to Transformer)

Electrical Installation Approval

1 of 3

Ack No : EI000110919788

Date : 13/01/2026



GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)



Scan the above QR Code
for verifying the authenticity of the Approval

2. HT Switchgear: 200Amps GOS Set with HG Fuse Unit.
3. HT Metering Cubicle: Panel Make: OMEGA SWITCHGEAR, Panel SI No: OMEGA/26-01-3581.
 - a) Current Transformer: Make: KALPA, Ratio: 25/1A, Class: 0.2S, Burden: 2.5VA, SI Nos: 1) 19711/25, 2) 19712/25, 3) 19699/25.
 - b) Potential Transformer: Make: KALPA, Ratio: 11KV/Rt3/110V/Rt3, Class: 0.2, Burden: 25VA, SI Nos: 1) 78928/25, 2) 79331/25, 3) 78973/25.
 - c) Energy Meter: Make: Schneider, Class: 0.2S, SI No: 25014403.
4. HT Switchgear: VCB Panel Make: DEV SWITCHGEAR, Panel SI No: DSG/114/2025-26. VCB, 11kV, 800A, SI No: DSG/VCB/056/2025-26.
5. Transformer: 1x2000kVA(Oil Type), 11kV/433V, 104.975/2666.823Amps, Make: VIJAY VIDYUTH UDYOG, SI No: 2025 EEL-2 ODO-001/10.
6. LT Cable: a) 2Rx 3.5Cx 400 Sqmm LT UG Cable.
b) 4Rx 3.5Cx 240 Sqmm LT UG Cable.
7. LT Switchgear: 4P ACB, Make: SCHNEIDER ELECTRIC, 2000Amps.
Subjected to the condition cites below
 1. A separate approval shall be obtained for D.G set and lift installation
 2. Any addition or alteration in the existing system shall be got approved from this office as per regulation 45(6) of central electricity authority (Measures relating to safety and Electric supply) regulation-2023.
 3. The approval accorded as per safety provisions of central Electricity Authority (Measures relating to safety and Electric supply) regulation- 2023. It shall not be considered for any type bill payments. Bill shall be paid after obtaining the joint inventory reports from ESCOM/ concerned Authority after taking the actual measurements, equipment bills etc.
 4. Approval is issued subject to Honorable Supreme court judgment of civil Appeal no: 14604/2024 and 14605/2024 Dt: 17-02-2024 and Ltr No: CEIG/ACEI/EI-1,2/14754-892/24-25 Dt: 28.01.2025, Electricity service provider shall service the building after obtaining the completion/occupation certificate.
 5. The responsibility of the authenticity of documents submitted by applicant lies with applicant.
 6. Separate approval shall be obtained for LT Loads after completion of internal wiring work from this office.

Yours faithfully,



Digitally Signed by :

Deputy Chief Electrical Inspector
Bangalore Additional South

Signed Date

: 13/01/2026