



# Bangalore Electricity Supply Company Limited

(Wholly Owned Government of Karnataka Undertaking)

No:EEE/RMG/AEE(O)/AE-3/2025-26/

5656-57

Office of the  
Executive Engineer(Ele.),  
C, O & M Division, BESCOM,  
Near Railway Station,  
Ramanagara-562159  
Date: 18 SEP 2025

E-mail: eeramanagardivision@bescom.co.in  
Phone: 080-27273521

To,

Smt. Mamatha Sundar Raju w/o S.G Sundarraju,  
Sy no-39/2,  
Harisandra village,Kasaba Hobli,  
Harisandra Gram Panchayath,  
Ramanagara Taluk,  
Bengaluru South District

340

## INTIMATION

Sub:- Estimate for arranging power supply to an extent of 10HP IP Set installation-LT-4(a) in favour of Smt. Mamatha Sundar Raju w/o S.G Sundarraju, Sy no-39/2, Harisandra village, Kasaba Hobli, Harisandra Gram Panchayath, Ramanagara Taluk, Bengaluru South District in O&M-3 unit, Sugganahalli, Section of Ramanagara Rural Sub-division. (Under self execution).

Ref: 1.AEE(E)/AET/RRSD/2025-26/F-816 dated:- 16.09.2025.

2. Application No.1311109250050 dated:- 12.09.2025.

3. Sub Application No.13111092500500001 dated:- 12.09.2025.

4. Estimate No: HRL-128 dated:- 12.09.2025.

With reference to above you are requesting for arranging power supply to an extent of 10HP IP Set installation-LT-4(a) in favour of Smt. Mamatha Sundar Raju w/o S.G Sundarraju, Sy no-39/2, Harisandra village, Kasaba Hobli, Harisandra Gram Panchayath, Ramanagara Taluk, Bengaluru South District in O&M-3 unit, Sugganahalli, Section of Ramanagara Rural Sub-division. (Under self execution).

You are requested to observe and fulfil the following conditions,

- 1)The power supply will be arranged at 230/400 Volts.
- 2)The Tariff applicable to your installation will be LT-4(a) or the Tariff in force
- 3)You have to enter into an agreement with the BESCOM in the prescribed form.
- 4)Pay 2MMD for 10HP of Rs. 16,600/-
- 5)Pay Meter security deposit of Rs. 2,380.00
- 6)Pay TP Box deposit of Rs. 3,644.00
- 7)Pay supervision charges of Rs.150.00
- 8)Pay transformer testing charges of Rs.1000/-
- 9)Submit the Contractor's Completion Cum Test Report along with diagram in Duplicate.
- 10)You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

In case the above requirements are not fulfilled within 90 days from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED.

You are requested to contact the Asst. Ex. Engineer (Ele), Ramanagara Rural SD, BESCOM for information and further needful.

Yours Faithfully

Executive Engineer (Ele).  
BESCOM, Ramanagara, Division.

### Copy to:

- 1) The Assistant Executive Engineer (Ele), BESCOM, Ramanagara Rural Subdivision for information and to submit the payment certificate
- 2)MF/AE-3

