



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/MALUR /AE(T)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, MALUR Sub Division
BESCOM , MALUR

To
INDIAN OIL CORPORATION LIMITED
PURASANAHALLI VILLAGE,

Sir/Madam

Sub : Arranging power supply to an extent of **20.00 KW** in favor of INDIAN OIL CORPORATION LIMITED PURASANAHALLI VILLAGE, in MALUR OMU, MALUR

Ref: 1) Your application registration **1243112250045** dated **06-DEC-2025**

2) AEE/MALUR /AE(T) a/ **16-FEB-2026**

With reference to your application dated **06-DEC-2025** . Requesting for arranging power supply to an extent of **20.00 KW** power installations in favor of INDIAN OIL CORPORATION LIMITED PURASANAHALLI VILLAGE, in MALUR OMU, MALUR Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M MALUR sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1243112250045	12431122500450001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	20.00 KW	62.9097-BESCOM Establishment Charges (at 10% on DCW	47692
1243112250045	12431122500450001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	20.00 KW	47.3137-47.3137 - DCW(HI/LI) - NO TAX	476918
1243112250045	12431122500450001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	20.00 KW	48.1017-48.1017 - ISD	32000
Total Amount in Rupees					556610

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM MALUR .

i. Intimation is valid up to 30 days from the date of issue.

You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.

Sl No	Description	Qty	Rate	GST (%)	Amount
1	LT AC 3 Phase 4 Wire CT Operated, 5 Amps Smart Energy Meter, Class 0.5s Accuracy with Communication Module without Box	1	9237.2900	18%	8611.00

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FORFEITED. You are requested to contact the Asst. Ex. Engineer Ele., MALUR Sub division, BESCOM for information and further needful.