


# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No.EE(E)/AEE(O)/AE-1/KGF/25-26/

848485



Office of the  
Executive Engineer (Elec.),  
C, O & M Division,  
Champion Reefs,  
K.G.F - 563117,  
Date: 29.12.2025

To,  
Sri. Padala Veera Venkata Satyanarayana Reddy,  
Sy No. 50/3,50/4,50/5, Kysamballi Village,  
KGF Taluk.

## UNDER SELF EXECUTION

Sir,

**Sub:** Electrification of Private Residential Layout to a requisite load of **244 KWs** by Providing **1x250 KVA 5 Star rated** Transformers in favour of Sri. Padala Veera Venkata Satyanarayana Reddy, Sy No. 50/3,50/4,50/5, Kysamballi Village, KGF Taluk, in O & M-Kysamballi Section of Bethamangala Sub Division Under Self-Execution.

**Ref:** 1. The SEE, Kolar Lr No. :SEE/EE(O)/AEE(T)/AE-W/25-26/6412-14, Dtd: 08.12.2025 for executing electrification work under Self Execution including Distribution Transformer.  
2. AEE(E), Bethamangala Sub-Division Letter No:AEE(EI)/AE(T)/BTM/996, Dtd: 20.12.2025.  
3. KERC 8<sup>th</sup> Amendment No: KERC/D/14/16-17/ dated: 22.11.2016.

\*\*\*\*\*

Electrification of Private Residential Layout is developed in the area of 03 Acre 19 Guntas with 58 Nos of Residential Sites to a requisite load of **244 KWs** by **Providing 1x250 KVA 5 Star rated Transformers in favour of Sri. Padala Veera Venkata Satyanarayana Reddy, Sy No. 50/3,50/4,50/5, Kysamballi Village, KGF Taluk, in O & M-Kysamballi Section of Bethamangala Sub Division Under Self-Execution** is sanctioned and requested to fulfill the following conditions.

1. You have to pay the following amount at O&M **Bethamangala** Sub-Division, BESCO within period of **90 days** from the date of this letter. Failing which the sanction stands cancelled.  
➤ **Supervision Charges shall be collected 5% on Self-Execution CDS of Rs. 72,314/-** (Rupees Seventy Two Thousand Three Hundred and Fourteen only) on Self-Execution portion of the Estimate Costing Rs. **14, 46,287/-** (Rupees Fourteen Lakhs Forty Six Thousand Two Hundred and Eighty Seven only).
2. You have to carry out the work involved for electrification of proposed residential Layout at your own cost under Self-Execution, through Class-I Electrical Contractor as per the Estimate approved by the Asst. Executive Engineer (Ele), C, O&M Sub-Division, BESCO, **Bethamangala**.
3. You have to pay **Rs. 72,314/- (Rupees Seventy Two Thousand Three Hundred and Fourteen only)** towards 5% on Total Estimate Cost (Under Self-Execution) as **onetime payment towards Maintenance of distribution work**.
4. You have to pay **Rs. 13,017/-** (Rupees Thirteen Thousand and Seventeen only) towards **GST @ 18% on onetime payment towards Maintenance of distribution work**.

### PROPOSALS:-

1. Work involves tapping of 11 kV F-6 NJY feeder feeding from 66/11KV Kysamballi MUSS. It is proposed to provide 9 Mtr DP Structure with GOS at the tap ping point near the entrance of the gate. Work involves drawing of 11kV OH line to a distance of 0.05 KMs and LT 3 phase 5 wire secondary for a distance of 0.575 Kms.
2. This proposed **1x250KVA 5 Star rated** DTC comes on 11 kV F-6 NJY feeder feeding from 66/11KV Kysamballi with a peak load of 19 MWs and peak load of the feeder is 30 Amps.
3. **1x250KVA 5 Star rated** Transformers and its allied equipments will be installed by Distribution Licensee at the later date depending upon the load demand.
4. Required deposit and application shall be submitted to concerned Asst. Executive Engineer (Ele), C, O&M Sub-Division, BESCO, **Bethamangala** at the time of energisation of Layout.
5. The applicant has to maintain the vertical & horizontal clearance from building as per the Rule No.80 of IE Rule 1956, where high or extra high voltage overhead line passes above or adjacent to any building or part of the building.
6. The applicant has to maintain following corridor width, based on the voltage of EHV line if any EHT line pass through the Layout.

66 KV	220 KV	400 KV
18 Mtrs (9 Mtrs on either side from the centre of the line)	35 Mtrs (17.5 Mtrs on either side from the centre of the line)	51 Mtrs (25.5 Mtrs on either side from the centre of the line)

Materials used shall confirm to BESCOM specifications whenever necessary.


7. The entire Distribution system with the connected equipment shall be handed over to BESCOM after completion of the work.
8. Guarantee shall be furnished for a period of not less than 1 year for the materials used in the work as well as the quality of the work carried out from the date of handing over of lines & equipments to BESCOM.
9. Proof of having purchased the materials used for executing the works for BESCOM vender approved firm will be verified whenever necessary.
10. After payment of Supervision Charges (Other Charges) which is given in the intimation work order will be issued by the Executive Engineer (Ele), C, O&M, BESCOM, K.G.F. Division.
11. Materials procured by the prospective consumer in respect of Self-Execution work shall confirm to BESCOM specification and shall be inspected by the jurisdictional Engineer, Electrical C. O&M or his authorized representative. The Executive Engineer (Ele)/ Asst. Executive Engineer (Ele). C. O&M Sub-Division shall ensure that materials are purchased from approved vendors. Proof of having purchased materials used for executing the works will be verified whenever necessary.
12. Other conditions specified in additional Class 3.2.1 of conditions of supply of electricity should be fulfilled.
13. **Material Inspection fees of Rs.20, 000/-** (Rupees Twenty Thousand only) shall be paid at Sub-Division office.
14. You have to pay **Rs.3,600/-** (Rupees Three Thousand Six Hundred only) towards **GST @ 18%** on Material Inspection Charges.
15. Separate Work Order will be given for drawing DTC's after payment of DCW charges as mentioned below.

We remain at your service.

**Deposits to be paid :**

01	Supervision Charges @ 5% on all the item of Self-Execution CDS	Rs. 72,315/-
02	5% Maintenance of distribution work charges on (US)	Rs. 72,315/-
03	GST @ 18% on One time maintenance charges	Rs. 13,017/-
04	Material Inspection Charges	Rs. 20,000/-
05	GST @ 18% on Material Inspection Charges	Rs. 3,600/-
06	Transformer Testing Charges Payable at Division Office	Rs. 1,000/-

Yours faithfully,

  
 EXECUTIVE ENGINEER (ELE),  
 BESCOM, KGF DIVISION.

**Copy to:-**

1. The Asst. Executive Engineer (Ele), C, O&M Sub-Division, BESCOM, Bethamangala.
2. O/C.