



**VIDYANAGARA ONLINE I**  
**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ**  
 20240033064 06/07/2024 14:46

**ರಶೀದಿ / RECEIPT**

**IS D[48.101]**

ರಶೀದಿ ಸಂಖ್ಯೆ  
 Receipt No. 5020179/  
 ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
 Consumer ID No. **M/S SUKHI ENTERPRISES**  
 ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
 Bill No. **Rupees Two Lakhs Thirty Th**  
**ree Thousand Twenty Three Only**  
 ಇವರಿಂದ  
 Received From

ದಿನಾಂಕ  
 Date  
 ವಿಧ  
 Type **233023.00**  
 ಬಿಲ್ಲಿನ ದಿನಾಂಕ  
 Bill Date **DD- 7448 06/07/2024**  
 ಮೊತ್ತ(ರೂ.)  
 Amount in Rs.

00Kxy062x40w3064x1446M47S32SUKHI3232w32  
 Amount in Words

ಪಾವತಿ ವಿಧಾನ/  
 Payment Mode 

Cash	<b>GANGARAJU</b>	DD
------	------------------	----

ದಯವಿಟ್ಟು ಕೌಂಟರ್ ಬಿಡುವ ಮೊದಲು ಮೊಬಲಗು ಮೊತ್ತ ಮತ್ತು ಬಿಡಿ.ನಂ. ಅನ್ನು ಪರಿಶೀಲಿಸಿ  
 Before leaving the counter please check the Amount & ID No.

Signature of the Cashier



**VIDYANAGARA ONLINE I**  
**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ**  
 20240033065 06/07/2024 14:46

**ರಶೀದಿ / RECEIPT**

**5% Supervisory Charge(61.904)**

ರಶೀದಿ ಸಂಖ್ಯೆ  
 Receipt No. 5020179/0  
 ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
 Consumer ID No. **M/S SUKHI ENTERPRISES**  
 ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
 Bill No. **Rupees Ninety One Thousand**  
**Nine Hundred Twenty Nine Only**  
 ಇವರಿಂದ  
 Received From

ದಿನಾಂಕ  
 Date  
 ವಿಧ  
 Type **91929.00**  
 ಬಿಲ್ಲಿನ ದಿನಾಂಕ  
 Bill Date **DD- 7448 06/07/2024**  
 ಮೊತ್ತ(ರೂ.)  
 Amount in Rs.

00Kxy062x40w30Ax1446M47S32SUKHI329291Z  
 Amount in Words

ಪಾವತಿ ವಿಧಾನ/  
 Payment Mode 

Cash	<b>GANGARAJU</b>	DD
------	------------------	----

ದಯವಿಟ್ಟು ಕೌಂಟರ್ ಬಿಡುವ ಮೊದಲು ಮೊಬಲಗು ಮೊತ್ತ ಮತ್ತು ಬಿಡಿ.ನಂ. ಅನ್ನು ಪರಿಶೀಲಿಸಿ  
 Before leaving the counter please check the Amount & ID No.

Signature of the Cashier



**VIDYANAGARA ONLINE I**  
**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ**  
 20240033066 06/07/2024 14:46

**ರಶೀದಿ / RECEIPT**

**CGST 9%**

ರಶೀದಿ ಸಂಖ್ಯೆ  
 Receipt No. 5020179/0  
 ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
 Consumer ID No. **M/S SUKHI ENTERPRISES**  
 ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
 Bill No. **Rupees Eight Thousand Two**  
**Hundred Seventy Four Only**  
 ಇವರಿಂದ  
 Received From

ದಿನಾಂಕ  
 Date  
 ವಿಧ  
 Type **8274.00**  
 ಬಿಲ್ಲಿನ ದಿನಾಂಕ  
 Bill Date **DD- 7448 06/07/2024**  
 ಮೊತ್ತ(ರೂ.)  
 Amount in Rs.

00Kxy062x40w30Bx1446M47S32SUKHI324728z  
 Amount in Words

ಪಾವತಿ ವಿಧಾನ/  
 Payment Mode 

Cash	<b>GANGARAJU</b>	DD
------	------------------	----

ದಯವಿಟ್ಟು ಕೌಂಟರ್ ಬಿಡುವ ಮೊದಲು ಮೊಬಲಗು ಮೊತ್ತ ಮತ್ತು ಬಿಡಿ.ನಂ. ಅನ್ನು ಪರಿಶೀಲಿಸಿ  
 Before leaving the counter please check the Amount & ID No.

Signature of the Cashier



**VIDYANAGARA ONLINE I**  
**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ**  
 20240033067 06/07/2024 14:46

**ರಶೀದಿ / RECEIPT**

**SGST 9%**

ರಶೀದಿ ಸಂಖ್ಯೆ  
 Receipt No. 5020179/0  
 ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
 Consumer ID No. **M/S SUKHI ENTERPRISES**  
 ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
 Bill No. **Rupees Eight Thousand Two**  
**Hundred Seventy Four Only**  
 ಇವರಿಂದ  
 Received From

ದಿನಾಂಕ  
 Date  
 ವಿಧ  
 Type **8274.00**  
 ಬಿಲ್ಲಿನ ದಿನಾಂಕ  
 Bill Date **DD- 7448 06/07/2024**  
 ಮೊತ್ತ(ರೂ.)  
 Amount in Rs.

00Kxy062x40w30Cx1446M47S32SUKHI324728z  
 Amount in Words

ಪಾವತಿ ವಿಧಾನ/  
 Payment Mode 

Cash	<b>GANGARAJU</b>	Cheque	DD
------	------------------	--------	----



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

## C E R T I F I C A T E

No: EEE/HKTD/AEE (O)/AE(T)/2024-25/ 117296  
Date: 11/7/24

SL No.547, Page No.153  
Date: 09.07.2024.

This estimate is sanctioned for Self-execution work for requesting for A/P/S to an extent of 100 kVA to HT Commercial purpose in favour of M/s Sukhi Enterprises, Plot No. 3-A-5,& 3-A-6., Hi-Tech Defence & Aerospace Park) KIADB Sy No. 104P, Hoovinayakanahalli village Sadahalli Cross O&M unit Vidyanagara Sub-Division under Self execution Work Scheme. by class-I Licensed Electrical Contractor as per the sanctioned estimate under the supervision of Asst. Engineer (Ele) /Asst. Executive Engineer (Ele), Vidyanagara Sub-Division.

5 % Supervision Charges of Rs. 91,929/- vide Rcpt No. 20240033065 Dated: 06.07.2024 at 5 % on the cost of the estimate is collected. No work order is assigned under any Head of Account of the Corporation to this work. This Certificate itself is treated as sanction for execution of work. After completion of work, joint inventory as prescribed vide Chief Controller of Accounts circular No. A0/Sa.4/Cys-10/92-93, dated 20-04-92 (page 246 of compendium vol.1) will be taken and asset accounted in the books. The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout/M.S Building.

66KV	220KV	400KV
2.3 Meters	3.8 Meters	5.6 Meters

All the electrical equipments such as LBS, Transformers and Metering cubicle shall be provided in Ground floor only.

As per Circular No. BESCO/BC-33/ F-2338/ CYS-11/05.05.09 vide Sl. No. 15(a); the materials procured by the contractors for execution of total turnkey/ Partial turnkey and self-execution, works shall be invariably be subjected to inspection by competent authority for its quality and specification as approved by BESCO before commencement of works. The material placed by you is of 1-year guarantee and you have to maintain the same for 1 year.

Consequent to the amendment by the regulation by the Hon'ble KERC vide reference, the work shall be executed, completed and shall avail service within **90 days** of this work order, else the application for power supply will be deemed as CANCELLED. On cancellation of the application, registration/re-registration cum processing charges shall stands forfeited for any further details you may contact Asst. executive Engineer, Vidyanagara Sub-Division.

- Note:
1. Materials to be procured by BESCO approved vendors and materials to be inspected by competent authority before execution /commencement of the work and remarks to be attend
  2. Vide ref no:GM(QS&S)/DGM(EI)-3/Mgr/BC-11/21-22/CYS-39/Date:12.07.2021.Incase of all Self execution works where dry type transformer, cable entry transformers are installed but not commissioned (for which there is no vendor approval ) shall be commissioned only after getting specific approval from GM(QS&S).
  3. Transformer installed under Self Execution scheme has to be tested by the concerned MT section as per circular cited under reference-4
  4. AEE, Vidyanagara sub division has to collect the self execution agreement before execution of work.

AEE (T),  
BESCO, HKTD

AEE (O),  
BESCO, HKTD

Executive Engineer  
BESCO, HOSAKOTE


A/C Head	Amount in Rs.	Receipt No	Date
5 % SC	Rs.91,929/- x 01 No	20240033065	06.07.2024
CGST+SGST of 9% on 5 % SC charges	Rs.8,274/- x 02 Nos	202400333066-67	06.07.2024
2MMD	Rs.2,33,000 /- X 1 No	20240033064	06.07.2024

Ref No:-

1. This office Intimation Ltr. No. EEE/HKTD/AEE(O)/AE/2024-24/3895 dt 02.07.24
2. Payment Certificate Ltr. No. AEE/V.Nagara/AET/24-25 1021 / dt:06.07.2024.
3. ಪತ್ರ ಸಂಖ್ಯೆ: ಬಿಎಕಂ/ ಬಿಸಿ-35/ ಪ್ರವ್ಯ(ಎ)/ಗು.ಪ್ರ &ಸು/2022-23/CYS-06 ದಿನಾಂಕ: 30.04.2022.
4. COM(OP)/DGM(OP-3)/AGM-1/(OP-3)/F-341/24-25/CYS-16 dated : 03.05.2024

Copy to.

1. Asst. Executive Engineer (Ele), BESCO, Vidyanagara Sub-Divison.
2. Account Officer (F&C), BESCO, Hosakote Division, Hosakote.
3. The Section Officer, BESCO, Sadahalli O&M- of Vidyanagara Sub Division for information
- 4 M/s Sukhi Enterprises, Plot No. 3-A-5,& 3-A-6., Hi-Tech Defence & Aerospace Park) KIADB Sy No. 104P, Hoovinayakanahalli village





# Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/HKTD/AEE (O)/AE(T)/2024-25/3895

Office of  
Executive Engineer  
C, O&M DIVISION HOSAKOTE

To

M/s Sukhi Enterprises,  
Plot No 3-A-5 & 3-A-6,  
Sy No 104P at Hi-Tech Defence & Aerospace park,  
KIADB, Hoovinayakanahalli Village,  
Jala Hobli,  
Banglore North Talluk

Sir/Madam,

Sub: - Arranging HT power supply to an extent of 100 KVA in HT-2B Tariff in favour of M/s Sukhi Enterprises at Plot No 3-A-5 & 3-A-6, Sy No 104P at Hi-tech Defence & Aerospace park KIADB, Hoovinayakanahalli Village, Jala Hobli, Bangalore North Talluk in O&M Sadahalli in Vidyanagara Sub-Division under Self Execution

Ref: 1) Your Application Reg. No. 5020179 dated: 15 Jun 2024.  
2) Letter No: AEE/V.Nagara/AET/2024-25/934 dt. 01.07.2024

BESCOM is pleased to sanction for power supply to an extent of 100 KVA to the HT installation in favour of M/s Sukhi Enterprises at Plot No 3-A-5 & 3-A-6, Sy No 104P at Hi-tech Defence & Aerospace park KIADB, Hoovinayakanahalli Village Jala Hobli, Bangalore North Talluk in O&M Sadahalli in Vidyanagara Sub-Division under Self Execution. is hereby sanctioned subject to the following conditions:

1. Power supply will be arranged from F02-GAIL GAS feeder of 66/11 KV KIADB HARDWARE PARK\_220 Station.

2. You are requested to pay the following charges by DD/Cash (above 10000/- only DD will be accepted) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM VIDYANAGAR Sub-Division within 90 Days from the date of this intimation and furnish the payment certificate for taking further action in this matter

Payment Towards	Amount(Rs.)
Initial Security Deposit from consumers (48.101)	233000
5% Supervision Charges	91929
9% CGST on 5% Supervision Charges	8274
9% SGST on 5% Supervision Charges	8274
<b>Total</b>	<b>341477</b>

Amt In Words: three lakh(s) fourty one thousand four hundred and seventy seven only

3. To Submit payment certificate along with Self execution agreement on Rs. 200/- stamp paper regarding obtaining of necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.

4. The metering equipment to be installed should be conspicuously visible and at the main inference to the premises preferably with an independent entrance.

5. The power supply will be arranged at 11KV Voltage class.

6. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation

It is proposed to provide 5/1A CT's with HT ETV Meter 1A class 0.2s accuracy with TOD feature 3CT's 3PTs metering cubicle.

7. a) You should execute an agreement in the prescribed form and shall be submitted to the Executive Engineer Ele. of concerned division along with payment certificate.

b) Produce necessary Licensee/permit/NOC objection Certificate, etc. Issued by the competent authorities as required under statute.