



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/ANEKAL/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, ANEKAL Sub Division
BESCOM , ANEKAL

To
GOVERNMENT INDUSTRIAL TRAINING INSTITUTE
SYNO.11

Sir/Madam

Sub : Arranging power supply to an extent of **16.00 KW** in favor of GOVERNMENT INDUSTRIAL TRAINING INSTITUTE SY NO.11 in ANEKAL OMU, ANEKAL

Ref : 1) Your application registration **1321102260089** dated **11-FEB-2026**

2) AEE/ANEKAL /AE(T) a/ **24-MAR-2026**

With reference to your application dated **11-FEB-2026** . Requesting for arranging power supply to an extent of **16.00 KW** power installations in favor of GOVERNMENT INDUSTRIAL TRAINING INSTITUTE SY NO.11 in ANEKAL OMU,ANEKAL Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M ANEKAL sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1321102260089	13211022600890001	LT2-Rural-DOMESTIC LIGHTING & HEATING - LT2-B2	16.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1321102260089	13211022600890001	LT2-Rural-DOMESTIC LIGHTING & HEATING - LT2-B2	16.00 KW	61.9047-(WITH TAX) 5% Supervisory Charge(61.904)+CGST(46.9977)9%+SGST(46.9987)9%=(21093 + (21093*0.09) + (21093*0.09))	24889
1321102260089	13211022600890001	LT2-Rural-DOMESTIC LIGHTING & HEATING - LT2-B2	16.00 KW	48.1037-48.1037 - ASD	30
1321102260089	13211022600890001	LT2-Rural-DOMESTIC LIGHTING & HEATING - LT2-B2	16.00 KW	48.1017-48.1017 - ISD	15810
Total Amount in Rupees					41729

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT2-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM ANEKAL .

i. Intimation is valid up to 30 days from the date of issue.

You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.

Sl No	Description	Qty	Rate	GST (%)	Amount
1	LT AC 3 Phase 4 Wire, 10-60 Amps Smart Energy Meter, Class 1.0 Accuracy with Communication Module without Box	1	7203.3900	18 %	8500.00

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., ANEKAL Sub division, BESCOM for information and further needful.

Your's Faithfully,

Your's Faithfully,

**Assistant Engineer (Technical),
ANEKAL, BESCOM**

**Assistant Executive Engineer Ele.,
ANEKAL, BESCOM**

Copy to:

- 1.The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M ANEKAL Sub division, BESCOM.