



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/BIDADI/ (AET)

Office of the  
Assistant Executive Engineer Ele.,  
C,O&M, BIDADI Sub Division  
BESCOM, BIDADI

To  
Senior Manager  
Indian Oil Corporation Ltd

Sir/Madam

**Sub :** Arranging power supply to an extent of **60.00 KW** in favor of Senior Manager Indian Oil Corporation Ltd in BIDADI OMU, BIDADI

**Ref :** 1) Your application registration **1312109250010** dated **09-SEP-2025**

2) AEE BIDADI /AE(T) a/ **24-OCT-2025**

With reference to your application dated **09-SEP-2025** . Requesting for arranging power supply to an extent of **60.00 KW** power installations in favor of Senior Manager Indian Oil Corporation Ltd in BIDADI OMU, BIDADI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C. O&M BIDADI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1312109250010	13121092500100001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	62.9097-62.9097 - ESCOM Establishment Charges @ 10% on DCW(TAX)+CGST(46.9977)9%+SGST(46.9987)9%= (63483 + (63483*0.09) + (63483*0.09))	74909
1312109250010	13121092500100001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	61.9067-LT METERING CUBICAL TESTING CHARGES	4080
1312109250010	13121092500100001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1312109250010	13121092500100001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	47.3067-47.3067 - DCW(OTHERS)ESTIMATE COST - NO TAX	634828
1312109250010	13121092500100001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	48.1037-48.1037 - ASD	1760
1312109250010	13121092500100001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	48.1017-48.1017 - ISD	53440
Total Amount in Rupees					770017

- b. The power supply will be arranged at 400V .
- c. The Tariff applicable to your installation will be LT6(C), or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

770018