

Deposits	Amount in Rs	CGST @ 9%	SGST @ 9%	Total Amount in Rs
2 MMD for 410 KVA is Rs: 8,24,100/-	4,74,910/-	-	-	4,74,910/-
5% SC payable (Estimate Cost of Rs.47,023/-)	2351/-	212/-	212/-	2775/-
<b>TOTAL ( Four Lakh Seventy Seven Thousand Six Hundred and Eighty Five Rupees only)</b>				<b>4,77,685/-</b>

3. The appropriate tariff shall be applicable as per prevailing **KERC tariff order 2025** for BESCO.
4. You are liable to pay the tariff minimum charges from the date of commencement of supply (i.e., actual date of availing of power supply or expiry of 30 days' notice period issued by the BESCO whichever is earlier) as indicated in the agreement even if you fail to avail power supply.
5. You have to install approved shunt capacitors of appropriate capacity as to maintain the power factor at not less than 0.9
6. The power tariff applicable to your installation will be **HT-2(A)** tariff or as in force from time to time.
7. The location of HT metering cubicle should be nearer to main entrance to the premises preferably with an independent entrance at ground floor and the entire cubicle should be visible from the outside. Cubicle should be located at your premises in consultation with our Assistant Executive Engineer El., (C, O&M) Sub-Division at convenient location for easy access to BESCO staff at all time.
8. The necessary Transformer and other Accessories for arranging addl. Power supply if required to be installed by you.
9. In future, if the total load requirement exceeds 7500 kVA then the applicant/developer shall establish 66/11 KV substation at their own cost in the above premises under self-execution and avail power supply on 66 KV EHT bases as per KERC regulations.
10. The Power supply shall be arranged duly observing all corporate norms.
11. **11 KV** systems shall be as per KPTCL/ BESCO standard practices.
12. The applicant shall execute the works under self-execution through Karnataka State government approved Class-1 Electrical Contractor in co-ordination and under the guidance of KPTCL/BESCO officials.
13. The entire Distribution system with connected equipment's shall be taken over by KPTCL/ BESCO after completion of the works.
14. All the major materials like Transformer, ACSR conductor, Metering cubicle, HT UG cable, LT UG cable, 11 kV Pin insulators and 11 kV single / double break GOS shall be procured by the agencies only from the BESCO approved vendors and other materials may be procured from authorized dealers of approved vendors to BESCO. You have to utilize only Polymer insulators as per corporate circular vide Lr no. BESCO/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/CYS-113 dt 29-8-13.
15. The materials procured shall be in accordance with the IE/BESCO/KPTCL specifications and the materials shall be got inspected by **Jurisdictional Assistant Executive Engineer Ele.**, before procurement. The copies of the invoices / bills of the materials purchased shall be submitted as a proof of purchased from the approved vendors / dealers.
16. You shall submit the copies of the invoices / bills in respect of materials purchased by you for proof of having purchased the materials from the approved vendors / dealers.
17. Guarantee shall be furnished for a period of not less than "one year" for the material used for the works as well as for the quality of work carried out from the date of taking over the lines and equipment's by BESCO/ KPTCL.
18. Proof of having purchased the materials and used for execution of works from a reputed firm shall be verified wherever necessary.

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ  
(Bengaluru Electricity Supply Company)  
ಆರೋಗ್ಯ ಮತ್ತು ಸುರಕ್ಷತೆ ವಿಭಾಗ, ಚಂದಾಪುರ,  
ಬೆಂಗಳೂರು, ಬೆಂಗಳೂರು-560081  
ದೂರವಾರ್ತೆ: 944279027



BANGALORE ELECTRICITY SUPPLY COMPANY  
(A Government of Karnataka Undertaking)  
O&M Division, CHANDAPURA  
BESCOM, Bangalore-560081  
E-Mail: eechnopr.work@gmail.com

NO : EE(E)/CDP/AEE(O)/JET-1 /2025-26 / 14499-14500

Date : 23 MAR 2026

Power Sanction Letter for HT  
Additional Load

To,  
M/s Metalex Steel Strips Pvt. Ltd.,  
Plot No. 158,  
Jigani Bommasandra Link Road,  
Anekal Taluk,  
RR No. AKLHT-627

Sir,  
Sub:- Intimation for Arranging additional HT Power supply to an extent of  
210 KVA (Existing: 200 KVA + Add 210 KVA) Total 410 KVA to an  
existing HT installation bearing R.R No- AKLHT-627 Under HT2(A)  
in favour of M/s Metalex Steel Strips Pvt. Ltd, at Plot No. 158,  
Jigani Bommasandra Link Road, Anekal Taluk, Jigani sub division  
under Self Execution.  
Ref:- 1.Your Application No: 61324101260058/ 21.01.2026  
2. AEE, Jigani SD Office Letter Ref No : 9516 dated 09.05.2026  
\*\*\* \*\*\*\* \*\*

With reference to the above subject, as per the recommendations of the  
Assistant Executive Engineer (Ele), Jigani Sub-division vide ref-(2), power sanction is  
hereby issued for additional HT Power supply to an extent of 210 KVA (Existing: 200  
KVA + Add 210 KVA) Total 410 KVA to an existing HT installation bearing R.R No-  
AKLHT-627 Under HT2(A) in favour of M/s Metalex Steel Strips Pvt. Ltd, at Plot No.  
158, Jigani Bommasandra Link Road, Jigani sub division under Self Execution,  
subject to the following conditions and observance of BESCOM norms in force.

The proposed for arranging power supply is as follow:

Regular source:

Station: 66/11 KV Jigani Bommasandra Link Road MUSS which has a peak  
load of 34.5 MW with installed capacity of power transformers 2\*31.5 MVA.  
Feeder: Existing F-4 RLC wire feeder which has a peak load of 144 Amps with  
3x400 Sq.mm XLPE HT UG cable.

The following works are proposed under self-execution.

BESCOM portion.

1. Replace the existing 25/1 Amps 3CT by 25/1 Amps 3CT under self execution.
2. You are requested to pay the following amount by way of Demand Draft drawn in  
favour of the AEE, Jigani SD, BESCOM, at the office of Assistant Executive Engine  
(Ele), Jigani Sub-division, within 90 days from the date of this intimation and  
furnish the payment certificate to this office for taking further action failing which the  
power sanction will stand cancelled.