



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No. 29AACC814126125

AEE/NELAMANGALA (AE(T))

Assistant Executive Engineer
C.O&M, NELAMANGALA Sub-Division
BESCOM, NELAMANGALA

To
M/S DY PRIME PROPERTIES LLT
SURVE NO:25/2 NAGASANDRA DASANAPURA (H) BANGALORE NORTH 562123

Sir/Madam

Sub : Arranging power supply to an extent of 20.00 KW in favor of M/S DY PRIME PROPERTIES LLT SURVE NO:25/2 NAGASANDRA DASANAPURA (H) BANGALORE NORTH 562123 in NELAMANGALA DMU, NELAMANGALA

Ref : 1) Your application registration 61112103260032 dated 06-MAR-2026

2) AEE/NELAMANGALA /AE(T) dt 25-MAR-2026

With reference to your application dated 06-MAR-2026 Requesting for arranging power supply to an extent of 20.00 KW power installation in favor of M/S DY PRIME PROPERTIES LLT SURVE NO 25-2 NAGASANDRA DASANAPURA (H) BANGALORE NORTH 562123 in NELAMANGALA DMU, NELAMANGALA Sub-division is hereby sanctioned subject to the following Conditions,

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C. O&M NELAMANGALA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount (Rs)
61112103260032	5605660	LT7-TEMPORARY - LT7	20.00 KW	61.9067-61.9067-(WITH TAX) TRANSFORMER TESTING FEE+CGST(46.9977%) + SGST(46.9977%) + 1000 + (1000*0.09) + (1000*0.09)	11000
61112103260032	5605660	LT7-TEMPORARY - LT7	20.00 KW	61.9067-61.9067-(TAX) MATERIAL INSPECTION CHARGES+CGST(46.9977%) + SGST(46.9977%) + (5000) + (5000*0.09) + (5000*0.09)	9000
61112103260032	5605660	LT7-TEMPORARY - LT7	20.00 KW	61.90474-(WITH TAX) 5% Supervisory Charge(61.904) + CGST(46.9977%) + SGST(46.9977%) + (57249) + (57249*0.09) + (57249*0.09)	67853
61112103260032	5605660	LT7-TEMPORARY - LT7	20.00 KW	47.3017-ACC	10000
Total Amount in Rupees					214653

i. The power supply will be arranged at 0V .

. The Tariff applicable to your installation will be LT7, or the Tariff in force From time to time.

You have to enter into an agreement with the BESCOM in the prescribed form.

Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

Energy meter should be placed outside the premises at the height of 5ft from the ground level

Amount through DD should be paid in the name AEE BESCOM NELAMANGALA .

Sanctionment is valid up to 30 days from the date of issue.

If the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will be CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., NELAMANGALA Sub-Division, BESCOM for information and further needful.

Sincerely,
Y's Faithfully,

Your's Faithfully,

Raise Ticket to update Acc
as 145200/-
25/3/26



Bangalore Electricity Supply Company Limited

FILE/AEE(O)/NEL/AET/25-26/ 17423-24

OFFICE OF THE
EXECUTIVE ENGINEER, ELE.,
C. O&M DIVISION, BESCO,
NELAMANGALA.
18/3/26

To,
M/s. DY Prime Properties LLP
sy no. 25/2 at Nagasandra village
Sondekoppa section of
Nelamangala sub division

SUB: For Providing for erection of new 1*63 KVA Transformer for arranging an addl. 17 KW power supply with existing 03 KW Total 20 KW bearing RR No. NTP-30146 in favour of M/s. DY Prime Properties LLP sy no. 25/2 at Nagasandra village Sondekoppa section of Nelamangala sub division under self execution

REF: 1. AEE/AET/NEL/25-26/14945 dtd. 17.03.2026

With reference to your application requesting for Providing for erection of new 1*63 KVA transformer for arranging an addl. 17 KW power supply with existing 03 KW Total 20 KW bearing RR No. NTP-30146 in favour of M/s. DY Prime Properties LLP sy no. 25/2 at Nagasandra village Sondekoppa section of Nelamangala sub division under self execution

are pleased to sanction the power with the following terms and conditions.

The power supply will be arranged at 400 Volts.

The tariff applicable to your installation will be under LT-07 Tariff in force.

You have to enter into an agreement with the Corporation in the prescribed format as per Electricity supply and distribution code 2005-07 and allied amendments.

You have to pay ACC charges of Rs. 145200/- (One Lakh Forty Five Thousand & Two Hundred rupees) by cash/DD at the office of the Asst.Exec. Engineer (Ele) Nelamangala sub Division

05% S/C Rs. 57249/- (Fifty Seven thousand Two Hundred & Forty Nine rupees only)

09% CGST Rs. 5152/- (Five Thousand One Hundred & Fifty Two rupees only)

09% SGST Rs. 5152/- (Five Thousand One Hundred & Fifty Two rupees only)

Material Inspection charges Rs. 5000/- (Five Thousand rupees only)

09% CGST Rs. 450/- (Four Hundred & Fifty rupees only)

09% SGST Rs. 450/- (Four Hundred & Fifty rupees only)

TC testing charges Rs. 1000/- (One Thousand rupees only)

09% CGST Rs. 90/- (Ninety rupees only)

09% SGST Rs. 90/- (Ninety rupees only)

DD Must be drawn from any nationalized bank in favour of Asst.Executive Engineer (Ele) BESCO Nelamangala sub-division. You have to Submit the contractor's completion-cum-test report along with wiring diagram in duplicate.

Furnish occupancy certificate from the competent authority wherever applicable before service

You should provide circuit breakers of appropriate capacity (MCB) and Current Operated Earth Leakage relay (ELCB) as prescribed by the BESCO, Which must be erected with in one meter of the Company's meter Board in such other position as shall be approved by the Company as per Regulation 409. No fuses shall be provided on the neutral conductor.

KERC 12th Amendment clause 3.2.5, the required Electric line/Plant charges are to be collected as per Clause 3.2.3(i) IFC & 3.1.1(A) SLC shall be collected as per BESCO norms.

As per the KERC 10 Amendment cited vide reference-4 and recovery of expenditure KERC 12th Amendment

This approval is only for above mentioned (01 Applicants). In case of new applications registered for the left out sites in the same Survey No. the power supply may be arranged duly obtaining approval as per the

BESCO Norms.