



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. SEE/BRC/EE(O)/AEE(O)/F-1(B)/2025-26/5340-42

Encl:

Ph No. 080-28482437 / 94482 79007  
Email ID: sebrco@bescom.co.in

To,  
M/s. Indian Oil Corporation Ltd Represented by  
it's manager Sri. Shailendra Singh Patel,  
Sy No. 259/3, T.Begur Village, Kasaba Hobli,  
Nelamangala Taluk-562123.

Sir,

Office of the  
Superintending Engineer (Ele),  
(C, O&M), B'lore Rural Circle,  
BESCOM, KSSCL, 5th Floor,  
"Beeja Bhavan", Bellary Road,  
Hebbal, Bangalore -560024.

Date: 30 SEP 2025

## Revised Intimation

**Sub:** Arranging power supply to an extent of 60 KW EV Charging Station under LT-6(c), [in the existing premises already having a SL of 34KW bearing RR No: NP-3056 under LT-3(a)] = Total 94KW in favour of M/s. Indian Oil Corporation Ltd Represented by it's manager Sri. Shailendra Singh Patel, Sy No. 259/3, T.Begur Village, Kasaba Hobli, Nelamangala Taluk in O&M-2 Unit of Nelamangala Sub-division of Nelamangala Division, "Under DCW Basis". (Application ID: 9762840)

- Ref:**
1. As per 7th Amendment & 11th Amendment of ROE.
  2. Corporate office circular No. BESCOM/CGM(O)/DGM(OP-3)/AGM-1/21-22/Cys-134 Dated: 09.11.2021.
  3. KERC/COS/DDD/1/2018-19/908, Bengaluru Dated: 22.10.2019.
  4. Meeting Proceeding Ltr No. BESCOM/CGM(OP)/DGM(EV)/BC-3/2023-24/716 Dated: 12.12.2023.
  5. BESCOM/BC-53/CGM(OP)/DGM(EV)/2023-24/362 Dated: 18.08.2023.
  6. BESCOM/CGM(OP)/DGM(OP3)/AGM(OP)/2024-25/CYS-70 Dated: 07.10.2024.
  7. EEE/NEL/AEE(O)/AE-1/2025-26/5638 Dated: 24.07.2025
  8. T.O earlier power sanction Ltr No: SEE/BRC/EE(O)/AEE(O)/F-1(B)/2025-26/2550-51 Dated: 04.08.2025.
  9. T.O Note Approved Dated: 30.09.2025.

\*\*\*\*\*

With reference to the above BESCOM is pleased to sanction power to execute the work of arranging power supply to an extent of 60 KW EV Charging Station under LT-6(c), [in the existing premises already having a SL of 34KW bearing RR No: NP-3056 under LT-3(a)] = Total 94KW in favour of M/s. Indian Oil Corporation Ltd Represented by it's manager Sri. Shailendra Singh Patel, Sy No. 259/3, T.Begur Village, Kasaba Hobli, Nelamangala Taluk in O&M-2 Unit of Nelamangala Sub-division of Nelamangala Division, "under Self-Execution Basis". subject to the following conditions:

The 11 kV line of **BF-2 Indusfila Feeder** which is emanating from 66/11 KV **T.Begur MUSS**. The Station installed

- 1) Capacity of 2x20 MVA & the Station peak load is 26 MW. The Bank-2 600 Amps & the feeder peak load of 140 Amps. The HTVR works out 2.76%.
- 2) You have to pay the following amount at **Nelamangala** Sub-division, BESCOM within a period of 90 days from the date of this power sanction.
- 3) The Total Estimate Costing of **Rs. 10,86,276/- "Under DCW basis"**. (Application ID: 9762840)

SlNo	Deposit details	Amount in Rs
1	2MMD for 60 KW under LT-6(c)	Rs. 54,840/- x 01
2	DCW Cost	Rs. 10,86,276/-
3	5% Tender Premium on DCW cost	Rs. 54,314/-
4	9% CGST on Sl No. 05	Rs. 4,888/-
5	9% SGST on Sl No. 05	Rs. 4,888/-
6	5% ESCOM Establishment Cost on Total DCW Cost	Rs. 54,314/-
7	9% SGST on Sl No. 08	Rs. 4,888/-
8	9% SGST on Sl No. 09	Rs. 4,888/-

- 4) The clause 8.14(ii) is applicable defined in COS of KERC.  
**As per reference-5**, the Metering arrangements for consumer availing load between 50 KW to 150 KW at low tension shall be as follows:
  - a. 01 No of CT & PT operated 0.2S accuracy class meter with provision for check meter.
  - b. 03 Nos of LT CT's of 0.2s accuracy class with burden of 2.5 VA and secondary current 1A.
  - c. 03 Nos of LT PT's of 0.2 accuracy class with burden of 5 VA and ration 440/3/110/3 volts.
  - d. 01 No. 9f Modem
  - e. 02 No of test terminal Block and suitable bus bar.
- 5) You should abide by the conditions of supply of electricity of Distribution Licensees in State of Karnataka in force with subsequent amendments.
- 6) The materials used shall confirm to ISI /BESCOM/KPTCL specifications and the materials procured should be got inspected before commencing of work by TA & QC or BESCOM authorities.
- 7)



8) You shall submit copies of the invoices / bills in respect of materials purchased by you for proof of having purchased the materials from the approved vendors /dealers.

All the major materials like Distribution transformer & transformer mounting structures, ACSR conductor, HT UG cable, LT UG cable, 11 KV Pin insulators and 11 KV single / double break GOS, shall be procured by the agencies

9) only from the BESCOM approved vendors and other materials may be procured from authorized dealers of approved vendors to BESCOM you have to utilize only polymer insulators as per corporate circular vide letter no BESCOM/BC-9/CGMCA/DGM(CA-3)/F-752/13-14/CYS 113. Dated 29.08.2013.

10) Guarantee shall be given by the developer for a period of one year for the materials used in the works as well as for the quality of work carried out, from the date of taking over of the distribution system and transformers by the BESCOM.

11) Proof of having purchased the materials used for execution of works from the reputed firm will be verified wherever necessary.

12) You have to furnish the approval of Electrical Inspectorate for new HT / LT lines / DTCs etc., which ever applicable.

13) BESCOM is not responsible in whatsoever manner regarding any of legal or local planning authority disputes that may arise at a later stage and deposits paid will be forfeited and power supply will be disconnected.

14) After payment of supervision charges and conditions to be fulfilled, the administrative approval will be issued from concerned Sub-division / Division / Circle office.

15) For all EHT and HT / LT lines passing through the layout safety clearance to be maintained (statutory) or shifting of existing lines to be done at your cost

16) You have to produce NOC from respective PGCIL/KPTCL in case if any EHV lines are passing in the layout before availing power supply to the layout.

17) You should clear the outstanding arrears if any of the installations inside the applicant premises.

18) You should abide by the conditions of supply of electricity of Distribution Licensees in State of Karnataka in force with subsequent amendments.

19) In future, the applicant has to pay any variation / difference of charges, if any, payable to BESCOM.

20) The released materials, if any as per 7th schedule credit estimate shall be handed over to the concerned divisional stores.

21) **After completion of work, joint inventory as prescribed vide chief Controller of Accounts, Circular No. AP/CYS-10/92-93/20-04-1992 (Page-246 of Compendium Vol-I) shall be taken and the assets shall be accounted in the books of company.**

22) In case, if applicant fail to meet the above conditions to arrange power supply the Intimation letter is deemed to be cancelled.


23) Any delay in making the payment, not fulfilling the above payments within 90 days, the power sanction / application deemed to have been cancelled as per the conditions stipulated in the KERC Amendment vide clause No. 4.03 (ii). The registration cum processing fee paid shall stand forfeited.

- 24) i. It is proposed to provide 11KV UG Cable (3x95Sqmm, XLPE) to a distance of 90Mtr from the proposed SP structure upto the proposed 100 KVA transformer.  
ii. It is proposed to provide new 1x100KVA Oil Type Distribution Transformer.  
iii. It is proposed to provide LT Metering Cubicle with modem & meter.  
iv. It is proposed to provide LT UG Cable.

**Note: For any 765/400/220/66/11 KV lines passing adjacent/ nearby/ on the premises, mandatory clearance certificate should be obtained from the competent authority by the developer / concerned EE of BESCOM before servicing of the installation. In case of any deviation in this regard concerned officers will be held responsible**

The above mentioned amounts should be paid within 90 days from the date of this letter at the **Nelamangala** sub division failing which this intimation will be deemed to be cancelled. And payment certificate duly signed by the Assistant Executive Engineer, **Nelamangala** Sub-Division to be sent to this office for communicating approval. Any delay beyond this would require renew of the feasibility which may please be noted.

Yours faithfully,

  
(Basavanna.C)  
Superintending Engineer (Ele).,  
BRC, BESCOM, Bangalore

Copy to:

1. The Executive Engineer (Ele), C, O&M, **Nelamangala** BESCOM for information.
2. The Assistant Executive Engineer (Ele), C, O&M, **Nelamangala** Sub-division, BESCOM for information.
3. **MF/F-1(B).**



Kiran Petrolum



Bengaluru Electricity Supply Company Limited  
(Wholly Owned Government of Karnataka Undertaking)  
BESCOM GSTN No. 29AACCB14126125

Office of the Assistant Executive Engineer Ele., C,O&M,  
NELAMANGALA Sub Division BESCOM,  
NELAMANGALA

At: NELAMANGALA (A/E)

To

INDIAN OIL CORPORATION LIMITED  
T.BEGURU, KASABA HOBLI, NELAMANGALA TALUK.

Sir/Madam

Sub: Arranging power supply to an extent of 60.00 KW in favor of INDIAN OIL CORPORATION LIMITED T.BEGURU, KASABA HOBLI, NELAMANGALA TALUK, in NELAMANGALA OMU, NELAMANGALA

Ref: 1) Your application registration 9762840 dated 20-DEC-2024

2) A/E NELAMANGALA (A/E) dt: 22-SEP-2025

With reference to your application dated 20-DEC-2024 Requesting for arranging power supply to an extent of 60.00 KW power installations in favor of INDIAN OIL CORPORATION LIMITED T.BEGURU, KASABA HOBLI, NELAMANGALA TALUK, in NELAMANGALA OMU, NELAMANGALA Sub division in hereby sanctioned subject to the following Conditions.

a) You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M NELAMANGALA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
9762840	11249714	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	62.9097-62.9097 - Tender Premium @ 5% on DCW+CGST(46.9977)9%+SGST(46.9987)9%=(64090.90	64090.90
9762840	11249714	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	47.3067-47.3067 - DCW(OTHERS)/ESTIMATE COST - NO TAX	1086276
9762840	11249714	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	48.1017-48.1017 - ISD	54840
9762840	11249714	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	62.9097-62.9097 - ESCOM Establishment Charges @ 5% on DCW(TAX)+CGST(46.9977)9%+SGST(46.9987)9% = (64090 + (64090*0.09) + (64090*0.09))	64090
Total Amount in Rupees					1269296

54314 + 54314 + 8

- b) The power supply will be arranged at 0V  
c) The Tariff applicable to your installation will be LT6(C), or the Tariff in force From time to time.  
d) You have to enter into an agreement with the BESCOM in the prescribed form.  
e) Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.  
f) You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.  
g) Energy meter should be placed outside the premises at the height of 5ft from the ground level.  
h) Amount through DD should be paid in the name AEE BESCOM NELAMANGALA.  
i) Intimation is valid up to 30 days from the date of issue.  
In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., NELAMANGALA Sub division, BESCOM for information and further needful.

Your's Faithfully,

Assistant Engineer (Technical)  
NELAMANGALA, BESCOM

Your's Faithfully,

Assistant Executive Engineer Ele.,  
NELAMANGALA, BESCOM

Copy to

- 1 The Executive Engineer Ele C, O&M NELAMANGALA Division, BESCOM
- 2 The Asst Executive Engineer Ele C,O&M NELAMANGALA Sub division, BESCOM